

AUG 07 1998

STATION 4

25

ENGINEERING DATA TRANSMITTAL

Page 1 of 1

1. EDT 622241

2. To: (Receiving Organization) Distribution		3. From: (Originating Organization) TWRS Projects/SST Retrieval		4. Related EDT No.: n/a	
5. Proj./Prog./Dept./Div.: D2991 W-320 TWRS/TCPN # B2MA1		6. Design Authority/ Design Agent/Cog. Engr.: JW Bailey, NHC		7. Purchase Order No.: n/a	
8. Originator Remarks: For approval and release of a new supporting document. This document has been generated to ensure retrievability of the Project W-320 "HVAC Calculations, Vol. 1".					
11. Receiver Remarks:		11A. Design Baseline Document? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		9. Equip./Component No.: n/a	
				10. System/Bldg./Facility: 241-C-106	
				12. Major Assm. Dwg. No.: n/a	
				13. Permit/Permit Application No.: n/a	
				14. Required Response Date:	

15. DATA TRANSMITTED					(F)	(G)	(H)	(I)
(A) Item No.	(B) Document/Drawing No.	(C) Sheet No.	(D) Rev. No.	(E) Title or Description of Data Transmitted	Approval Designator	Reason for Transmittal	Originator Disposition	Receiver Disposition
1	HNF-2483	-	0	Project W-320, 241-C-106 Sluicing, HVAC Calculations, Vol. 1	NA			-

16. KEY		
Approval Designator (F)	Reason for Transmittal (G)	Disposition (H) & (I)
E, S, Q, D or N/A (see WHC-CM-3-5, Sec.12.7)	1. Approval 2. Release 3. Information	4. Review 5. Post-Review 6. Dist. (Receipt Acknow. Required)
	1. Approved 2. Approved w/comment 3. Disapproved w/comment	4. Reviewed no/comment 5. Reviewed w/comment 6. Receipt acknowledged

17. SIGNATURE/DISTRIBUTION (See Approval Designator for required signatures)											
(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN	(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN
2	1	Design Authority	<i>JW Bailey</i>	7/25/98	S2-48						
		Design Agent	<i>MC Davenport</i>	7/25/98							
2	1	Cog. Eng.	<i>EE Greaves</i>	7/25/98	S2-48						
2	1	Cog. Mgr	<i>JW Bailey</i>	7/25/98	S2-48						
		QA									
		Safety									
		Env.									

18. <i>MC Davenport</i> Signature of Edr Originator Date: 3/24/98		19. <i>JW Bailey</i> Authorized Representative Date for Receiving Organization		20. <i>JW Bailey</i> Design Authority/ Cognizant Manager Date: 7/25/98		21. DOE APPROVAL (if required) Ctrl. No. <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/comments <input type="checkbox"/> Disapproved w/comments	
---	--	---	--	--	--	--	--

# Project W-320, 241-C-106 Sluicing HVAC Calculations, Vol. 1

John W. Bailey  
Numatec Hanford Co., Richland, WA 99352  
U.S. Department of Energy Contract DE-AC09-96RL13200

EDT/ECN: 622241 UC: 506  
Org Code: 8C452 Charge Code: D2991/HANA0600  
B&R Code: EW3130010 Total Pages: 153


Key Words: W-320, Sluicing, Tank 241-C-106, Tank 241-AY-102, WRSS,  
calculations, HVAC.

Abstract: This supporting document has been prepared to make the FDNW  
calculations for Project W-320, readily retrievable.

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by  
trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its  
endorsement, recommendation, or favoring by the United States Government or any agency thereof or  
its contractors or subcontractors.

Printed in the United States of America. To obtain copies of this document, contact: Document  
Control Services, P.O. Box 950, Mailstop H6-08, Richland WA 99352, Phone (509) 372-2420;  
Fax (509) 376-4989.

*Kara Broz*  
\_\_\_\_\_  
Release Approval  
8/7/98  
\_\_\_\_\_  
Date



Approved for Public Release

*Cover sheet  
page 1 of 2*

### APPLICATION FOR PERMISSION TO USE YOUR COPYRIGHTED MATERIAL

To: NEW YORK BLOWER

Date: 07/29/98

Permission is requested to reproduce the following copyrighted material from:

FAN CURVE FROM NEW YORK BLOWER COMPANY BULLETIN. DATE: 3/1/1994. SIZE: 2606;  
TAG: 2DT; CFM: 360.

Selections from text (specify by date of issue, page, paragraph, or illustration if desired, attach a copy of the material in question):

FAN CURVE

Title of work or project in which this material will be included:

W-320 PROJECT DOCUMENTATION

Estimated publication date: 07/31/98

Author: O.D. NELSON

Publisher (if applicable): HANFORD SITE (RICHLAND, WASHINGTON)

If the copyrighted material is not to be used in a published work, please provide a brief description of how it is to be used:

N/A

A self-addressed stamped envelope is enclosed for your reply.

Name: OWEN D. NELSON

MSIN: S2-48 Date: 07/29/98

Signature: for O.D. Nelson (see selection) (Rich. Dickerson)

Credit line (if required):

Application approved by:

Name: Thomas P Hamilton

Date: 7/30/98

Company Name: NEW YORK BLOWER

Signatory's Position: NATE SALESMAN

Signature: Thomas P Hamilton

(on behalf of) NIB

HNF-2483, Rev 0  
Cover Sheet  
page 2 of 2

## Project W-320, 241-C-106 Sluicing HVAC Calculations, Vol. 1

### TABLE OF CONTENTS

Calc. No.	Title	Page
W320-28-001	Exhaust Airflow Sizing for Tank 241-C-106	A-i
W320-28-003	Equipment Sizing & Selection Recirculation Fan	B-i
W320-28-004	Sizing High Efficiency Mist Eliminator	C-i
W320-28-005	Sizing Electric Heating Coil	D-i
W320-28-006	Equipment Sizing & Selection Recirculation Condenser	E-i
W320-28-007	Chiller Skid System Sizing and Selection	F-i
W320-28-008	High Efficiency Metal Filter Shielding Input and Flushing Frequency	G-i
W320-28-011	Exhaust Skid Stack Sizing and Fan Sizing	H-i

W320-28-001

Exhaust Airflow Sizing for  
Tank 241-C-106



## DESIGN ANALYSIS

Client WHC

Subject W-320 Exhaust Airflow Sizing for Tank  
241-C-106

Location 241-C Farm, 200 East

WO/Job No. ER4319

Date 3/28/95

Checked 3/31/95

Revised

By PH Langowski

By *T. Am*

By

### 1.0 OBJECTIVE

The objective of this calculation is to determine the range of exhaust airflow design values required for Tank 241-C-106 during active sluicing retrieval operations.

### 2.0 DESIGN INPUTS

#### 2.1 CRITERIA AND SOURCE

DOE General Order 6430.1A

Functional Design Criteria WHC-SD-W320-FDC-001, rev. 2, 1-18-94

#### 2.2 GIVEN DATA

- none

#### 2.3 ASSUMPTIONS

- Assumed C-106 tank minimum operating pressure of -2.00" water gauge (w.g.). This assumes that the operating pressure setpoint will be approximately -1.50" w.g. with a range of control that would limit the minimum pressure to -2.00" w.g. under normal operating conditions. Operating pressure setpoint is stated as -1.50" w.g. on ref. 6.

- Assumed the C-105 airspace temperature is equal to 80F and a vaporspace pressure of -1.00" water gauge due to continuing radiolytic heat input. C-105 was formerly designated a high-heat watchlist tank and is estimated to have between 20,000 and 25,000 Btu/h of radiolytic heat generation in January, 1991 per Figure 12 of ref. 3 (see Appendix A). The thermal analysis shows that the temperature in C-105 may reach 120F if the ventilation is ceased. With a C-105 ventilation rate of approximately 1,000 cfm at a tank pressure of -1.0" water gauge (similar to actual conditions on 2/5/91 data), the tank average annual air temperature should be approximately 80F.

- Assumed a maximum infiltration rate of 250 scfm into tank C-106 through the three existing pits with cover blocks and the additional riser flanges. Actual infiltration will be less with the installation of the sealing tape from the W-030 project and proper operating procedures. This assumes that the three cover blocks currently in place on C-106 are replaced with new cover blocks which will have covers for all penetrations (2" valve handle holes and others) through the cover blocks. The design of new, low-infiltration cover blocks is the current design assumption and design philosophy. Psychrometric data from DST's AW, AN, and AP (see Appendix A) shows that 250 scfm is a reasonable assumption for the maximum infiltration through the three existing cover blocks.

#### 2.4 METHODS

Hand calculations and Excel spreadsheet using ASHRAE formulae.

## DESIGN ANALYSIS

Client WHC  
 Subject W-320 Exhaust Airflow Sizing for Tank  
 241-C-106

WO/Job No. ER4319

Date 3/28/95

By PH Langowski

Checked 3/31/95

By *P. Langowski*

Location 241-C Farm, 200 East

Revised

By

### 2.5 REFERENCES

1. WHC-SD-WM-ANAL-012, Rev. 1, "Flow Analysis for Single Shell Tanks", p. 2
2. W320ER1.TD.395, "Tank 241-C-106 Stuiicing Tank Farm Riser Usage and Pit Modifications," 9/93.
3. WHC-SD-WM-ER-189, Rev. 0, "Thermal Analysis of Tank 241-C-105 in Support of Process Test," Figure 12, January 1993.
4. WHC-EP-0651, Rev. 0, "Barometric Pressure Variations," June 1993.
5. W320-H-011, Rev. 0, "Exhaust Skid Stack Sizing and Fan Sizing"
6. H-2-818468, draft 21, 3-17-95, "Overall Flow Diagram C-106"
7. HW-72743, Rev. 19, "75'-0" Dia Storage Tanks Arrangements"
8. ASHRAE Fundamentals 1993

### 3.0 CALCULATIONS

The total airflow into Tank 241-C-106, and hence, the total exhaust flowrate from C-106 is estimated to be made of two components: 1) the infiltration through the three pit cover blocks and into the pit drains and infiltration through riser flanges outside of the pits on Tank C-106, and; 2) the inflow through the 3" cascade line which connects tank C-106 to tank C-105.

#### 3.1 Infiltration

Riser Study ref. 2 (see Appendix A) details the current existing risers on Tank C-106. There are fourteen risers listed on the summary, seven of which are located inside the three pits. Of the remaining seven, one is covered with dirt and could be assumed sealed airtight. Of the remaining six, there are four 4" and two 12" risers. It is expected that all three existing pits on C-106 will have large openings into the tank and that the pit cover blocks will be the limiting infiltration path. No new risers are currently planned to be constructed under W-320. The existing 3" floor drains in the three existing pits are not planned to be used after W-320 construction. The risers through which the pumps are inserted are planned to have perforated spacer rings which will provide a large drain opening to the tank. This large opening is thought to be required based on the accident scenario of 350 gpm spilling into the pit.

A calculation of infiltration into the C-106 tank with the equipment installed in the risers is severely dependent on the crack width assumptions used on each riser flange and on the pit cover blocks. This calculation was not undertaken due to its inherent low reliability. The maximum 250 scfm infiltration rate for a 75' diameter tank with three pits is based on psychrometric data from existing DST's (see Appendix A) which showed a wide range of airflows, generally in the 100 to 200 cfm range, but with a few big exceptions. DST's generally have at least twice as many risers as SST's. The high end of the general range of the DST infiltration data was used.

The W-320 design assumes that the pit cover blocks are sealed so that the size of the drains in the pits is unimportant. This would yield infiltration rates near zero with only the purge air used for the FIC, purge air for the pressure transmitter PIT-1361 at Hatchway Riser R-15, the CCTV purge air, and the infiltration through the riser flanges on risers located outside of the pits or through penetrations in the pit cover blocks as contributors. This is a partially unrealistic assumption. Even if the pits are

## DESIGN ANALYSIS

Client WHC

WO/Job No. ER4319

Subject W-320 Exhaust Airflow Sizing for Tank  
241-C-106

Date 3/28/95

By PH Langowski

Location 241-C Farm, 200 East

Checked 3/31/95

By *C. Pina*

Revised

By

sealed there will be times when the seals are broken for maintenance of items in the pits, or infiltration due to lack of maintenance of the seals themselves. The 250 scfm maximum infiltration assumption should prove conservative. For calculations where a normal operating flow rate is specified, 170 scfm shall be used.

The ref. 1 flow analysis report (see Appendix A) discusses infiltration rates into single shell tanks for various combinations of risers, pit drains, and pressures. For 2" w.g. pressure drop, the following infiltration rates were calculated: 23 cfm for a tank with sealed pits; 425 cfm for a tank with cover blocks off and pit drains sealed 50%; 819 cfm for a tank with cover blocks off and pit drains 100% open; and, 2819 cfm for a tank with an open inlet filter and 100% open pit drains. Pit drains are the standard 3" drains in the flow analysis report. The 250 scfm maximum infiltration assumption is reasonable in this context.

### 3.2 Inflow Through Cascade Line

The airflow through the 3" (ref. HW-72743 see Appendix B) cascade line of approximately 30' length from C-105 is calculated by assuming a delta pressure drop along the cascade line. Thirty feet of pipe with a 2" w.g. delta pressure drop would require a pressure drop of approximately  $(2")(100'/30")=6.67"$  w.g. per 100' of pipe and require a substantial velocity. The entrance and exit losses should not be neglected at these high velocities.

The C-105 entrance is a 4" schedule 80 pipe on the OD with the 3" cascade line inside overhanging the sidewall of the tank by 12". The C-106 exit side is the 3" cascade line overhanging the tank by 4' (see ref. 7). ASHRAE Fundamentals 1993 fitting ED1-1 was assumed to model the entrance in C-105 (See Appendix B). Using Schedule 80 pipe data (see Appendix B). For C-105:  $2t=4.5"-2.9"=1.6"$ , so  $t=0.8"$ ;  $L=12"$ ;  $D=2.9"$ ;  $t/D=0.8/2.9=0.276$ ;  $L/D=12/2.9=4.14$ ; from the table  $C_c=0.50$ . The exit in C-106 can use  $C_c=1.00$  since the airstream decelerates to zero velocity.

Appendix B contains a simple Excel spreadsheet which proved useful in iterating in on an airflow with a given delta pressure. ASHRAE Fundamentals (ref. 8) equations as listed on the spreadsheet were used to calculate friction factors and pressure loss through the piping. The entrance and exit losses which are dependent on velocity pressure are also included. The spreadsheet shows that a normally expected cascade airflow of 60 scfm of 80F air can be expected at 0.5" w.g. total pressure drop between the two tanks. The same spreadsheet yielded 103 scfm of 120F air and 108 scfm of 80F air at 1.5" w.g. total pressure drop simulating the case of C-105 not being ventilated. 110 scfm shall be used as the maximum cascade line airflow.

### 3.4 Minimum Airflow

DOE Order 6430.1A, para. 1550-99.0.3 "Offgas Systems", states that "the design of process confinement off-gas treatment systems shall preclude the accumulation of potentially flammable quantities of hydrogen generated by radiolysis or chemical reactions within process equipment." Review of SY-101 hydrogen generation was undertaken to investigate an assumed worst case. Scaling down an estimated 241-SY-101 steady-state hydrogen generation rate of 2.24 scfh based on total mass yields a C-106 steady-state hydrogen generation rate of 0.33 scfh. To operate safely below the lower

## DESIGN ANALYSIS

Client WHC  
 Subject W-320 Exhaust Airflow Sizing for Tank  
 241-C-106

WO/Job No. ER4319

Date 3/28/95

Checked *4/2/95*

Revised

By PH Langowski

By *PL*

By

Location 241-C Farm, 200 East

explosive limit only 1 scfm need be exhausted. The W-030 flammability calculations yielded a 3 scfm fresh air sweep requirement. The W-320 airstream characterization lists no flammable components.

Minimum airflow for infiltration should address the tank breathing rate due to changes in atmospheric pressure. Barometric Pressure Variation Report ref. 4 (see Appendix A) analyzes data for 1988-1991 as measured at the Hanford Weather Station located between 200E and 200W. The report presents the average breathing rate as 0.005639 inches of mercury per hour. It also presents hourly swing data. The largest value which occurred through the four year data collection is 0.12 inches of mercury per hour. The report presents annual average barometric pressures ranging from 29.22 to 29.26 inches mercury. The thirty year average for 1950 to 1980 is presented as 29.21 inches of mercury.

Assuming ideal conditions, the % volume change in one hour would be:

$$0.005639/29.21 = 0.0193\% \text{ volume change per hour (average)}$$

$$0.12/29.21 = 0.41\% \text{ volume change per hour (maximum)}$$

A 530,000 gallon single shell tank consists of a 75' diameter cylinder which is 18' tall, a 12' tall dome, and a 1' deep dished bottom. The total tank volume would be:

$$\text{cylinder: } (\pi * 75^2 / 4) (18) = 79,522 \text{ cubic feet}$$

$$\text{dish: approximately } (\pi * 75^2 / 4) (0.5) = 2,209 \text{ cubic feet}$$

$$\text{dome: approximately } \pi * 75^2 * 12 / 8 = 26,507 \text{ cubic feet (paraboloid)}$$

The total tank volume (neglecting any waste in the tank) is approximately:

$$79,522 + 2,209 + 26,507 = 108,238 \text{ cubic feet}$$

At the average hourly volume change this yields:

$$(0.000193 \text{ volume/hour})(108,238 \text{ cubic feet})(1 \text{ hour}/60 \text{ minutes}) = 0.35 \text{ cfm}$$

At the maximum hourly volume change this yields:

$$(0.00411 \text{ volume/hour})(108,238 \text{ cubic feet})(1 \text{ hour}/60 \text{ minutes}) = 7.4 \text{ cfm}$$

The maximum flowrate of 7.4 cfm is the most that could be expected through infiltration due to pressure variations.

The minimum airflow requirement to properly operate the high pressure blower exhaust fan may prove to be a concern when detailed selection of fan and controls is undertaken. Calculation ref. 5, lists a potential fan for consideration. The fan should be able to operate down at any reduced airflows below the 180 scfm minimum sizing range since a radial high pressure blower can function down to shut-off routinely.

## DESIGN ANALYSIS

Client WHC

WO/Job No. ER4319

Subject W-320 Exhaust Airflow Sizing for Tank  
241-C-106

Date 3/28/95

By PH Langowski

Location 241-C Farm, 200 East

Checked *3/31/95*By *T. P. ...*

Revised

By

### 4.0 FINDINGS & CONCLUSIONS

The total maximum exhaust airflow is the sum of the 250 scfm infiltration airflow, and the 110 scfm cascade line flow. This yields a total maximum exhaust design airflow of 360 scfm. 360 scfm should be used for maximum exhaust design airflow purposes. Normal operating design airflow would be 60 scfm cascade flow, plus 170 scfm infiltration flow for a total of 230 scfm.

The proposed 360 scfm maximum exhaust air system can maintain the tank vapor space pressure at -1.50" water gauge under the worst case assumptions. 360 scfm should be used for maximum exhaust airflow sizing of equipment. The minimum absolute total exhaust airflow if Tank C-105 were actively ventilated to an equal or more negative pressure than C-106 (or the cascade line is plugged) and infiltration is extremely small should be considered to be 70 scfm infiltration (assumed). Neither of these two scenarios are deemed likely. For design purposes, the minimum exhaust airflow should be considered to be 60 scfm cascade flow (0.5" w.g. cascade line pressure drop) plus 120 scfm infiltration for 180 scfm total.

APPENDIX A

HNF-2483, Rev. 0  
Page A-7

*PHR 3/31/95*  
*W320-28-001 rev 1 PHR*  
*4395*

Figure 12. Calculated Temperatures to Year 2002.  
(Level 3 — Level 4 +++)




Table 1. Maximum Temperatures for Dry Out Transient.

	Ventilation (600 ft <sup>3</sup> /min)		Ventilation off	
	0.2	0.1	0.2	0.1
Minimum Waste Conductivity (Btu/(h ft °F))	0.2	0.1	0.2	0.1
Maximum Waste Temperature (°F)	137	163	166	189
Maximum Concrete Temperature (°F)	133	151	162	175

# Vent & Balance Data

## PSYCHROMETRIC SURVEY

DATE: 6-13-89

TO: ~~A. ALSTAD~~ Jan Sailer R1-51  
Jim P

FROM: J. Johnson  
~~W. Nichols~~  
2101M Bldg. Rm. 133  
200 East (S2-70)  
3-1857

Psychrometric Tank Farm Survey 241-AP , TANK EXH.

Taken by: RUGGLES, WARD, KENZEL

The following airflow and temperature readings were taken on subject tank.

Date: 6-13-89

Weather: Lower

Time: 9:00 AM Wet Bulb 63° °F Dry Bulb 77° °F

Ambient:

Time: 9:00 AM Wet Bulb 64° °F Dry Bulb 78° °F

Tank No.	Time	Temperature		Flow CFM	Neg. Off Chart %	Exh Duct Eff IN. W.G.	Exh Damp Pos. % OPEN	Neg. Off Tank IN. W.G.
		Wet °F	Dry °F					
101	9:00 AM	68°	68°	100	18%	2.37" W.G.	25	-2.70" W.G.
102	9:10 AM	68°	68°	130	26%	2.07" W.G.	25	-2.40" W.G.
103	9:15 AM	68°	68°	130	18%	2.00" W.G.	25	-2.80" W.G.
104	9:35 AM	70°	70°	212	17%	2.45" W.G.	20	-2.60" W.G.
105	9:40 AM	61°	70°	264	10%	2.91" W.G.	100	-3.00" W.G.
106	9:50 AM	68°	68°	188	15%	2.55" W.G.	188	-2.70" W.G.

COMMENTS:

296 A-40

681 CFM

PAE FILTER 10" W.G. DIP  
PRIMARY 80" W.G. DIP  
SECONDARY 165" W.G. DIP  
DEENTRAINER 168" W.G. DIP

INLET TEMP 68°  
OUTLET TEMP 76°

CC. H. N. ANDERSON-

Roby Hankins AT 52

HNF-2483, Rev. 0  
Page A-9

2 PM 3/11/85

W320-28-001 rev 4

# Vent & Balance Data

## PSYCHROMETRIC SURVEY

DATE: 7/17/89

TO: J. H. Cleaver Dan Baird R151

FROM: I. T. Johnson  
2101M bldg. Rm. KKK  
200 East (S2-70)  
C-1887

141-D

Psychrometric Tank Farm Survey 241 A.P., TANK EXH.

Taken by: KINZEL KNUTSON Aultjen

The following airflow and temperature readings were taken on subject tank.

Date: 7/17/89

Weather Tower

Time: 10:00 Wet Bulb 59 °F Dry Bulb 76 °F

Ambient:

Time: 10:00 Wet Bulb 60 °F Dry Bulb 75 °F

Tank No.	Time	Temperature		Flow CFM	Neg. Off Chart %	Exh Duct S/P IN. W. G.	Exh Damp Pos. % OPEN	Neg. Off Tank IN. W. G.
		Wet °F	Dry °F					
101	9:18	66	73	110	-2.7%	12.61" w.g.	18	-2.60" w.g.
102	9:22	66	72	99	-2.1%	12.02" w.g.	25	-2.10" w.g.
103	9:27	66	73	99	-2.7%	12.00" w.g.	22	-2.70" w.g.
104	9:32	66	72	116	-2.7%	12.44" w.g.	20	-2.60" w.g.
105	10:50	64	75	255	-2.2%	12.90" w.g.	95	-2.10" w.g.
106	10:00	71	73	153	-2.2%	12.40" w.g.	25	-2.60" w.g.
								Blanked off
								Blanked off

COMMENTS:

296 - A - 40 791 CFM

Pre Filter 10" w.g.  
Primary 25" w.g.  
Secondary 163" w.g.  
Downstream 45" w.g.

Inlet Temp. 65°F  
Outlet Temp. 77°F

Betty Hanlon R1-30  
5/18/89

7. Pin. 3/31/15

70-28-001 rev 1 PRR 4-3-89

MAINTENANCE ENGINEERING SERVICES  
 MAINTENANCE PROCEDURE  
 AIRFLOW AND PSYCHROMETRIC READING ON UNDERGROUND WASTE  
 STORAGE TANKS

7-GY-063  
 Rev. 2  
 Page 11 of 11

*Vent & Balance Data*

241-AM Tank Farm

DATE: 2-8-90

TO: \_\_\_\_\_

FROM: 2101-M RM.  
 200 E (S2-70)  
 3-1857

Instrument Type Micro

Instrument Last Calibration Date 11-8-89

Instrument Code No. WHSL 702-28-09-013

Psychrometric Survey Tank 241, TANK EXH.

Taken By: Carriek, Tiffany & Melissa

The following airflow and temperature readings were taken on subject tank.

DATE: 2-8-90

Weather Tower:   
 Time: 9:00 AM Wet Bulb 31 °F Dry Bulb 33 °F

Ambient:   
 Time: N/A Wet Bulb N/A °F Dry Bulb N/A °F

TANK NO.	TIME	TEMPERATURE		FLOW CFM	NEG. OFF CHART %	EXHAUST DUCT S/P IN. W.G.	EXHAUST DAMP POSITION % OPEN	NEG. OFF TANK IN. W.G.
		WET OF	DRY OF					
<u>AM</u>	<u>AM</u>							
101	10:10	61°F	66°F	.48	41%	-1.65" w.g.	100%	10/39 -2.0" w.g.
102	10:30	75°F	77°F	34	40%	-1.66" w.g.	100%	10/39 -1.50" w.g.
103	10:20	63°F	78°F	235	43%	-1.65" w.g.	100%	10/39 -1.30" w.g.
104	10:00	66°F	75°F	55	43%	-1.67" w.g.	100%	10/39 -2.0" w.g.
105	9:40	66°F	70°F	34	43%	-1.61" w.g.	60%	10/37 -2.0" w.g.
106	9:30	59°F	63°F	347	45%	-1.55" w.g.	75%	10/39 -1.50" w.g.
107	9:10	61°F	75°F	203	42%	-1.65" w.g.	80%	10/37 -1.90" w.g.

COMMENTS: No Ambient readings due to broken equipment.

Ira Johnson, Manager Ventilation Balance

TEST RECORD SHEET 3.

*2 PM 3/6/95*  
 20-28-001 real #439

*Vent & Balance Data*

241-AW Tank Farm

DATE: 2-9-90

TO: \_\_\_\_\_

FROM: 2101-M RM.  
 200 E (S2-70)  
 3-1857

Instrument Type micro

Instrument Last Calibration Date 11-8-89

Instrument Code No. WHSL 712-28-09-013

Psychrometric Survey Tank 241, TANK EXH.

Taken By: Carrick, McCause + Tiffany

The following airflow and temperature readings were taken on subject tank.

DATE: 2-9-90

Weather Tower:  
 Time: 1:45 Wet Bulb 35 °F Dry Bulb 41 °F

Ambient:  
 Time: N/A Wet Bulb N/A °F Dry Bulb N/A °F

TANK NO.	TIME	TEMPERATURE		FLOW CFM	NEG. OFF CHART %	EXHAUST DUCT S/P IN. W.G.	EXHAUST DAMP POSITION % OPEN	NEG. OFF TANK IN. W.G.
		WET OF	DRY OF					
<u>AW</u>	<u>P.M.</u>							
<u>101</u>	<u>1:50</u>	<u>65°F</u>	<u>65°F</u>	<u>.59</u> X	<u>55%</u>	<u>-1.30" w.g.</u>	<u>15%</u>	<u>7/97</u> <u>-1.70" w.g.</u>
<u>102</u>	<u>2:30</u>	<u>66°F</u>	<u>66°F</u>	<u>339</u> X	<u>60%</u>	<u>-1.19" w.g.</u>	<u>50%</u>	<u>7/99</u> <u>-1.70" w.g.</u>
<u>103</u>	<u>3:00</u>	<u>65°F</u>	<u>65°F</u>	<u>106</u> X	<u>59%</u>	<u>-1.99" w.g.</u>	<u>25%</u>	<u>7/97</u> <u>-1.20" w.g.</u>
<u>104</u>	<u>2:40</u>	<u>67°F</u>	<u>67°F</u>	<u>243</u> X	<u>59%</u>	<u>-1.19" w.g.</u>	<u>25%</u>	<u>7/97</u> <u>-1.70" w.g.</u>
<u>105</u>	<u>2:20</u>	<u>52°F</u>	<u>59°F</u>	<u>270</u> X	<u>55%</u>	<u>-1.27" w.g.</u>	<u>100%</u>	<u>4/97</u> <u>-1.40" w.g.</u>
<u>106</u>	<u>2:10</u>	<u>69°F</u>	<u>72°F</u>	<u>116</u> X	<u>65%</u>	<u>-1.89" w.g.</u>	<u>25%</u>	<u>7/97</u> <u>-1.0" w.g.</u>

COMMENTS: Ambient inst. broken RT-5-2 Fan inservice.

Ira Johnson, Manager Ventilation Balance  
TEST RECORD SHEET 3.

*T. Pitt 2/21/95*  
 28-001 real PHT 43-95

Riser	Existing Use	Proposed Modification
<b>TANK 241-C-106</b>		
R1 - 4 in.	FIC	
R2 - 12 in.	HVAC Outlet	HVAC Outlet
- 42 in. (36 in.)	Dirt Covered Construction Manhole	
<b>TANK 241-C-106 SLUICE PIT</b>		
R3 - 12 in.	Liquid Level Tape Riser blanked, H-2-73346	Install New Sluicer Risiers-empty and open
R4 - 4 in.	Recirc Dipleg Still there, H-2-73346 Sluice Pit Drain	Dipleg is laying in pit Riser is empty and open
<b>TANK 241-C-106 HEEL PIT</b>		
R13 - 26 in.	Heel Jet Pump Still there, H-2-73346 Heel Pit Drain	Install New Heel Pump Possibly Modify Riser dia. Remove Old Pump
<b>TANK 241-C-106 PUMP PIT</b>		
R5 - 4 in.	Recirc Dipleg Still there, H-2-73346 Pump Pit Drain	Riser is empty and open
R6 - 12 in.	Sluicing Access	New Sluicer
R7 - 12 in.	Observation Port In wall of Pit See H-2-93726 Blind Flange on Riser	Visual System Installation
R-9 - 42 in. (36 in.)	Sludge Pump Still there, H-2-73346	New Submersible Pump
<b>TANK 241-C-106</b>		
R8 - 4 in.	Temp Cont. Still there, H-2-73346 West of Pump Pit	
R11 - 4 in.	Southeast of Heel Pit (below grade)	
R14 - 4 in.	Thermocouple Tree	
<b>TANK 241-C-106 HVAC INTAKE</b>		
R15 - 12 in.	HVAC, HEPA Filtered Intake Intake, Riser plate could be made larger	HVAC Intake

## 1.0 INTRODUCTION

The purpose of this document is to show the analytical results which were reached in determining the minimal flow rate for one air change per day from a single shell tank.<sup>1</sup> Also, what flow rate will be required to maintain a static pressure of  $-0.3''$  wg to  $-5.9''$  wg in the tank (DOE Order 6430.1A page 11-4 paragraph 1161-4, and OSD #113). This flow may be used to size an exhauster for both, before and after stabilization. Please review all the assumptions made during this analysis very carefully. These assumptions are uncontrolled variables (ie.. drains being plugged by dirt and debris), therefore, close attention should be paid to these assumptions.

## 2.0 SCOPE

The flow rates and static pressures were determined by the following four scenarios:

- o 2 - 4" risers and 2 - 6" risers with a crack width of 1/64" each, 3 - 3" drains in the sluice pits (completely open free from debris), and 1 - 4" drain in the pump pit (completely open free from debris). In addition, 50 cfh or .833 cfm<sup>2</sup> is also added due to purge air used by the FIC.
- o 2 - 4" risers and 2 - 6" risers with a crack width of 1/64" each, 3 - 3" drains in the sluice pits (50% of the drain blocked due to dirt and debris), and 1 - 4" drain in the pump pit (50% of the drain blocked due to dirt and debris). In addition, 50 cfh or .833 cfm<sup>2</sup> is also added due to purge air used by the FIC.
- o 1 - inlet filter placed on a 12" riser with flow through both, the inlet filter, and flow going through the above mentioned cracks. In addition, 50 cfh or .833 cfm<sup>2</sup> is also added due to purge air used by the FIC.
- o 2 - 4" risers and 2 - 6" risers with a crack width of 1/64" each, and the sluice pits and pump pit are sealed up completely (no in-leakage through pits). In addition, 50 cfh or .833 cfm<sup>2</sup> is also added due to purge air used by the FIC.

The tank which was used for this analysis was 104-AX. This tank had the largest vapor space (gal.) due to the lowest liquid level (gal.) of all single shell tanks. This was determined by using the March 30, 1991 Tank Farm Facilities Chart (see appendix B).

1 = Internal Memo from J.D. Thomson and J.L. Deichman to M.A. Payne, 2-18-92, Single Shell Tank Ventillation Systems  
2 = Information supplied by A.T. Alstad and V.D. Maupin

3.0 RESULTS

All scenarios, which were mentioned above, were evaluated, labeled, and explained in Appendix A. The results were as follows:

<u>PRESSURE DROP</u> in. wg	<u>SCENARIO #1<sup>3</sup></u> cfm	<u>SCENARIO #2<sup>3</sup></u> cfm	<u>SCENARIO #3<sup>1,2,3</sup></u> cfm	<u>SCENARIO #4<sup>3</sup></u> cfm
.3" wg	317	165	300 + #1 or #2	9
1" wg	579	301	1000 + #1 or #2	16
2" wg	819	425	2000 + #1 or #2	23
3" wg	1003	521	3000 + #1 or #2	28
4" wg	1158	601	4000 + #1 or #2	33
5" wg	1333	672	5000 + #1 or #2	37
5.9" wg	1406	730	5900 + #1 or #2	40

1 = Based on damper being completely open  
 2 = See page 16 in Appendix A for reasoning of additive flows  
 3 = .83 cfm needs to be added to these values for the purge air off the FIC

*Rev 3/31/95*  
 10-28-001 *ARR* 4-3-95

Table 4. Population of Pressure Changes Every Hour.

Press swing (inches of mercury)	Year			
	1988	1989	1990	1991
-0.13 or lower	0	0	0	0
-0.12	0	0	1	0
-0.11	3	1	1	3
-0.10	0	2	1	0
-0.09	2	0	1	0
-0.08	3	3	3	3
-0.07	1	2	4	4
-0.06	10	5	15	7
-0.05	26	10	27	16
-0.04	130	86	128	110
-0.03	344	238	294	302
-0.02	890	915	990	976
-0.01	1,446	1,583	1,435	1,473
0	2,838	2,934	2,785	2,825
0.01	1,772	1,806	1,674	1,703
0.02	930	888	995	958
0.03	266	181	252	231
0.04	76	71	99	89
0.05	17	14	31	33
0.06	13	8	14	13
0.07	3	2	0	7
0.08	1	0	4	2
0.09	3	2	1	0
0.10	1	0	2	1
0.11	1	3	0	1
0.12	2	1	1	0
0.13 or higher	0	0	1	0

\*One reading was 0.18 but is ascribed to an error, see discussion in Section 1.2, "Raw Data."

*Rev 3/31/95*  
20-28-001 rev1 *PHH*  
4-3-95

Table 1. Annual Data.

Value	Year				
	1988	1989	1990	1991	1950 -1980*
Average (inches of mercury)	29.25	29.26	29.22	29.23	29.21
Standard deviation (inches of mercury)	0.211	0.197	0.193	0.210	-
Number	8779	8756	8760	8758	-
Maximum (inches of mercury)	29.94	29.96	30.02	29.83	30.23
Minimum (inches of mercury)	28.52	28.79	28.50	28.33	28.10
Total increases (inches of mercury)	49.98	46.04	51.46	49.97	-
Total decrease (inches of mercury)	50.50	46.20	51.28	49.78	-

\* Source: Stone et al. (1983)

gross outliers. Some years have more storms than others. Further computations would show that the coupling of extremes with the average and standard deviations indicate a well-behaved and normal distribution of values. Finally, 1988 was a leap year.

The total yearly breathing is 49.40 inches of mercury (0.005639 inches of mercury per hour) or about 1.69 atmospheres, which is somewhat lower than previous rates of about 2.2 atmospheres used in other studies (Klem 1991; Garfield 1975). Note that the present data gave breathing rates approaching 3 atmospheres before the few erroneous entries were corrected. Therefore, we believe the 1.69 atmospheres (0.005639 inches of mercury per hour) annual breathing rate to be valid and the best available.

Note that the total hourly barometric movement (upward or downward changes being accumulated as separate accounts) are higher than would be determined from Stone et al. (1983). For example, Table 36 in Stone et al. (1983) gives the annual average station pressure for hours 1 through 24. From this, the average diurnal change from low to high is 0.04 inches of mercury, or about 30% of the movement determined by the present analysis from hourly changes. Although this is a natural rate, one needs to be aware that some tanks are actively being purged (through the Food Instrument Corporation level gauge or other instruments). These purges may be in excess of 0.71 m<sup>3</sup>/h (25 ft<sup>3</sup>/h), which is similar to the natural breathing rate.

The data were examined on a daily basis to see if variations could be seen that were similar to the sinusoidal temperatures seen during the day. Those results for 1990 are presented (other years are very similar) as Table 2. Figure 1 is a graphical representation of the same data. There really is no trend over the day; in this case, Figure 1 is more enlightening than Table 2. Therefore, it would be impossible to predict that tank pressure would be high or low for any given hour of the day at some time in the future.

**APPENDIX B**

HNF-2483, Rev. 0  
Page A-18

*2/24 3/31/95*  
*28-001 rev 1 PHR 4-3-95*



**KAISER ENGINEERS HANFORD CO.**  
**DUCT PRESSURE LOSS**  
**CALCULATION SHEET**

NOTES: Calculation W320-28-001.

3" schedule 80, ID=2.90"  
 Assume loss per 100' per ASHRAE Fundamentals p.32.4 Darcy Equation (19).  
 Higher loss per 100' per 1993 ASHRAE Fundamentals p.32.6 Friction (20).  
 Assume loss per 100' per 1993 ASHRAE Fundamentals p.32.5 Equation (21).  
 Reynolds Number per 1993 ASHRAE Fundamentals p.32.5 Equation (22).  
 ASHRAE fitting ED1-1 1993 ASHRAE Fundamentals p.32.28.

JOB NO./W.O. NO. : W-320ER4319  
 BLDG NO./AREA : 241-C-106/200E  
 DUCT SYSTEM : Cascade Line from C-105  
 to C-106

PREPARED BY: P.H. LANGOWSKI  
 DATE: 3/28/95  
 CHECKED BY:

NOTE: COLUMNS UNDER SHADED AREAS REQUIRE USER INPUT

AIR STREAM	AIR FLOW	TEMP	AIR FLOW	DEGREE F	AIR FLOW	ACPM	SCPM	AIR TAKEOFF	DUCT SIZE			EQUIV DUCT LENGTH	DUCT AREA	PERI METER	HYDRAL DIA	REY	FRIME	F	VEL.	VEL. PRESS. Vp	VEL. PRESS. LOSS.																			
									WIDTH	HEIGHT	DIA.																													
									IN.	IN.	IN.	FT.	sq. IN.	IN.	IN.			FT/M	IN. WG	IN. WG																				
C-105 (SHADE) pressure increases at C-105	103	120	113	120	113						2.90	duct only	6.61	9.11	2.90	58.591	0.022	0.022	2.458	0.377	0.188																			
30" of 3" schedule 80	103	120	113	120	113						2.90	30	6.61	9.11	2.90	58.591	0.022	0.022	2.458	0.377	0.935																			
exit in C-106	103	120	113	120	113						2.90		6.61	9.11	2.90	58.591	0.022	0.022	2.458	0.377	0.377																			
total																																								0.000

DATA USED ABOVE  
 roughness = 0.0005  
 density = 0.075 lbm/ft<sup>3</sup>  
 kinematic viscosity = 0.000188 ft<sup>2</sup>/s  
 120F, dry air 14.613 ft<sup>3</sup>/lbm

friction factors  
 galvanized carbon steel 0.0003  
 carbon steel 0.0001

	temp(F)	ft <sup>2</sup> /s
From Mechanical Engineering Reference Manual Eighth Edition, p.3-36.	0.00	0.000126
	20.00	0.000135
	40.00	0.000148
	60.00	0.000168
	80.00	0.000180
	100.00	0.000189
	120.00	0.000189
	250.00	0.000273

**KAISER ENGINEERS HANFORD CO.  
DUCT PRESSURE LOSS  
CALCULATION SHEET**

NOTES:  
Calculation W320-28-001.  
3" schedule 80, ID = 2.90".  
Pressure loss per 100' Fundamentals p.32.4 Darcy Equation (19).  
Hydraulic diameter per 1993 Fundamentals p.32.6 Equation (29).  
Reynolds number per 1993 Fundamentals p.32.7 Equation (24).  
Friction factor per 1993 Fundamentals p.32.8 Equation (22).  
ASHRAE fitting ED-1-1 1993 Fundamentals p.32.23.

PREPARED BY: P.H. LANGOWSKI  
DATE: 3/27/95  
CHECKED BY:

JOB NO./W.O. NO.: W-320/ER4319  
BLDG NO./AREA: 241-C-106/200E  
DUCT SYSTEM: Cascade Line from C-105 to C-106

NOTE: COLUMNS UNDER SHADED AREAS REQUIRE USER INPUT

AIR STREAM	AIR FLOW		TEMP	DUCT SIZE			EQUIV DUCT LENGTH		DUCT AREA	PERI METER	HYDRAL DIA		FRIME	F	VEL.		PRESS.		LOSS
	SCFM	ACFM		WIDTH	HEIGHT	DIA.	FT.	IN.			IN.	IN.			IN.	IN.	IN.	IN.	
C-106 gauge pressure	108	110	80			2.90			6.61	9.11	2.90		57.188	0.022	2.400	0.359		-1.500	
Entrance to C-105	108	110	80			2.90		30	6.61	9.11	2.90		57.188	0.022	2.400	0.359		0.160	
30' of 3 schedule 80	108	110	80			2.90			6.61	9.11	2.90		57.188	0.022	2.400	0.359		0.961	
Exit to C-105	108	110	80			2.90			6.61	9.11	2.90		57.188	0.022	2.400	0.359		0.359	
																		total	0.000

DATA USED ABOVE  
roughness = 0.0001  
density = 0.074 lbm/ft<sup>3</sup> 80F, dry air  
kinematic viscosity = 0.000169 ft<sup>2</sup>/s

friction factors galvanized carbon steel 0.0003 0.0001

kinematic viscosity	temp(F)	ft <sup>2</sup> /s
From Mechanical Engineering Reference Manual Eighth Edition, p.3-36.	0.00	0.000126
	20.00	0.000138
	40.00	0.000146
	60.00	0.000152
	80.00	0.000160
	100.00	0.000169
	120.00	0.000180
	150.00	0.000189
	250.00	0.000273

equals the difference between the upstream pressure, which is zero (atmospheric pressure), and the loss through the fitting. The static pressure of the ambient air is zero; several diameters downstream, static pressure is negative, algebraically equal to the total pressure (negative) and the velocity pressure (always positive).

System resistance to airflow is noted by the total pressure grade line in Figure 3. Sections 3 and 4 include fan system effect pressure losses. To obtain the fan static pressure requirement for fan selection where the fan total pressure is known, use:

$$P_s = P_t - P_{vo} \quad (18)$$

where

- $P_s$  = fan static pressure, in. of water
- $P_t$  = fan total pressure, in. of water
- $P_{vo}$  = fan outlet velocity pressure, in. of water




Fig. 2 Illustrative 6-Path, 9-Section System

## FLUID RESISTANCE

Duct system losses are the irreversible transformation of mechanical energy into heat. The two types of losses are (1) frictional losses and (2) dynamic losses.

## FRICTIONAL LOSSES

Frictional losses are due to fluid viscosity and are a result of momentum exchange between molecules in laminar flow and between particles moving at different velocities in turbulent flow. Frictional losses occur along the entire duct length.

### Darcy, Colebrook, and Altshul Equations

For fluid flow in conduits, friction loss can be calculated by the Darcy equation:

$$\Delta p_f = f(12L/D_h) \rho (V/1097)^2 \quad (19)$$

where

- $\Delta p_f$  = friction losses in terms of total pressure, in. of water
- $f$  = friction factor, dimensionless
- $L$  = duct length, ft
- $D_h$  = hydraulic diameter [Equation (24)], in.
- $V$  = velocity, fpm
- $\rho$  = density, lb<sub>m</sub>/ft<sup>3</sup>

Within the region of laminar flow (Reynolds numbers less than 2000), the friction factor is a function of Reynolds number only.




Fig. 3 Pressure Changes During Flow in Ducts

*C. P. Pitt 3/31/95*  
*B3*  
*W320-28-001 rev1 P48 4-3*

## Duct Design

For turbulent flow, the friction factor depends on Reynolds number, duct surface roughness, and internal protuberances such as joints. The traditional Moody chart depicts the behavior for round passages. For hydraulically smooth ducts, the friction factor again depends only on Reynolds number, but the dependence is markedly different from that for laminar flow. In general, for non-smooth surfaces, the friction factor depends on roughness and Reynolds number; however, for a particular level of roughness beyond a sufficiently large Reynolds number, the friction factor becomes independent of Reynolds number, a flow condition considered as fully rough. Between the bounding limits of hydraulically smooth behavior and fully rough behavior, is a transitional roughness zone where the friction factor depends on both roughness and Reynolds number. In this transitionally rough, turbulent zone, where most cases of airflow occur in air-conditioning applications, the friction factor  $f$  is calculated by Colebrook's equation (1938-39). Since this equation cannot be solved explicitly for  $f$ , use iterative techniques (Behls 1971).

$$\frac{1}{f^{0.5}} = -2 \log \left[ \frac{12\epsilon}{3.7D_h} + \frac{2.51}{Re f^{0.5}} \right] \quad (20)$$

where

$\epsilon$  = material absolute roughness factor, ft  
 $Re$  = Reynolds number

A simplified formula for calculating friction factor, developed by Altshul (1975) and modified by Tsal, is

$$f' = 0.11 \left( \frac{12\epsilon}{D_h} + \frac{68}{Re} \right)^{0.25}$$

$$\text{If } f' \geq 0.018: f = f'$$

$$\text{If } f' < 0.018: f = 0.85f' + 0.0028 \quad (21)$$

Friction factors obtained from Altshul's modified equation are within 1.6% of those obtained by Colebrook's equation.

Reynolds number ( $Re$ ) may be calculated by using Equation (22).

$$Re = \frac{D_h V}{720 \nu} \quad (22)$$

where  $\nu$  = kinematic viscosity,  $\text{ft}^2/\text{s}$ .

For standard air,  $Re$  can be calculated by

$$Re = 8.56 D_h V \quad (23)$$

### Roughness Factors ( $\epsilon$ )

The  $\epsilon$ -values listed in Table 1 are recommended for use with the Colebrook or Altshul-Tsal equation. These values should be interpreted as representing a combination of material, duct construction, joint type, and joint spacing (Griggs and Khodabakhsh-Sharifabad 1992). Roughness factors for other materials are presented in Idelchik *et al.* (1986). Idelchik summarizes roughness factors for 80 materials including metal tubes; conduits made from concrete and cement; and wood, plywood, and glass tubes.

Swim (1978) conducted tests on duct liners of varying densities, surface treatments, transverse joints (workmanship), and methods of attachment to sheet metal ducts. As a result of these tests, Swim recommends for design 0.015 ft for spray-coated liners and 0.005 ft for liners with a facing material cemented onto the air side. In both cases, the roughness factor includes the resistance offered by mechanical fasteners and assumes good joints. Liners cut too long

and fastened to the duct cause much more loss than a liner cut too short; therefore, any fabrication error in liner length should be on the short side. Liner density does not significantly influence flow resistance.

Manufacturers' data indicate that the absolute roughness for fully extended nonmetallic flexible ducts ranges from 0.0035 to 0.015 ft. For fully extended flexible metallic ducts, absolute roughness ranges from 0.0004 to 0.007 ft. This range covers flexible duct with the supporting wire exposed to flow or covered by the material. Figure 4 provides a pressure drop correction factor for straight flexible duct when less than fully extended.

Table 1 Duct Roughness Factors

Duct Material	Roughness Category	Absolute Roughness $\epsilon$ , ft
Uncoated carbon steel, clean (Moody 1944) (0.00015 ft)	Smooth	0.0001
PVC plastic pipe (Swim 1982) (0.00003 - 0.00015 ft)		
Aluminum (Hutchinson 1953) (0.000015 - 0.0002 ft)		
Galvanized steel, longitudinal seams, 4-ft joints (Griggs <i>et al.</i> 1987) (0.00016 - 0.00032 ft)	Medium smooth	0.0003
Galvanized steel, continuously rolled, spiral seams, 10-ft joints (Jones 1979) (0.0002 - 0.0004 ft)		
Galvanized steel, spiral seam with 1, 2, and 3 ribs, 12-ft joints (Griggs <i>et al.</i> 1987) (0.00029 - 0.00038 ft)		
Galvanized steel, longitudinal seams, 2.5-ft joints (Wright 1955) (0.0005 ft)	Average	0.0005
Fibrous glass duct, rigid	Medium	0.003
Fibrous glass duct liner, air side with facing material (Swim 1978) (0.005 ft)	Rough	
Fibrous glass duct liner, air side spray coated (Swim 1978) (0.015 ft)	Rough	0.01
Flexible duct, metallic (0.004 - 0.007 ft when fully extended)		
Flexible duct, all types of fabric and wire (0.0035 - 0.015 ft when fully extended)		
Concrete (Moody 1944) (0.001 - 0.01 ft)		




Fig. 4 Correction Factor for Unextended Flexible Duct

### Friction Chart

Fluid resistance caused by friction in round ducts can be determined by the Friction Chart (Figure 5). This chart is based on standard air flowing through round galvanized ducts with beaded slip couplings on 48-in. centers, equivalent to an absolute roughness of 0.0003 ft.

Changes in barometric pressure, temperature, and humidity affect air density, air viscosity, and Reynolds number. No corrections to the Friction Chart are needed for (1) duct materials with a medium smooth roughness factor, (2) temperature variations in the order of  $\pm 30^\circ\text{F}$  from  $70^\circ\text{F}$ , (3) elevations to 1500 ft, and (4) duct pressures from  $-20$  in. of water to  $+20$  in. of water relative to the ambient pressure. These individual variations in temperature, elevation, and duct pressure result in duct losses within  $\pm 5\%$  of the standard air friction chart.

For duct materials other than those categorized as medium smooth in Table 1, and for variations in temperature, barometric pressure (elevation), and duct pressures (outside the range listed), calculate the pressure loss in a duct due to friction by the Alshul-Tsal and Darcy equations [(21) and (19), respectively].

### Noncircular Ducts

A momentum analysis can relate average wall shear stress to pressure drop per unit length for fully developed turbulent flow in a passage of arbitrary shape but of uniform longitudinal cross-sectional area. Combining the result with the definition of the Darcy friction factor leads to Equation (24), with the ratio  $4A/P$  defined as hydraulic diameter:

$$D_h = 4A/P \quad (24)$$

where

$$\begin{aligned} D_h &= \text{hydraulic diameter, in.} \\ A &= \text{duct area, in}^2 \\ P &= \text{perimeter of cross section, in.} \end{aligned}$$

While the hydraulic diameter is often used to correlate noncircular data, exact solutions for laminar flow in noncircular passages show that such practice causes some inconsistencies. No exact solutions exist for turbulent flow. Tests over a limited range of turbulent flow indicated that fluid resistance is the same for equal lengths of duct for equal mean velocities of flow if the ducts have the same ratio of cross-sectional area to perimeter. From a series of experiments using round, square, and rectangular ducts having essentially the same hydraulic diameter, Huebscher (1948) found that each, for most purposes, had the same flow resistance at equal mean velocities. Tests by Griggs and Khodabakhsh-Sharifabad (1992) also indicated that experimental rectangular duct data for airflow over the range typical of HVAC systems can be correlated satisfactorily using Equation (20) together with hydraulic diameter, particularly when a realistic experimental uncertainty is accepted. These tests support using hydraulic diameter to correlate noncircular duct data.

Rectangular ducts. Huebscher developed the relationship between rectangular and round ducts that is used to determine size equivalency based on equal flow, resistance, and length. This relationship, Equation (25), is the basis for Table 2.

$$D_e = 1.30 \frac{(ab)^{0.625}}{(a+b)^{0.250}} \quad (25)$$

where

$$\begin{aligned} D_e &= \text{circular equivalent of rectangular duct for equal length,} \\ &\quad \text{fluid resistance, and airflow, in.} \\ a &= \text{length of one side of duct, in.} \\ b &= \text{length of adjacent side of duct, in.} \end{aligned}$$

To size rectangular ducts, determine the circular duct diameter by any design method, and use Table 2 to select the equivalent duct size as a function of aspect ratio. Equations (21) or (20) and (19) must be used to determine pressure loss.

**Flat oval ducts.** To convert round ducts to spiral flat oval sizes, use Table 3. Table 3 is based on Equation (26) (Heyt and Diaz 1975), the circular equivalent of a flat oval duct for equal airflow, resistance, and length. Equations (21) or (20) and (19) must be used to determine frictional pressure loss.

$$D_e = \frac{1.55 A^{0.625}}{p^{0.250}} \quad (26)$$

where  $A$  is the cross-sectional area of flat oval duct defined as:

$$A = (\pi b^2/4) + b(a-b) \quad (27)$$

and the perimeter  $P$  is calculated by:

$$P = \pi b + 2(a-b) \quad (28)$$

where

$$\begin{aligned} P &= \text{perimeter of flat oval duct, in.} \\ a &= \text{major dimension of flat oval duct, in.} \\ b &= \text{minor dimension of flat oval duct, in.} \end{aligned}$$

### DYNAMIC LOSSES

Dynamic losses result from flow disturbances caused by fittings that change the airflow path's direction and/or area. These fittings include entries, exits, transitions, and junctions. Idelchik (1986) discusses parameters affecting fluid resistance of fittings and presents loss coefficients in three forms: tables, curves, and equations.

#### Local Loss Coefficients

The following dimensionless coefficient is used for fluid resistance, since this coefficient has the same value in dynamically similar streams, *i.e.*, streams with geometrically similar stretches, equal values of Reynolds number, and equal values of other criteria necessary for dynamic similarity. The fluid resistance coefficient represents the ratio of total pressure loss to velocity pressure at the referenced cross section.

$$C = \frac{\Delta p_f}{\rho(V/1097)^2} = \frac{\Delta p_f}{p_v} \quad (29)$$

where

$$\begin{aligned} C &= \text{local loss coefficient, dimensionless} \\ \Delta p_f &= \text{fitting total pressure loss, in. of water} \\ \rho &= \text{density, lb}_m/\text{ft}^3 \\ V &= \text{velocity, fpm} \\ p_v &= \text{velocity pressure, in. of water} \end{aligned}$$


Dynamic losses occur along a duct length and cannot be separated from frictional losses. For ease of calculation, dynamic losses are assumed to be concentrated at a section (local) and to exclude friction. Frictional losses must be considered only for relatively long fittings. Generally, fitting friction losses are accounted for by measuring duct lengths from the centerline of one fitting to that of the next fitting. For fittings closely coupled (less than six hydraulic diameters apart), the flow pattern entering subsequent fittings differs from the flow pattern used to determine loss coefficients. Adequate data for these situations are unavailable.

For all fittings, except junctions, calculate the total pressure loss  $\Delta p_f$  at a section by:

(30)


CD9-3 Fire Damper, Curtain Type, Type C

$C_o = 0.12$




ED1-1 Duct Mounted in Wall (Idelchik *et al.* 1986, Diagram 3-1)

$t/D$	$C_o$ Values									
	$L/D$									
	0.000	0.002	0.010	0.050	0.100	0.200	0.300	0.500	10.000	
0.00	0.50	0.57	0.68	0.80	0.86	0.92	0.97	1.00	1.00	
0.02	0.50	0.51	0.52	0.55	0.60	0.66	0.69	0.72	0.72	
0.05	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	
10.00	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	



ED2-1 Conical Diffuser, Round to Plenum, Exhaust/Return Systems (Idelchik *et al.* 1986, Diagram 5-8)

$A_1/A_o$	$C_o$ Values													
	$L/D_o$													
	0.5	1.0	2.0	3.0	4.0	5.0	6.0	8.0	10.0	12.0	14.0			
1.5	0.03	0.02	0.03	0.03	0.04	0.05	0.06	0.08	0.10	0.11	0.13			
2.0	0.08	0.06	0.04	0.04	0.04	0.05	0.05	0.06	0.08	0.09	0.10			
2.5	0.13	0.09	0.06	0.06	0.06	0.06	0.06	0.06	0.07	0.08	0.09			
3.0	0.17	0.12	0.09	0.07	0.07	0.06	0.06	0.07	0.07	0.08	0.08			
4.0	0.23	0.17	0.12	0.10	0.09	0.08	0.08	0.08	0.08	0.08	0.08			
6.0	0.30	0.22	0.16	0.13	0.12	0.10	0.10	0.09	0.09	0.09	0.08			
8.0	0.34	0.26	0.18	0.15	0.13	0.12	0.11	0.10	0.09	0.09	0.09			
10.0	0.36	0.28	0.20	0.16	0.14	0.13	0.12	0.11	0.10	0.09	0.09			
14.0	0.39	0.30	0.22	0.18	0.16	0.14	0.13	0.12	0.10	0.10	0.10			
20.0	0.41	0.32	0.24	0.20	0.17	0.15	0.14	0.12	0.11	0.11	0.10			



$A_1/A_o$	Optimum Angle, $\theta$											
	0.5	1.0	2.0	3.0	4.0	5.0	6.0	8.0	10.0	12.0	14.0	
1.5	34	20	13	9	7	6	4	3	2	2	2	
2.0	42	28	17	12	10	9	8	6	5	4	3	
2.5	50	32	20	15	12	11	10	8	7	6	5	
3.0	54	34	22	17	14	12	11	10	8	8	6	
4.0	58	40	26	20	16	14	13	12	10	10	9	
6.0	62	42	28	22	19	16	15	12	11	10	9	
8.0	64	44	30	24	20	18	16	13	12	11	10	
10.0	66	46	30	24	22	19	17	14	12	11	10	
14.0	66	48	32	26	22	19	17	14	13	11	11	
20.0	68	48	32	26	22	20	18	15	13	12	11	

B6

**Appendix F**  
**Dimensions of Welded and Seamless Steel Pipe**

Nominal Diameter	Schedule	Outside Diameter	Wall Thickness	Internal Diameter	Internal Area	Internal Diameter	Internal Area
Inches		Inches	Inches	Inches	Sq Inches	Feet	Sq Feet
1/8	40 (S)	0.405	0.068	0.269	0.0568	0.0224	0.00039
	80 (X)		0.095	0.215	0.0363	0.0179	0.00025
1/4	40 (S)	0.540	0.088	0.364	0.1041	0.0303	0.00072
	80 (X)		0.119	0.302	0.0716	0.0252	0.00050
3/8	40 (S)	0.675	0.091	0.493	0.1909	0.0411	0.00133
	80 (X)		0.126	0.423	0.1405	0.0353	0.00098
1/2	40 (S)	0.840	0.109	0.622	0.3039	0.0518	0.00211
	80 (X)		0.147	0.546	0.2341	0.0455	0.00163
	160		0.187	0.466	0.1706	0.0388	0.00118
	(XX)		0.294	0.252	0.499	0.0210	0.00035
3/4	40 (S)	1.050	0.113	0.824	0.5333	0.0687	0.00370
	80 (X)		0.154	0.742	0.4324	0.0618	0.00300
	160		0.219	0.612	0.2942	0.0510	0.00204
	(XX)		0.308	0.434	0.1479	0.0362	0.00103
1	40 (S)	1.315	0.133	1.049	0.8643	0.0874	0.00600
	80 (X)		0.179	0.957	0.7193	0.0798	0.00500
	160		0.250	0.815	0.5217	0.0679	0.00362
	(XX)		0.358	0.599	0.2818	0.0499	0.00196
1 1/4	40 (S)	1.660	0.140	1.380	1.496	0.1150	0.01039
	80 (X)		0.191	1.278	1.283	0.1065	0.00890
	160		0.250	1.160	1.057	0.0967	0.00734
	(XX)		0.382	0.896	0.6305	0.0747	0.00438
1 1/2	40 (S)	1.900	0.145	1.610	2.036	0.1342	0.01414
	80 (X)		0.200	1.500	1.767	0.1250	0.01227
	160		0.281	1.338	1.406	0.1115	0.00976
	(XX)		0.400	1.100	0.9503	0.0917	0.00660
2	40 (S)	2.375	0.154	2.067	3.356	0.1723	0.02330
	80 (X)		0.218	1.939	2.953	0.1616	0.02051
	160		0.344	1.687	2.235	0.1406	0.01552
	(XX)		0.436	1.503	1.774	0.1253	0.01232
2 1/2	40 (S)	2.875	0.203	2.469	4.788	0.2058	0.03325
	80 (X)		0.276	2.323	4.238	0.1936	0.02943
	160		0.375	2.125	3.547	0.1771	0.02463
	(XX)		0.552	1.771	2.464	0.1476	0.01711
3	40 (S)	3.500	0.216	3.068	7.393	0.2557	0.05134
	80 (X)		0.300	2.900	6.605	0.2417	0.04587
	160		0.438	2.624	5.408	0.2187	0.03755
	(XX)		0.600	2.300	4.155	0.1917	0.02885
3 1/2	40 (S)	4.000	0.226	3.548	9.887	0.2957	0.06866
	80 (X)		0.318	3.364	8.888	0.2803	0.06172
4	40 (S)	4.500	0.237	4.026	12.73	0.3355	0.08841
	80 (X)		0.337	3.826	11.50	0.3188	0.07984
	120		0.438	3.624	10.32	0.3020	0.07163
	160		0.531	3.438	9.283	0.2865	0.06447
	(XX)		0.674	3.152	7.803	0.2627	0.05419

B7



W320-28-001

Equipment Sizing & Selection  
Recirculation Fan

# CALCULATION IDENTIFICATION AND INDEX

Date

3-6-95

This sheet shows the status and description of the attached Design Analysis sheets.

Discipline 28/HVAC

WO/Job No. ER4319

Calculation No. W320-~~1003~~ <sup>28-003</sup>

Project No. & Name W-320 Tank 241-C-106 Waste Retrieval

Calculation Item Equipment Sizing & Selection Recirculation Fan

These calculations apply to:

Dwg. No. N/A

Rev. No. N/A

Dwg. No. N/A

Rev. No. N/A

Other (Study, CDR) Procurement Specifications:  
W-320-P6 Recirculation fan

Rev. No. 0

The status of these calculations is:

Preliminary Calculations

Final Calculations

Check Calculations (On Calculation Dated )

Void Calculation (Reason Voided )

Incorporated in Final Drawings?

Yes

No

This calculation verified by independent "check" calculations?

Yes

No

No

Original and Revised Calculation Approvals:

	Rev. 0 Signature/Date	Rev. 1 Signature/Date	Rev. 2 Signature/Date
Originator	<i>PH Lough</i> 3-6-95		
Checked by	<i>Paul Price</i> 3-8-95		
Approved by	<i>PH Lough</i> 3-9-95		
Checked Against Approved Vendor Data	<i>Charles T. Li</i> 4/10/98		

### INDEX

Design Analysis Page No.	Description
i	Calculation Identification and Index
1	Objective, Design Inputs, & Calculations
2	Findings & Conclusions
A1-A10	Appendix A: Supporting Information

# DESIGN ANALYSIS

Client WHC  
Subject Equipment Sizing & Selection,  
Recirculation Fan  
Location 241-C/200 East

WO/Job No. ER4319  
Date 3-6-95  
Checked 3.8.95  
Revised

By PH Langowski *PHL*  
By *Saul*  
By

## 1.0 OBJECTIVE

The objective of this calculation is to determine the performance requirements of the recirculation fan.

## 2.0 DESIGN INPUTS

### 2.1 CRITERIA AND SOURCE

DOE General Order 6430.1A  
Functional Design Criteria WHC-SD-W320-FDC-001, rev. 2, 1/18/94

### 2.2 GIVEN DATA

1. Energy Balance drawing H-2-818479 which gives normal fan operation of 77F fan inlet air conditions.

### 2.3 ASSUMPTIONS

1. Pressure drop through the condenser is linear with reduced airflow.
2. Pressure drop through the moisture separator is governed by the square of the velocity ratio of the design airflow to the actual operating point airflow (based on Wright-Austin vendor data).

### 2.4 METHODS

Hand calculations, Excel spreadsheet, vendor information.

### 2.5 REFERENCES ~~28~~

W320-~~H~~-018, rev 1 Calculation, Pressure Drop Calculations for Exhaust Skid Sizing  
W320-~~H~~-015, rev 0 Calculation, Moisture Separator Sizing  
1993 ASHRAE Fundamentals

~~28~~

### 3.0 CALCULATIONS ~~26~~

From W320-~~H~~-015 para 7.4, 5463 lb<sub>da</sub>/h at a 40F saturated humidity ratio of 0.005216 lb<sub>w</sub>/lb<sub>da</sub> yields 28.49 lb<sub>w</sub>/h (vapor) leaving the condenser. From the same calculation para 7.5 it is shown that 0.7 lb<sub>w</sub>/min (mist) enters the moisture separator and 0.56 lb<sub>w</sub>/min (mist) is removed by the moisture separator. Therefore, (0.14 lb<sub>w</sub>/min)(60 min/h)=8.4 lb<sub>w</sub>/h of mist is leaving the moisture separator.

The humidity ratio of the airstream is therefore (28.49 + 8.4)lb<sub>w</sub>/h / 5463 lb<sub>da</sub>/h = 0.006753 lb<sub>w</sub>/lb<sub>da</sub>. At the 77F temperature exiting the heating coil with a saturated humidity ratio of 0.020170 lb<sub>w</sub>/lb<sub>da</sub> for 77F, the relative humidity is 0.006753/0.020170=33%.

From the psychrometric chart (App A), at 77F and 33% RH, the specific volume is 13.569 ft<sup>3</sup>/lb<sub>da</sub> (0.0737 lb<sub>da</sub>/ft<sup>3</sup>). At 500 feet elevation the standard atmosphere is 14.430 psia which is equivalent to (14.430)(27.708)=399.83" water absolute [(14.696)(27.708) = 407.20" water absolute at sea level]. Using ideal gas laws, a density factor of 399.83/407.20 = 0.982 accounts for a 500 foot elevation difference and yields (0.982)(0.0737) = 0.0724 lb<sub>da</sub>/ft<sup>3</sup>. The specification P6 was completed with

*See calc. on page 2 C.T.C. 4/7*

# DESIGN ANALYSIS

Client WHC  
 Subject Equipment Sizing & Selection,  
 Recirculation Fan  
 Location 241-C/200 East

WO/Job No. ER4319  
 Date 3-6-95 By PH Langowski *PLK*  
 Checked 3.8.95 By *Paul Rice*  
 Revised By

an inlet air density of 0.0704 lb<sub>da</sub>/ft<sup>3</sup>, which is within three percent of that calculated at 500 foot elevation. At a slightly higher elevation the air density would be even closer to that listed in the specification.

An upset condition where the condenser is off line and the tank is at a 120F operating limit condition is based on FDC equipment operating limits for tank installed equipment. The assumed 100% saturation at this upset condition yields a 0.0605 lb/ft<sup>3</sup> density. The fan should be sized to be away from the top of it's curve between the normal and upset operating points so as to not induce pulsations. Using the W320-H-018 spreadsheet with 120F saturated air and the airflows set at 600, 750, and 860 scfm for the recirculation fan yields a system curve for this temperature (App A spreadsheet printout results are plotted on top of vendor fan curve on page A4). Intersection of an upset system curve with the vendor fan curve at this upset condition shows that at 120F the fan will move approximately 850 acfm at a 16.8" w.g. pressure differential.

### 4.0 FINDINGS & CONCLUSIONS

The recirculation fan sizing design operating point will be: 860 scfm (916 acfm) @ 19.0" water gauge static pressure differential and a 77F inlet air density of 0.0704 lb/ft<sup>3</sup>. The maximum assumed upset operating temperature is 120F (saturated) with an inlet air density of 0.0605 lb/ft<sup>3</sup>. At the 120F upset condition, the fan will move approximately 850 acfm at a 16.8" w.g. pressure differential and operation should be stable.

3.0 Calculations

- vapor leaving condenser = 28.49 lb/hr
- wt. of air through condenser = 5463 lb<sub>da</sub>/hr
- wt of air recirculated = 5463 x  $\frac{860}{7500}$  = 3851 lb<sub>da</sub>/hr } Para. 7.4 of Calc. W320-28-15
- wt. of water reentrained to moisture separator = 0.7 lb/min
- wt. of water removed by moisture separator = 0.59 lb/min } Para. 7.5 of W320-28-15
- wt of water leaving moisture separator (0.7 - 0.59) x 60 = 6.6 lb/hr
- Humidity ratio for air leaving heating coil  
 $(28.49 + 6.6) / 3851 = 0.0091$  lb<sub>w</sub>/lb<sub>da</sub>
- R.H. of air leaving heating coil =  $0.0091 / 0.020170 = 45.18\%$
- Specific volume = 13.72 ft<sup>3</sup>/lb<sub>da</sub> ; 0.0729 lb<sub>da</sub>/ft<sup>3</sup>
- Corrected to 500' elevation 0.982 x 0.0729 = 0.0716 lb<sub>da</sub>/ft<sup>3</sup>
- Volume of air to be handled by recirculation fan  
 $3851 \text{ lb}_{da}/\text{hr} \times 13.72 \text{ ft}^3/\text{lb}_{da} = 52,840 \text{ ft}^3/\text{hr}$  at heating coil outlet condition  
 or 880 ft<sup>3</sup>/min

*ETL*  
 #1/198

APPENDIX A



**DAVID W. MCKENZIE, INC.**

Air Handling Equipment

P.O. Box 728, Bellevue, WA 98009

Phone Number: 206-454-4666

Fax Number: 206-562-1169

Date: 02-09-95

Number of Pages (Including Cover Page): 3

To: PETER LANGOWSKI  
KAISER ENGINEERS HANFORD

Fax Number: 509-373-3343

RE:

RECIRCULATION & EXHAUST FANS  
FAN ENGINEERING COMPANY


Message:

Enclosed are performance curves for the design density of 0.0704 lb/cu ft and the upset density of 0.0605 lb/cu ft.

As we discussed, the basic fan and motor size remains the same. The fan wheel diameter will increase from 17" to 18.25".

Information on the clutch for preventing backflow has been forwarded to the factory. It appears as though the overall length of the assembly will increase with the addition of this device. There will be no change in the fan centerline height or in the relationship between the inlet and discharge. I will advise you of any changes as soon as I hear from the factory.

Please call whenever I can be of assistance.



STATIC PRESSURE - INCHES W.G.


KEH  
MODEL 1-20 HP  
IMPELLER DIA. = 18.24 INCHES  
R.P.M. = 3500  
INLET DENSITY = .0704 LB./CU.FT.

C.F.M. VS. S.P. \_\_\_\_\_

C.F.M. VS. B.H.P. \_\_\_\_\_



FAN ENGINEERING CO., INC.  
3430 W. CARRIAGE DRIVE  
SANTA ANA, CA 92704  
(714) 957-5900  
FAX (714) 957-5911




BRAKE HORSEPOWER

Handwritten note: *no 100*

C.F.M.

STATIC PRESSURE - INCHES W.G.

KEH  
 MODEL 1-20 HP  
 IMPELLER DIA. = 18.25 INCHES  
 R.P.M. = 3500  
 INLET DENSITY = .0605 LB./CU.FT.



FAN ENGINEERING CO., INC.  
 3430 W. CARRIAGE DRIVE  
 SANTA ANA, CA 92704  
 (714) 957-5900  
 FAX (714) 957-5911

BRAKE HORSEPOWER



# SYSTEM CURVES - CONT.

KAISER ENGINEERS HANFORD, CO.  
DUCT PRESSURE LOSS  
CALCULATION SHEET

PREPARED BY: Peter H. Langswank  
DATE: 2/15/95  
CHECKED BY:

W320H4319  
JOB NO./ I.W.O. NO.:  
DATE: 241-C-106200E  
DUCT SYSTEM:

NOTES: **General Notes:**  
Pressure loss per 100' Fundamentals p.32.4 Darcy Equation (19).  
Hydraulic diameter per 1993 Fundamentals p.32.6 Equation (24).  
Reynold's Number per 1993 Fundamentals p.32.5 Equation (23).  
Algebraic K-VALUE fitting numbers from 1993 Fundamentals. Nomenclature fitting numbers from 1985 Fundamentals. Pipe data for schedule 40S.  
  
Long Radius (LR) elbows:  $RD = 1.5$ , fitting loss = 0.15; Short Radius (SR) elbows:  $RD = 1.0$ , fitting loss = 0.22, losses per 1991 Applications, p. 27.9.  
Table 4. Combined elbow factor of 1.26 per p. B-14.

#	FLOW		TEMP	REQD USER INPUT		SHADED AREAS REQUIRE		FITTING ASSUMES #1		AIR FLOW		DUCT SIZE		PRESS. LOSS		FITTING LOSS		EQUIV DUCT LENGTH		DUCT AREA		PERI METER		HYDRA DIA		REY		FRICME		F		VEL.		VEL. PRES.					
	SCFM	CFM		DEG F	ACFPA	ACFPA	IN.	IN.	IN.	IN.	IN.	IN.	IN.	IN.	IN.	IN.	IN.	IN.	IN.	IN.	IN.	IN.	IN.	IN.	IN.	IN.	IN.	IN.	IN.	IN.	IN.	IN.	IN.	IN.	IN.				
1	1110	1237	120	0	0	1.500	0.50	24.375	0.05	0.42	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				
2	1110	1237	120	0	0	24.375	0.05	24.375	0.05	0.50	486.64	76.98	24.38	86.513	0.19	0.019	0.019	382	0.009	1.50	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				
3	1110	1237	120	0	0	24.375	0.05	24.375	0.05	0.50	486.64	76.98	24.38	86.513	0.19	0.019	0.019	382	0.009	1.50	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
4	1110	1237	120	0	0	69	39	69	39	0.00	2691.00	216.00	49.83	31.360	0.24	0.024	0.024	66	0.000	1.52	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
5	1110	1237	120	0	0	69	39	69	39	0.00	2691.00	216.00	49.83	31.360	0.24	0.024	0.024	66	0.000	1.52	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		
6	1110	1237	120	0	0	10.020	0.158	10.020	0.158	0.50	78.85	31.48	10.02	215.319	0.16	0.016	0.016	2.259	0.318	1.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
7	1110	1237	120	0	0	10.020	0.158	10.020	0.158	0.50	78.85	31.48	10.02	215.319	0.16	0.016	0.016	2.259	0.318	1.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
8	1110	1237	120	0	0	10.020	0.158	10.020	0.158	0.50	78.85	31.48	10.02	215.319	0.16	0.016	0.016	2.259	0.318	1.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		
9	1110	1237	120	0	0	10.020	0.158	10.020	0.158	0.50	78.85	31.48	10.02	215.319	0.16	0.016	0.016	2.259	0.318	1.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
10	1110	1237	120	0	0	10.020	0.158	10.020	0.158	0.50	78.85	31.48	10.02	215.319	0.16	0.016	0.016	2.259	0.318	1.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
11	1110	1237	120	0	0	10.020	0.158	10.020	0.158	0.50	78.85	31.48	10.02	215.319	0.16	0.016	0.016	2.259	0.318	1.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
12	1110	1237	120	0	0	10.020	0.158	10.020	0.158	0.50	78.85	31.48	10.02	215.319	0.16	0.016	0.016	2.259	0.318	1.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
13	1110	1237	120	0	0	10.020	0.158	10.020	0.158	0.50	78.85	31.48	10.02	215.319	0.16	0.016	0.016	2.259	0.318	1.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
14	1110	1237	120	0	0	10.020	0.158	10.020	0.158	0.50	78.85	31.48	10.02	215.319	0.16	0.016	0.016	2.259	0.318	1.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
15	1110	1237	120	0	0	10.020	0.158	10.020	0.158	0.50	78.85	31.48	10.02	215.319	0.16	0.016	0.016	2.259	0.318	1.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
16	1110	1237	120	0	0	10.020	0.158	10.020	0.158	0.50	78.85	31.48	10.02	215.319	0.16	0.016	0.016	2.259	0.318	1.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
17	1110	1237	120	0	0	10.020	0.158	10.020	0.158	0.50	78.85	31.48	10.02	215.319	0.16	0.016	0.016	2.259	0.318	1.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
18	1110	1237	120	0	0	10.020	0.158	10.020	0.158	0.50	78.85	31.48	10.02	215.319	0.16	0.016	0.016	2.259	0.318	1.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
19	1110	1237	120	0	0	10.020	0.158	10.020	0.158	0.50	78.85	31.48	10.02	215.319	0.16	0.016	0.016	2.259	0.318	1.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
20	1110	1237	120	0	0	10.020	0.158	10.020	0.158	0.50	78.85	31.48	10.02	215.319	0.16	0.016	0.016	2.259	0.318	1.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
21	1110	1237	120	0	0	10.020	0.158	10.020	0.158	0.50	78.85	31.48	10.02	215.319	0.16	0.016	0.016	2.259	0.318	1.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
22	1110	1237	120	0	0	10.020	0.158	10.020	0.158	0.50	78.85	31.48	10.02	215.319	0.16	0.016	0.016	2.259	0.318	1.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
23	1110	1237	120	0	0	10.020	0.158	10.020	0.158	0.50	78.85	31.48	10.02	215.319	0.16	0.016	0.016	2.259	0.318	1.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
24	1110	1237	120	0	0	10.020	0.158	10.020	0.158	0.50	78.85	31.48	10.02	215.319	0.16	0.016	0.016	2.259	0.318	1.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
25	1110	1237	120	0	0	10.020	0.158	10.020	0.158	0.50	78.85	31.48	10.02	215.319	0.16	0.016	0.016	2.259	0.318	1.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
26	1110	1237	120	0	0	10.020	0.158	10.020	0.158	0.50	78.85	31.48	10.02	215.319	0.16	0.016	0.016	2.259	0.318	1.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
27	1110	1237	120	0	0	10.020	0.158	10.020	0.158	0.50	78.85	31.48	10.02	215.319	0.16	0.016	0.016	2.259	0.318	1.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
28	1110	1237	120	0	0	10.020	0.158	10.020	0.158	0.50	78.85	31.48	10.02	215.319	0.16	0.016	0.016	2.259	0.318	1.67	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
29	1110	1237	120	0	0	10.020																																	







KAISER ENGINEERS HANFORD CO.

DUCT PRESSURE LOSS CALCULATION SHEET

JOB NO./ W.D. NO.: W-3205E04319  
BLOG NO./ AREA: 244-1C-106/200E

PREPARED BY: Peter H. Langowski  
DATE: 2/15/95  
CHECKED BY:

NOTES:

- Pressure loss per 1993 Fundamentals p.32.4 Darcy Equation (19).
- Hydraulic diameter per 1993 Fundamentals p.32.6 Equation (24).
- Reynold's Number per 1993 Fundamentals p.32.5 Equation (24).
- Alphabetic ASHRAE fitting numbers from 1993 Fundamentals. Numeric fitting numbers from 1993 Fundamentals. Pipe sizes for schedule 40S.
- Long Radius (LR) elbows: r/D = 1.5, fitting loss = 0.15; Short Radius (SR) elbows: r/D = 1.0, fitting loss = 0.22, losses per 1991 Applications, p. 27.9.
- Table 4. Combined elbow factor of 1.25 per p. B-14.

#	TYPE OF FITTING (ASHRAE #)	AIR FLOW		TEMP	AIR FLOW		TEMP	AIR FLOW		TEMP	PRESS. LOSS	FITTING LOSS	EQIV. DUCT LENGTH	DUCT AREA	PER. AREA	HYDRAL DIA.	REY	FPRIME	F	VEL. FPM	VEL. IN. WG	PRESS. VP
		SCFM	ACFM		SCFM	ACFM		SCFM	ACFM													
71	90 (LR)	346	0	40	346	0	40	346	0	40	6.065	0.028	17	28.89	19.05	6.07	39,458	0.019	0.019	1,724	0.185	29.49
72	90 (SR)	360	0	40	360	0	40	360	0	40	6.065	0.028	17	28.89	19.05	6.07	39,458	0.019	0.019	1,724	0.185	29.49
73	elbow, 90 (LR)	360	0	40	360	0	40	360	0	40	6.065	0.028	2	28.89	19.05	6.07	39,458	0.019	0.019	1,724	0.185	29.49
74	pipe section/flange exhaust riser	360	0	40	360	0	40	360	0	40	6.065	0.028	2	28.89	19.05	6.07	39,458	0.019	0.019	1,724	0.185	29.49
total to exhaust stack 29.53																						
26A	tee, flow split, main (6-3)	860	120	958	0	860	120	958	0	10.020	0.073	0.38	76.85	31.48	10.05	166,924	0.017	0.017	3,750	0.193	13.70	
8D	reducer, contraction (5-1)	860	120	958	0	860	120	958	0	6.065	0.100	0.12	28.86	15.05	6.07	276,610	0.016	0.016	4,777	1.423	13.91	
81	elbow, 90 (LR)	860	120	958	0	860	120	958	0	6.065	5.500	0.15	28.89	19.05	6.07	276,610	0.016	0.016	4,777	1.423	13.91	
83	radius, extension (4-1)	860	120	958	0	860	120	958	0	7.981	0.353	0.68	28.89	19.05	7.98	209,445	0.016	0.016	4,777	1.423	13.91	
84	tee (6-3)	860	120	958	0	7,981	0.000	0.00	50.03	25.07	7.98	209,445	0.016	50.03	25.07	7.98	209,445	0.016	0.017	2,759	0.474	20.14
85	elbow, 90 (LR)	860	120	958	0	7,981	0.000	0.00	50.03	25.07	7.98	209,445	0.016	50.03	25.07	7.98	209,445	0.016	0.017	2,759	0.474	20.14
86	transition (4-3)	860	120	958	0	7,981	0.000	0.00	50.03	25.07	7.98	209,445	0.016	50.03	25.07	7.98	209,445	0.016	0.017	2,759	0.474	20.14
87	transition (4-3)	860	120	958	0	7,981	0.000	0.00	50.03	25.07	7.98	209,445	0.016	50.03	25.07	7.98	209,445	0.016	0.017	2,759	0.474	20.14
88	friction (5-1)	860	120	958	0	7,981	0.000	0.00	50.03	25.07	7.98	209,445	0.016	50.03	25.07	7.98	209,445	0.016	0.017	2,759	0.474	20.14
89	elbow, 90 (LR)	860	120	958	0	7,981	0.000	0.00	50.03	25.07	7.98	209,445	0.016	50.03	25.07	7.98	209,445	0.016	0.017	2,759	0.474	20.14
90	pipe section	860	120	958	0	7,981	0.000	0.00	50.03	25.07	7.98	209,445	0.016	50.03	25.07	7.98	209,445	0.016	0.017	2,759	0.474	20.14
91	reconnection fan FN-1361	860	120	958	0	7,981	0.000	0.00	50.03	25.07	7.98	209,445	0.016	50.03	25.07	7.98	209,445	0.016	0.017	2,759	0.474	20.14
92	elbow, 45 (LR)	860	120	958	0	7,981	0.000	0.00	50.03	25.07	7.98	209,445	0.016	50.03	25.07	7.98	209,445	0.016	0.017	2,759	0.474	20.14
93	pipe section	860	120	958	0	7,981	0.000	0.00	50.03	25.07	7.98	209,445	0.016	50.03	25.07	7.98	209,445	0.016	0.017	2,759	0.474	20.14
94	pipe section	860	120	958	0	7,981	0.000	0.00	50.03	25.07	7.98	209,445	0.016	50.03	25.07	7.98	209,445	0.016	0.017	2,759	0.474	20.14
95	elbow, 45 (LR)	860	120	958	0	7,981	0.000	0.00	50.03	25.07	7.98	209,445	0.016	50.03	25.07	7.98	209,445	0.016	0.017	2,759	0.474	20.14
96	tee, bypass valve (7-3) HV-13648	860	120	958	0	7,981	0.000	0.00	50.03	25.07	7.98	209,445	0.016	50.03	25.07	7.98	209,445	0.016	0.017	2,759	0.474	20.14
97	tee, bypass valve (7-3) HV-13648	860	120	958	0	7,981	0.000	0.00	50.03	25.07	7.98	209,445	0.016	50.03	25.07	7.98	209,445	0.016	0.017	2,759	0.474	20.14
98	elbow, 90 (LR)	860	120	958	0	7,981	0.000	0.00	50.03	25.07	7.98	209,445	0.016	50.03	25.07	7.98	209,445	0.016	0.017	2,759	0.474	20.14
99	converging, wye (5-2)	860	120	958	0	7,981	0.000	0.00	50.03	25.07	7.98	209,445	0.016	50.03	25.07	7.98	209,445	0.016	0.017	2,759	0.474	20.14
100	pipe section fan R-2	860	120	958	0	7,981	0.000	0.00	111.23	31.90	1.986	140,922	0.017	1.986	140,922	0.017	0.017	1,333	0.055	20.87		
split back to tank 7.34 total for static fan 19.37																						

sum delta p (in. w.g.) for seal port calc  
13.68  
13.70  
13.71  
13.72  
13.73  
13.74  
13.75  
13.76  
13.77  
13.78  
13.79  
13.80  
13.81  
13.82  
13.83  
13.84  
13.85  
13.86  
13.87  
13.88  
13.89  
13.90  
13.91  
13.92  
13.93  
13.94  
13.95  
13.96  
13.97  
13.98  
13.99  
14.00  
14.01  
14.02  
14.03  
14.04  
14.05  
14.06  
14.07  
14.08  
14.09  
14.10  
14.11  
14.12  
14.13  
14.14  
14.15  
14.16  
14.17  
14.18  
14.19  
14.20  
14.21  
14.22  
14.23  
14.24  
14.25  
14.26  
14.27  
14.28  
14.29  
14.30  
14.31  
14.32  
14.33  
14.34  
14.35  
14.36  
14.37  
14.38  
14.39  
14.40  
14.41  
14.42  
14.43  
14.44  
14.45  
14.46  
14.47  
14.48  
14.49  
14.50  
14.51  
14.52  
14.53  
14.54  
14.55  
14.56  
14.57  
14.58  
14.59  
14.60  
14.61  
14.62  
14.63  
14.64  
14.65  
14.66  
14.67  
14.68  
14.69  
14.70  
14.71  
14.72  
14.73  
14.74  
14.75  
14.76  
14.77  
14.78  
14.79  
14.80  
14.81  
14.82  
14.83  
14.84  
14.85  
14.86  
14.87  
14.88  
14.89  
14.90  
14.91  
14.92  
14.93  
14.94  
14.95  
14.96  
14.97  
14.98  
14.99  
15.00

DATA USED ABOVE  
elevation density factor at 800 feet = 0.982  
roughness = 0.0001  
density (corrected for elevation) = 0.0554 lbm/ft<sup>3</sup>  
kinematic viscosity = 0.000146 ft<sup>2</sup>/s

120F saturated air  
120F saturated air: 16.519 (lb/ft<sup>3</sup>)  
40F saturated air: 12.685

0.0003 medium smooth  
0.0001 smooth  
0.0001  
0.00  
1.26E-04  
20.00  
1.98E-04  
1.98E-04  
60.00  
1.98E-04  
68.00  
1.60E-04  
80.00  
1.69E-04

iterative factors  
iterative velocity (temp/F)  
Mechanical Engineering  
Reference Manual Eighth Edition, p.3-36.  
W22001016.MLS

W320-28-004

Sizing High Efficiency Mist Eliminator



**CALCULATION IDENTIFICATION  
AND INDEX**  
Continuation Sheet

Date

11-3-94

Discipline 28/HVAC

WO/Job No. ER4319

Calculation No. W320-11-004

	Rev. 0 Signature/Date	Rev. 1 Signature/Date	Rev. 2 Signature/Date
Originator	<i>R. Pitt</i> 11/3/94	<i>R. Pitt</i> 4/3/95	
Checked by	<i>B. Rice</i> 11/3/94	<i>P. H. ...</i> 4-3-95	

INDEX

Design  
Analysis  
Page No.

Description

Appx A-A1-A 2 Sample Calculation


**DESIGN ANALYSIS**

Client WHC

WO/Job No. ER4319/W320

Subject Sizing of High Efficiency Mist  
Eliminator

Date 11-3-94

By R. Pina

Location 241-C/200 East

Checked 11/8/94

By P. Rice

Revised 4/3/95

By R. Pina

PHR 434

**1.0 OBJECTIVE**

To size a High Efficiency Mist Eliminator (HEME) for Project W-320.

**2.0 CRITERIA**

The HEME will remove aerosols and condensed water vapor (mist) from the exhaust ventilation system of Tank 241-C-106. Criteria provided per reference (1) and (2), and (16).

**3.0 GIVEN DATA**

The tank airstream characterization, per Reference (2), is as follows:

~~AMMONIA AND ORGANIC CONCENTRATIONS~~

Component	Concentration (mg/m <sup>3</sup> )
EDTA	0.03285
HEDTA	0.02664
Oxylates and formulate and citrate	0.50286
Ammonia	0.00765

**TOTAL AEROSOL CONCENTRATION**~~(<10 micron)~~

(includes components above)

Component	Concentration (mg/m <sup>3</sup> )
Water	±0 2.97E+02
Soluble solids in water solution	±0 6.92E-01
Insoluble free solids	±0 1.49E+01
Total	±00 313

Air Flow Rates, per Reference (14), are as follows:

Range 180-360 scfm  
nominal 230 scfm

HNF-2483, Rev. 0

Page C-3

**DESIGN ANALYSIS**

Client WHC

WO/Job No. ER4319/W320

Subject Sizing of High Efficiency Mist  
Eliminator

Date 11-3-94

By R. Pina

Location 241-C/200 East

Checked 11/8/94

By P. Rice

AJR 4-3-95

Revised 4/3/95

By R. Pina

**4.0 ASSUMPTIONS**

Review of references, standards, etc... indicates that there is no definitive process to size/select a HEME. As will be shown later there are varied recommendations by manufacturers, test labs and users of HEME's. Material from many sources were gathered to provide a basis for sizing and selection of a HEME for Project W-320. Assumptions are as stated within calculation.

**5.0 REFERENCES**

- 1) DOE 6430.1A, General Design Criteria
- 2) WHC-SD-W320-FDC-001, rev. 2, 1/18/94
- 3) IAEA-TELDOC-521, Retention of Iodine and Other Airborne Radionuclides in Nuclear Facilities During Abnormal and Accident Conditions, 1989
- 4) US Energy Research and Development Administration 76-21, 1976
- 5) Perry's Chemical Engineering Handbook, 6th Edition
- 6) PNL-7142, Hanford Waste Vitrification Program Pilot-Scale Ceramic Melter Test 23
- 7) PNL-7188, Performance Evaluation of the Pilot-Scale, Double-Shell Tank Ventilation System Using Simulated Aerosol Streams.
- 8) IAEA-TELDOC-325, Particulate Filtration in Nuclear Facilities, 1991
- 9) Industrial Ventilation, 2nd Edition
- 10) ASME N509-1989, Nuclear Power Plant Air Cleaning Units and Components
- 11) Monsanto Enviro-Chem Quote MCB-001-21390.00-000
- 12) KOCH Engineering Co. Quote 61921A00
- 13) CEKO Filters Inc. Quote 2973-3
- 14) H-2-818470, HVAC Overall Flow Diagram, Rev. 0
- 15) Calculation W320-H-015, Rev. 0
- 16) LOT, ADDENDUM 7, 12/13/94



# DESIGN ANALYSIS

Client WHC  
 Subject Sizing of High Efficiency Mist  
 Eliminator  
 Location 241-C/200 East

WO/Job No. ER4319/W320  
 Date 11-3-94 By R. Pina  
 Checked *11/8/94* By *P. Rice*  
 Revised By

## 7.2 FILTER SURFACE AREA

With a face velocity of 12 ft/min the required surface area is as follows:

The maximum flow shall be Flow:= 360 scfm  
 utilized to size HEME filter area. Velocity:= 12 fpm

The actual maximum flow rate at 40F, 13.5psia is:  $360 \left( \frac{14.7}{14.7 - 1.2} \right) \cdot \left( \frac{460 + 40}{520} \right) = 377$  acfm

Surface Area Required Min.  $\frac{377}{12} = 31$  ft<sup>2</sup>

## 7.3 NOZZLE SPRAY RATE

The cases below are the best examples of water spray rates and will be used to determine the spray rate for Project W-320. The range of spray rates could be attributed to the different filter configurations, fiberbed packing density, manufacturer experience, flow conditions, flow rates, etc.... There are too many variables to determine why the spray rates vary so much; therefore, the most conservative option is to select a spray nozzle that can provide .086 to 10.5 gph.

# DESIGN ANALYSIS

Client WHC

WO/Job No. ER4319/W320

Subject Sizing of High Efficiency Mist Eliminator

Date 11-3-94

By R. Pina

Location 241-C/200 East

Checked 11/3/94

By P. Rice

Revised

By

TABLE 1

	Savannah River <sup>1</sup>	DWPF <sup>2</sup>	CECO <sup>3</sup>	PNL <sup>4</sup>	PNL <sup>5</sup>
Spray Rate (mg/ft <sup>3</sup> )	15	50	51	1471	.25 (gph/ft <sup>2</sup> )
Total gph required for W-320 using above rates at 360 scfm	.086	.286	.29	8.4	10.5
Rate Developed by	in-use	in-use	experience	scale study	scale study

see Appx A for sample calc

- 1) Per discussion with D. Miller, Westinghouse Savanna, 6/29/94
- 2) Para. 10.2.5, Ref. (6), Defense Waste Processing Facility (DWPF) at Savannah River
- 3) Quote No. 2973-2, CECO Filters
- 4) Pg 10.53-10.54, Ref. (6)
- 5) Pg 2.3, Ref. (7), note spray rate was rated per ft<sup>2</sup> of filter

Having determined the range of .086 to 10.5 gph the size of the spray nozzle can now be selected. The following flow rates utilize "FullJet" spray nozzles, Spraying Systems Co. to estimate the time required to achieve the gph range. A spray nozzle of .29 ±.05 gpm at 40 ±10 psig provides the gph range at reasonable spray durations and provides additional capacity if required.

# DESIGN ANALYSIS

Client WHC

WO/Job No. ER4319/W320

Subject Sizing of High Efficiency Mist Eliminator

Date 11-3-94

By R. Pina

Location 241-C/200 East

Checked *11/8/94*

By *P. Rice*

Revised

By

	Gallons per Hour					Maximum Flow in 1hr (gal)
	.086	.286	.29	8.4	10.5	
Nozzle at 40 psig (gpm)	Time to reach gph (minutes)					
.95	.09	.3	.3	9	11	57
.5	.17	.6	.6	17	21	30
.38	.32	.8	.8	22	28	22.8
.29	.29	1.	1.	29	36	17.4
.19	.45	1.5	1.5	44.2	55	11.4

see Appx A for sample calc

Note per Ref. (5), pg 18-84, "solid particulates are captured as readily as liquids in fiber beds but can rapidly plug the bed if they are insoluble." Solid particulate if not washed away from the fiberbed can become imbedded and impossible to wash off. Therefore, it is imperative that solids introduced into the HEME be minimized and spraying be done frequently to remove insolubles which have impacted the face of the fiberbed. Various studies, handbooks and manufacturers have concluded that intermittent washing of the HEME filter will remove collected aerosols and regenerate the filter (e.g., pg 6.31 of Ref. (7) and pg 37 of Ref. (8)). Findings per Ref. (3), paragraph 5.1.4, indicated "the pressure drop of the HEME filter intensively sprayed with regeneration liquid is dependent on regeneration cycles." Also manufacturers such as CECE recommend spraying intermittently.

Since the introduction of water into a contaminated stream should be minimized and frequent spraying is desired for regeneration, initially the spray should be operated at the low end providing .29 gal/hr and may be increase if necessary. Since the spray will operate for 1 min., it essentially provides .29 gpm. Note, this is significantly greater than .035 gpm of mist in the airstream (due to reentrained water at condenser) and should provide sufficient washing of the fiber, see paragraph 7.7. Monitoring of the differential pressure is recommended during initial operation and the spray rate shall be adjusted, as required. In addition, during any major changes in system operation (e.g, increased sluicing) the HEME should be monitored and adjusted (i.e., frequency & duration of spray) as required. It is not recommended that the HEME operate without intermittent spraying, since this is likely to reduce the life of the HEME.

## DESIGN ANALYSIS

Client WHC  
Subject Sizing of High Efficiency Mist  
Eliminator  
Location 241-C/200 East

WO/Job No. ER4319/W320  
Date 11-3-94 By R. Pina  
Checked 11/8/94 By R. Rice PAK 4-395  
Revised 4/4/95 By Z. Pao

### 7.4 FIBER MATERIAL

Recommendations from manufacturers indicate that fiberglass is not resistant to ammonia vapors and polyester is more resistant. Polyester as indicated in Table 4-1 of Ref. (9) provides fair to excellent resistance to various chemicals (mineral acid, organic acid, alkalies, solvents & oxidizing). Without the ability to perform tests with the actual airstream and fiberbed, the recommendations of the manufacturers and Ref. (9), Table 4-1 will be relied upon.

#### 7.4.1 GASKET MATERIAL

Based on the following, EPR (EPT (NORDEL) more commonly known as EPT or EPDM or EPR) gaskets shall be used in the HEME. Compatibility charts from Aeroquip and Pall Trinity Micro Corp. indicate that EPR is compatible with ammonia. Chicago Wilcox Mfg. Co. recommends EPR for chemicals, acids, alkalis. Klinger Inc. indicates that it is suitable for ammonia and has excellent aging properties. Grinnell Saunders indicates that EPR has the best relative radiation resistance of their materials. Note, Viton and Buna-N were considered but eliminated due to unsatisfactory resistance to ammonia (anhydrous and aqueous) per AEROQUIP, AIRCO and PALL compatibility charts. Neoprene was not chosen since EPR provides better resistance to chemicals and radiation. Ref. (6) indicates that Ammonia is no longer a concern; however, material will not be changed since it will perform satisfactorily.

#### 7.5 LIFE EXPECTANCY

Essentially the HEME can be regenerated if the airstream consists mostly of soluble aerosols and minimal amounts of insoluble solid particulate. Reference (7) attempted to predict the life of a HEME with a scale HEME; however, attempts to extrapolate this data were unsuccessful. Most references did not provide methods or estimates to predict the life of a HEME; however, I found agreement that the HEME will be regenerated with a water spray. Spraying frequently appears to be the key in extending the life of the HEME.

**DESIGN ANALYSIS**

Client WHC

WO/Job No. ER4319/W320

Subject Sizing of High Efficiency Mist  
Eliminator

Date 11-3-94

By R. Pina

Checked 11/8/94

By G. Diaz

PH 4-3-95

Location 241-C/200 East

Revised 4/3/95

By J. Pina

7.6 AEROSOL REMOVAL EFFICIENCY

HEME's have varying removal efficiencies dependent upon many variables, fiber density, fiber material, flow rates, airstream, etc... The ranges listed below provide some guidance as to what we can expect. Monsanto and KOCH guarantee that their removal efficiency will be obtained and their efficiencies appear to be in close agreement with the other data. Note, other studies have demonstrated that higher efficiencies are attainable: therefore, it is within reason that manufacturer estimates are attainable. Therefore, the HEME shall be specified to satisfy a removal efficiency of all particulates  $>3\mu\text{m}$  <sup>essentially</sup> 100% and  $\leq 3\mu\text{m}$  99.5%.

The following removal efficiencies were obtained from studies or references:

Ref. (3)  $\geq 99.97\%$   
aerosols sizes of  $0.52\mu\text{m}$ .

Ref. (4) 99.3%  
 $0.3-0.5\mu\text{m}$ .

Ref. (5), 5th ed., Table 18-29,  
99.3%  
 $\leq 3\mu\text{m}$  inlet concentration of  $2.12\text{ mg/scfm}$  of  $\text{H}_2\text{SO}_4$ .

Table 18-22, Ref (5)  
 $>3\mu\text{m}$  100%  
 $\leq 3\mu\text{m}$  95-99%

Para. 5.4 of Ref. (10),  
99%  
 $5-10\mu\text{m}$

The following quotes are manufacturer removal efficiencies for the airstream characterization at low face velocities for project W-320:

III Monsanto Enviro-Chem (Ref. 11)  
 $>3\mu\text{m}$  100%  
 $\leq 3\mu\text{m}$  99.5%

IV KOCH Engineering Co. (Ref. 12)  
 $>3\mu\text{m}$  100%  
 $\leq 3\mu\text{m}$  99.5%

V CECO Filters Inc. (Ref. 13)  
 $\geq 0.5\mu\text{m}$  99%

7.7 Concentration of Reentrained Condenser Water at HEME

## DESIGN ANALYSIS

Client WHC

Subject Sizing of High Efficiency Mist  
Eliminator

Location 241-C/200 East

WO/Job No. ER4319/W320

Date 11-3-94

Checked 11/2/94

Revised

By R. Pina

By *R. Pina*

By

The following calculation determines the amount of water mist at the inlet to the HEME due to reentrained water at the condenser. See Calc W320-H-015 for additional information.

Volumetric flowrate of reentrained water at inlet to HEME:

$$m_w := 0.7 \cdot \frac{\text{lb}}{\text{min}}$$

In lieu of repeating Ref (15), paragraph 7.5 calc, the reentrained mist at the HEME is equal to a percentage of the mist originating from the condenser.

$$m_r := \frac{360 \cdot \frac{\text{ft}^3}{\text{min}}}{860 \cdot \frac{\text{ft}^3}{\text{min}}} \cdot m_w$$

$$m_r = 0.293 \cdot \frac{\text{lb}}{\text{min}}$$

Concentration of reentrained water at inlet to HEME:

$$m_r \cdot 0.454 \cdot \frac{\text{kg}}{\text{lb}_m} \cdot \frac{1}{360} \cdot \frac{\text{min}}{\text{ft}^3} \cdot \left(3.281 \cdot \frac{\text{ft}}{\text{m}}\right)^3 \cdot 1 \cdot 10^6 \cdot \frac{\text{mg}}{\text{kg}} = 13052 \cdot \frac{\text{mg}}{\text{m}^3}$$

**DESIGN ANALYSIS**

Client WHC  
Subject SIZING OF HIGH EFFICIENCY MIST  
ELIMINATOR  
Location 241-C/200EAST

WO/Job No. ER 4319/W-320  
Date 7/12/94 By R. PINA  
Checked 11/8/94 By P. Ric  
Revised By


7.8 SPRAY WATER GENERATED OVER 2 YRS:

$$\left( \frac{1 \text{ min}}{\text{hr}} \right) \left( \frac{24 \text{ hrs}}{\text{day}} \right) \left( \frac{365 \text{ days}}{\text{yr}} \right) (2 \text{ yr}) \left( .29 \frac{\text{gal}}{\text{min}} \right) = 5,081 \text{ gal}$$

BASED ON .29 gpm, OPERATING 1 min/hr for 2 yrs

7.9 MAXIMUM HEME DIMENSIONS

WIDTH OF HEME IS APPROXIMATED FROM QUOTES RECEIVED FROM VENDORS, EXCEPT FOR SHIELDING.



$$\text{WIDTH} = \text{FILTER OD.} + (2)(4.6 + .5 + 5.75)$$

FOR 32" OD, W = 54"

FOR 24" OD, W = 46"

THE AVAILABLE SPACE IS ~49", TO THE WALL. VENDORS SHOULD BE ABLE TO PROVIDE A WIDTH OF ≤ 45". THIS WOULD ALLOW 4" CLEARANCE FOR WALL.

**DESIGN ANALYSIS**

Client WAC  
Subject SIZING OF HIGH EFFICIENCY MIST  
ELIMINATOR  
Location 241 - C/200 EAST

WO/Job No. ER 4319 W-320  
Date 7/12/94 By R. PINA  
Checked 11/8/94 By B. Rice  
Revised By

**7.9 CONT.**

ESTIMATED HEIGHT OF HEHE IS APPROXIMATED FROM VENDOR QUOTES AS WELL AS UTILIZING REQUIRED FACE VELOCITY TO DETERMINE FILTER SURFACE AREA.

AREA REQUIRED IS 31 - 42 FT<sup>2</sup>, SEE PARA 7.2

MINIMUM HEIGHT

(FOR "CECO")

32" OD  
28" ID

HT OF FILTER IS, AT MIN. AREA

$$\frac{31 \text{ FT}^2}{2\pi (1.167 \text{ FT})} = 4'$$

MAXIMUM HEIGHT

(FOR "MONSANTO")

24" OD  
20" ID

AT MAX. AREA

$$\frac{42 \text{ FT}^2}{2\pi (.933 \text{ FT})} = 8'$$

THE HT ESTIMATED IS

	MONSANTO	CECO
FILTER	8 (MAX)	4 (MIN)
HOUSING	3.5	3.5
SHIELDING	1	1
SUPPORT	1.5	1.5
	<u>14'</u>	<u>10'</u>

IT IS LIKELY A HEHE CAN BE SIZED TO ACCOMODATE A 10'3" AVAILABLE HEIGHT. NOTE 11' IS ACTUALLY AVAILABLE SO THIS WOULD PROVIDE A 9" CLEARANCE.

**DESIGN ANALYSIS**

Client **WHC**  
Subject **SIZING OF HIGH EFFICIENCY MIST  
ELIMINATOR**  
Location **241-C/200 EAST**

WO/Job No. **ER4319/W-320**  
Date **7/12/94** By **R. PIÑA**  
Checked **11/8/94** By **P. Die**  
Revised \_\_\_\_\_ By \_\_\_\_\_

**APPX A**  
**SAMPLE CALC FOR TABLE 1**

THE FOLLOW CALCULATIONS CONVERT THE RECOMMENDED  
SPRAY RATES TO  $mg/Ft^3$ , FOR TABLE 1.

FOR "CECO"  
THEY RECOMMENDED .37 gal/hr AT MAX 460 SCFM

$$= \frac{(.37 \text{ gal/hr}) \left( \frac{1}{.1198} \frac{lb}{gal} \right) \left( \frac{1}{2.205 \times 10^{-3}} \frac{g}{lb} \right) \left( \frac{1000 \text{ mg}}{1} \right)}{\left( \frac{60 \text{ min}}{hr} \right) \left( 460 \frac{ft^3}{min} \right)} = 51 \frac{mg}{ft^3}$$

FOR PNL<sup>4</sup> THEY RECOMMENDED 15 L/hr, AT MAX 170 SCFM

$$= \frac{(15 \text{ L/hr}) \left( 1.2642 \frac{gal}{L} \right) \left( \frac{1}{.1198} \frac{lb}{gal} \right) \left( \frac{1}{2.205 \times 10^{-3}} \frac{g}{lb} \right) \left( \frac{1000 \text{ mg}}{1} \right)}{\left( \frac{60 \text{ min}}{hr} \right) \left( 170 \frac{ft^3}{min} \right)}$$

= 1471  $mg/Ft^3$

SPRAY RATES FOR SAVANNAH, DWPF & PNL<sup>5</sup> NOT SHOWN SINCE  
THEY WERE GIVEN IN  $mg/Ft^3$ .

**DESIGN ANALYSIS**

Client WHC  
Subject SIZING OF HIGH EFFICIENCY  
MIST ELIMINATOR  
Location 241-C/200 EAST

WO/Job No. ER4319/W-320  
Date 7/12/94 By R. PINA  
Checked 11/8/94 By G. Rice  
Revised By

THE GPH REQUIRED AT RECOMMENDED SPRAY RATES AT 360SCFM ARE DETERMINED AS FOLLOWS: (FOR TABLE 1)

FROM VARIOUS RECOMMENDATIONS

$$GPH = \left( \square \frac{mg}{Ft^3} \right) \left( \frac{1}{1000} \frac{i}{mg} \right) \left( 2.205 \times 10^{-3} \frac{lb}{g} \right) \left( \frac{1}{9} \right) \left( 1198 \frac{gal}{lb} \right) \left( \frac{60 \text{ min}}{hr} \right) \left( 360 \frac{Ft^3}{min} \right)$$

$$= \left( \square \frac{mg}{Ft^3} \right) \left( 5.71 \times 10^{-3} \right)$$

FOR EXAMPLE AT 51 mg/Ft<sup>3</sup>, CECCO

$$GPH = 51 (5.71 \times 10^{-3}) = .29 \text{ gph}$$

TIME FOR SPRAYING OBTAINED AS FOLLOWS:  
(FOR TABLE 2)

$$\frac{.29 \text{ gph}}{\text{spray rate} \rightarrow .29 \text{ gpm}} = 1 \text{ minute per hr}$$

TOTAL GPH FOR PNL<sup>S</sup> DETERMINED USING MAX AREA

$$.25 \frac{gph}{Ft^2} (42 \text{ Ft}^2) = 10.5 \text{ gph}$$

W320-28-005

Sizing Electric Heating Coil



**DESIGN ANALYSIS**

Client WHC  
Subject SIZING ELECTRIC HEATING COIL  
Location 241-C/200E

WO/Job No. ER4319  
Date 5-10-94  
Checked *R.M.*  
Revised 4/4/95  
By B. E. HURNEVICH  
By 5/18/94 *AK 4695*  
By *R.P.M.*

**OBJECTIVE:** THE OBJECTIVE OF THIS CALCULATION IS TO SIZE THE ELECTRIC HEATING COIL REQUIRED FOR THE HVAC RECIRCULATION LOOP FOR PROJECT W-320.

**CRITERIA AND SOURCE:** FUNCTIONAL DESIGN CRITERIA, WHC-SD-W320-FDC-001, REVISION 2.

GIVEN DATA:

- AIR ENTERS COIL AT 40FDB (DRAWING H-2-818470<sup>68</sup>, REV. 0)
- ~~15% CONDENSATE (DRAWING H-2-818478, REV. 0) IS ENTRAINED IN THE AIRSTREAM. 15% OF THE CONDENSATES ENTERING THE CONDENSER UPSTREAM OF THE HEATER.~~
- DURING NORMAL OPERATION AIR WILL LEAVE THE COIL AT 77FDB. (DRAWING H-2-818470<sup>68</sup>, REV. N 0)
- AIR VOLUME FLOWING ACROSS COIL WILL BE 860 SCFM (DRAWING H-2-818470<sup>68</sup> REV. 0).
- ASSUME HEATING COIL WILL BE SIZED TO HAVE THE CAPABILITY OF HEATING AIR UP TO 100FDB.

METHODS TO BE USED: HAND CALCULATIONS.

REFERENCES:

- 1 • CHROMALOX TECHNICAL P-120 CATALOG, PAGE 604 & 605.
- 2 • ASHRAE 93' FUNDAMENTAL.
- 3 • CRANE FLOW OF FLUIDS (TECHNICAL PAPER NO. 410).
- 4 • ASHRAE POCKET GUIDE FOR HVAC. (1989)
- 5 • FUNDAMENTAL OF ENGINEERING THERMODYNAMICS PAGE A-57. (ROBERSON/CROWE THIRD EDITION)
- 6 W320-H-005, SIZING OF MOISTURE SEPARATOR, REV. 1

CALCULATION:

Sensible heating:

$$KW = \frac{Wt * Cp * (T2-T1) * S. F.}{3412} \text{ (Chromalox page 604)}$$

where:

Air Volume = 860 scfm

Air density = .0749 lb/ft<sup>3</sup> at 70F (Ashrae Pocket Guide for HVAC, PAGE 129)

Wt - Weight of Air per hr. (Mass Flow Rate)

$$Wt = \text{Air volume} * \text{Air density} * 60 \text{ min/hr}$$

$$Wt = 860 \text{ scfm} * .0749 \text{ lb/ft}^3 * 60 \text{ min/hr} = 3865 \text{ lb-air/hr.}$$

Cp - Specific Heat of Air = .24 Btu/lb at 70F (Fund. of Eng. Thermodynamics PAGE A-57)

$$T2 - T1 - \text{TEMPERATURE ACROSS COIL} = 100F - 40F = 60 F$$

**DESIGN ANALYSIS**

Client WHC  
Subject SIZING ELECTRIC HEATING COIL

WO/Job No. ER4319

Date 5-10-94 By B. E. HURNEVICH

Checked *S-18-94* By *EM PR 4695*

Revised *4/4/95* By *TPH*

Location 241-C/200E

S. F. - Safety Factor 1.15 (15%)

3412 Btu/hr. = 1 KW

$KW = \frac{3865 \text{ lb air/hr} * .24 \text{ Btu/lb} * (100F - 40F) * 1.15}{3412 \text{ Btu/hr}} = 18.75 \text{ KW}$

Latent heat of Vaporization of <sup>36</sup>15% liquid condensate in airstream:

Entering the Condenser at 95F and 100%RH the Humidity Ratio(HR) = .036757 lb.moisture/lb.dry air (ASHRAE 93' Fundamentals Table 2 Page 6.4)

Mass Flow Rate(Wt) = Air Volume \* Air Density \* 60 min/hr.  
Air Volume = 860 scfm, Air Density = .0749 lb./ft<sup>3</sup>  
Wt = 860 scfm \* .0749 lb./ft<sup>3</sup> \* 60 min/hr. = 3865 lb/hr

Amount of H2O in Airstream: Wt \* HR  
H2O = 3865 lb/hr \* .036757 lb.moisture/lb.dry air = 142 lb.H2O/hr

Exiting the Condenser at 40F and 100% RH Humidity Ratio (HR) = .005216 lb.moisture/lb.dry air. (ASHRAE 93' Fundamentals Table 2 Page 6.3)

Amount of H2O in airstream exiting condenser: 3865 lb/hr \* .005216 lb.moisture/lb.dry air = 20.2 lb/hr

Amount of condensate = ~~142 lb.H2O/hr - 20.2 lb.H2O/hr = 121.8 lb.H2O/hr~~  
*0.11 lb/min From Ref. (6), (.7-.59), REPRESENTS 36% REENTRINMENT*  
~~15% of the condensate = 18.3 lb.H2O/hr~~

Heat of Vaporization of <sup>6.6</sup>~~18.3~~ lb.H2O/hr of condensate:

Latent Heat of Evaporization of H2O at .2 psig and 53F = 1053 Btu/lb. (Crane Flow of Fluids page A-12)

$BTU = \frac{6.6}{18.3} \text{ lb.H2O/hr} * 1053 \text{ Btu/lb} = \frac{6950}{19270} \text{ btu/hr}$

$KW = \frac{6950}{3412} \text{ btu/hr} = \frac{2.0}{5.7} \text{ KW}$

TOTAL POWER REQUIRED ELECTRIC HEATING COIL = 18.75KW + <sup>2.0</sup>5.7KW = <sup>20.75</sup>24.45KW

**CONCLUSION:** An additional 15% safety factor was included in the sizing of this heating coil along with the heating coil having the capability of heating air up to 100FDB. With the presence of <sup>2.0</sup>15% liquid condensate in the airstream an additional <sup>5.7</sup>5.7KW of power is needed to evaporate the condensate. The total power required to heat the airstream to the specified design conditions is ~~24.45KW~~, therefore a 30KW heating coil has been selected. *The heating coil is slightly oversized to provide additional capacity for coil element failure. If a few coil elements fail, immediate replacement is not required to maintain the required load.*

BEST AVAILABLE COPY

HNF-2483, Rev. 0

Page D-4

# High temperature air duct heaters

- From 300 kW and above
- Outlet air temperatures to 1200°F
- 40 volt 3 phase (voltages to 480 V available)
- With .475 dia. tubular elements
- Types ADH and ADHT

**Applications**

- Heating air for various drying/curing operations up to 1200°F air temperature
- Heat treating
- Re-heating or dehumidification
- Other similar air heating applications

**Features**

- Riveted construction. Sturdy 0.475 diameter tubular elements mounted to a heavy 3/4" or 1" thick steel flange.
- Elemental housing made of 18 ga. galvanized steel. Element support plates of 16 ga. aluminumized steel are in place by stainless steel support bolts. High temperature units have the special feature of stainless steel material for the 3 inch insulation housing and element support plate — all of which provides superior rigidity, strength and reliability.


- Long life metal sheath tubular elements—Corrosion/oxidation resistant sheath. High grade Chromalox® sheath material for excellent corrosion/oxidation resistance at high operating temperatures.

- High purity magnesium oxide. The elements are filled with highest purity grades of magnesium oxide refractory (MGO) compacted to a rock hard density to insure maximum thermal conductivity and electrical insulation resistance.


- Superior grade resistance wire. The elements of each heating element is made of 80% nickel-20% chromium resistance wire for maximum long life.

- Low watt density resistor wire. Watt density on the heating coil is designed for low watt density operation by increasing the coil diameter, gauge and length of resistance wire to give maximum surface area and low operating coil surface temperature — providing longer coil life.



ADH—Low/medium temperature (30 w/in²)  
(800°F maximum output air temperature)



Duct opening is  
D + 1/4" x M + 1/4"



Typical Installation



ADH—Low/medium temperature (30 w/in²)

kW	Dimensions—Inches								No. Elem.	No. Cirs.	Catalog No.	SP-17	PCN	WL Lbs.	
	A	B	C	D	E	H	K	L							
5	5 1/2	20 1/4	28 1/4	4	1/4	2 1/2	3 1/2	1 1/4	9 1/2	3	1	ADH-005	S	210016	8
10	7 1/2	20 1/4	28 1/4	6	1/4	3 1/2	3 1/2	1 1/4	9 1/2	6	1	ADH-010	S	210022	15
15	9 1/2	20 1/4	28 1/4	8	1/4	3	3 1/2	1 1/4	9 1/2	9	1	ADH-015	S	210032	25
20	11 1/2	20 1/4	28 1/4	10	1/4	2 3/4	3 1/2	1 1/4	9 1/2	12	1	ADH-020	S	210040	35
25	13 1/4	20 1/4	28 1/4	12	1/4	3 1/4	3 1/4	1 1/4	9 1/2	15	1	ADH-025	S	210059	40
30	15 1/4	20 1/4	28 1/4	14	3/4	3 1/4	3 1/2	1 1/4	9 1/2	18	1	ADH-030	S	210057	55
35	17 1/4	20 1/4	28 1/4	16	3/4	4 1/4	3 1/2	1 1/4	9 1/2	21	1	ADH-035	S	210075	65
40	19 1/4	20 1/4	28 1/4	18	3/4	4 3/4	3 1/2	1 1/4	9 1/2	24	2	ADH-040	S	210023	70
45	21 1/4	20 1/4	28 1/4	20	3/4	5 1/4	3 1/2	1 1/4	9 1/2	27	2	ADH-045	S	210091	80
50	23 1/4	20 1/4	28 1/4	22	3/4	5 3/4	3 1/2	1 1/4	9 1/2	30	2	ADH-050	S	210104	90
60	27 1/4	20 1/4	28 1/4	26	3/4	4 1/2	3 1/2	1 1/4	9 1/2	36	2	ADH-060	S	210112	105
80	35 1/4	20 1/4	28 1/4	34	3/4	4 1/2	3 1/2	1 1/4	9 1/2	48	4	ADH-080	KS	210122	140
90	39 1/4	20 1/4	28 1/4	38	3/4	4 1/2	3 1/2	1 1/4	9 1/2	54	5	ADH-090	KS	210139	160
100	43 1/4	20 1/4	28 1/4	42	3/4	5 1/4	3 1/2	1 1/4	9 1/2	60	5	ADH-100	KS	210147	175
144	35 1/4	35	42 1/4	34	3/4	4 1/2	3 1/2	1 1/4	9 1/2	48	4	ADH-144	KS	210153	165
162	39 1/4	35	42 1/4	38	3/4	4 1/2	3 1/2	1 1/4	9 1/2	54	5	ADH-162	S	210163	185
216	27 1/4	35	42 1/4	26	3/4	4 1/2	3 1/2	20	18 1/2	72	6	ADH-216F	S	210171	240
270	35 1/4	35	42 1/4	32	3/4	5 1/4	3 1/2	20	18 1/2	90	6	ADH-270F	S	210190	300

Specify: Quantity, catalog no., PCN, kW, air duct heaters.

Process Air

A-2

D/4 Process air heaters

# High temperature air duct heaters (con't.)

Superior performance at element bends. All elements bends are repressed in hydraulic presses after bending to assure recombination of refractory material to eliminate hot spots and electrical insulation voids.

Sturdy metal sheath elements eliminate problems associated with open coil resistance wire units. Such as high operating temperatures resulting in shorter life, short circuits due to broken resistance wire or insulators, electrical shock hazard and flash fire hazard on start up due to dust and dirt accumulation.

Easy element replacement. Individual elements are mechanically fastened to the flange permitting convenient, easy replacement.

Low wiring compartment temperatures. Made possible by the addition of a one inch thick blanket of insulation in the terminal box—allows use of low temperature field wiring instead of expensive high temperature busbars and additional three inches of insulation to help reduce duct heat losses.



Meets NEC wiring requirements. Heaters are subdivided into 48 amp maximum circuits in compliance with the National Electrical Code (NEC).

Easy access to simplified field wiring terminals. Terminal housing is completely removable for maximum access to field wiring terminals. Individual terminal blocks with threaded stud type terminals are provided for each circuit to permit quick positive attachment of circuit wiring conductors.

Dirt/dust resistant terminal housing. Terminal housing made of solid heavy gauge aluminumized steel rather than perforated metal to resist dirt and dust accumulation on the electrical connections and thus provide longer service life.

Flange mounting gasket. Packed separately with each duct heater to minimize air leakage between the flange and air duct.

ADHT—High temperature (20 w/in.<sup>2</sup>)  
(1200°F maximum output air temperature)



ADHT—High temperature (20 w/in.<sup>2</sup>)

kW	Dimensions—Inches							No. Elem.	No. Circ.	Catalog No.	Status	PCN		
	A	B	C	D	E	H	K							
5	5 1/2	20 1/2	28 1/4	4	1/4	2 1/2	3 1/2	11 1/2	9 1/2	3	1	ADHT-005	S	210158-10
10	7 1/2	20 1/2	28 1/4	6	1/4	3 1/2	3 1/2	11 1/2	9 1/2	6	1	ADHT-019	NS	210220-23
15	9 1/2	20 1/2	28 1/4	8	1/4	3	3 1/2	11 1/2	9 1/2	9	1	ADHT-015	NS	210219-28
20	11 1/2	20 1/2	28 1/4	10	1/4	2 3/4	3 1/2	11 1/2	9 1/2	12	1	ADHT-020	S	210227-21
25	13 1/2	20 1/2	28 1/4	12	1/4	3 1/4	3 1/2	11 1/2	9 1/2	15	1	ADHT-025	NS	210235-25
30	15 1/2	20 1/2	28 1/4	14	1/4	3 3/4	3 1/2	11 1/2	9 1/2	18	1	ADHT-030	NS	210243-25
35	17 1/2	20 1/2	28 1/4	16	3/4	4 1/4	3 1/2	11 1/2	9 1/2	21	1	ADHT-035	S	210227-18
40	19 1/2	20 1/2	28 1/4	18	3/4	4 3/4	3 1/2	11 1/2	9 1/2	24	2	ADHT-040	S	210250-25
45	21 1/2	20 1/2	28 1/4	20	3/4	5 1/4	3 1/2	11 1/2	9 1/2	27	2	ADHT-045	NS	210278-18
50	23 1/2	20 1/2	28 1/4	22	3/4	5 3/4	3 1/2	11 1/2	9 1/2	30	2	ADHT-050	NS	210285-18
60	27 1/2	20 1/2	28 1/4	26	3/4	4 1/2	3 1/2	11 1/2	9 1/2	36	2	ADHT-050	S	210254-18
80	35 1/2	20 1/2	28 1/4	34	3/4	4 2/4	3 1/2	11 1/2	9 1/2	48	4	ADHT-080	NS	210307-17
90	39 1/2	20 1/2	28 1/4	38	3/4	4 7/8	3 1/2	11 1/2	9 1/2	54	5	ADHT-090	NS	210315-20
100	43 1/2	20 1/2	28 1/4	42	3/4	5 1/2	3 1/2	11 1/2	9 1/2	60	5	ADHT-100	NS	210322-20
120	27 1/2	35	42 1/2	26	3/4	4 7/8	3 1/2	11 1/2	9 1/2	35	4	ADHT-120	NS	210331-25
160	35 1/2	35	42 1/2	34	3/4	4 7/8	3 1/2	11 1/2	9 1/2	48	8	ADHT-160	NS	210340-25
180	39 1/2	35	42 1/2	38	3/4	4 7/8	3 1/2	11 1/2	9 1/2	54	8	ADHT-180	NS	210358-30
240	27 1/2	35	42 1/2	26	3/4	4 7/8	3 1/2	20	16 1/2	72	8	ADHT-240F	NS	210385-30
300	33 1/2	35	42 1/2	32	3/4	5 1/8	3 1/2	20	16 1/2	90	10	ADHT-300F	NS	210374-50

# High temperature air duct heaters (cont.)

## Application Guide

Selecting heater size. Refer to Technical Section for examples on determining KW requirements. For quick estimating purposes, the following formula may be used for standard conditions:

$$KW = CFM \times \text{temp. diff}/3000$$

Maximum work temperatures. Types ADH and ADHT process air heaters can generally be used at the following maximum temperatures shown, provided the minimum air velocity is maintained uniformly through the heater:

Air Velocity (ft/sec)	Max. Outlet Air Temp.*F	
	ADH	ADHT
4	800	1050
9	800	1100
16	800	1150
25	800	1200
35	800	1200

Application assistance. Chromalox sales/application engineers are available to assist you in the design or selection of equipment. Please contact your local Chromalox Sales Office if you need engineering assistance.

## Installation mounting tips

Low temperature duct heaters can be fastened directly to the sheet metal duct work with bolts or sheet metal screws.

High temperature duct heaters are generally mounted to a field fabricated stand off collar from the ductwork to position the heater such that the 3" insulation housing is in the same plane as the duct insulation.

All heaters can be mounted in any position; top, side or bottom (preferred) way. Minimum duct size is A or L dimension plus 3/4" and B dimension plus 1/4".

Provide adequate heater support. Consideration should be given to installing hangers or some other means of heater support whenever there is any question about the ability of the ductwork to support the heater weight.

Overtemperature protection. All heaters should include an overtemperature (overheat) control whose temperature sensing element is located on the air discharge side of the heater as close to the heater as practical. High temperature ADHT units include an overtemperature (Type K) thermocouple as standard.

Additional protection can be achieved by installing an air flow or pressure differential switch to protect the heater against low air flow conditions.

Operational controls. Selection of these controls, thermostat, SCR units, contactors and etc., depends on the degree of accuracy required, reliability, electrical rating of heater and economic considerations. Refer to Control Section.

Field power & control circuit wiring. Must be capable of carrying the electrical load and be protected by overcurrent protective devices, such as fusing, circuit breakers or ground fault detection in accordance with the requirements of the National Electrical Code and local codes as applicable.

Tandem mounting. Multiple heaters may be mounted in tandem with each other provided the maximum recommended outlet air temperature is not exceeded.

Pressure drop. Depends on the size of heater, its orientation with respect to air flow and the velocity of the air. Curve G-227-2 in Technical Section lists pressure drops for various heaters. Note, if pressure drop must be kept to a minimum, the heater should be mounted in the duct with the narrow width of the heater perpendicular to the air flow.

## Options available

Gas tight design. Achieved by the use of threaded compression fittings with fiber washers to attach heating elements to flange—prevents leakage of ducted air into terminal housing.

Overtemperature protection. Thermocouple welded to the element sheath surface and wired to a terminal block can be provided for accurate overheat protection. Standard on high temperature units.

Moisture or explosion-resistant terminal housings are available for those applications requiring special terminal protection.

Special ratings or sizes. Chromalox can custom fabricate a duct heater to your particular needs whether it be rating, physical size or other specifications.

Contact your local Chromalox representative for assistance.

# T/8 Technical information/calculation examples

## Examples for heating air/gases

### Heating air in ducts

**Problem:** A special drying process requires that we raise 450 cfm of air from 70° to 150°F. The existing ductwork which will be used for this purpose is insulated (negligible losses) and measures 2 ft. wide by 1 ft. high. Power available is 240 volts, 3 phase. Calculate the required kW and select a compatible heater for this application.

**Solution:** Under standard conditions air has a specific weight of .08 lbs./ft<sup>3</sup> and a specific heat value of .24 Btu/lb/°F.

To find heating capacity in kW

$$kW = \frac{W_T \times C_p \times \Delta T \times 1.2}{3412}$$

Where:

W<sub>T</sub> = Wt. of air/hr (450 x 60 x .08) = 2160

C<sub>p</sub> = Spec. heat of air (.24)

ΔT = Temp. rise °F (80)

3412 = BTU to kWh conversion (for air at other than standard conditions refer to page T/37.)

1.2 = Safety factor.

$$kW = \frac{2160 \times .24 \times 80 \times 1.2}{3412} = 14.85$$

For quick estimates, the following formula may be used where 3000 is a conversion factor in units of ft<sup>3</sup> —°F/min — kW.

$$kW = \frac{cfm \times temp. rise}{3000} = \frac{450 \times 80}{3000} = 12 \times 1.2 = 14.4$$

Or: When airflow (ft<sup>3</sup>/min) and temp. rise are known, curve G-176S (which shows 15 kW for this example) may be used. (This curve does not include contingency allowance).

### To select the heater.

In this application there are a few choices to be explored. First, consider Chromalox type CAB heaters. Knowing the application required, 15 kW leads us to select either the CAB-1511 with chrome steel elements or the CAB-152 with iron sheath elements rated at 26 W/in<sup>2</sup>. The maximum operating sheath temperatures are 750°F for iron and 950° for chrome steel.

Calculate air velocity through the heater to verify maximum operating sheath temperatures will not be exceeded.

$$V = \frac{F}{A \times 60}$$

Where:

V = Air velocity in ft/sec

F = Air flow in ft<sup>3</sup>/min (450 cfm)

A = Area of hir. (15<sup>1</sup>/<sub>8</sub>" x 21<sup>1</sup>/<sub>8</sub>" = 2.3 ft<sup>2</sup>)

$$V = \frac{450}{2.3 \times 60} = 3.3 \text{ ft/sec.}$$

Using curve G107S, page T/23, based on an outlet temperature of 150°F and a watt density of 26 W/in<sup>2</sup>, a velocity in excess of 9 ft/sec is required to keep the sheath temperature at permissible levels for the CAB-152. This is well above the actual velocity and rules out the use of the CAB-152. By applying the watt density and outlet air temperature to curve G106S we see that we need a minimum of approximately 3 ft/sec air velocity to maintain a maximum of 900°F sheath temperature. Since this is lower than actual velocity, the use of CAB-1511 is acceptable.\*

\*Use of CAB-1511 will require a transition in the existing ductwork to accommodate the heater.

An alternative method to be considered would be mounting banks of Finstrip<sup>®</sup> heating elements in the ductwork. Knowing that 15 kW is required and that our duct measures 2 ft. wide x 1 ft. high and that a chrome steel sheath is required, we can select the proper Finstrip.

Using curve G108S, the maximum allowable watt density is 26 W/in<sup>2</sup>. Elements with watt densities of 26 W/in<sup>2</sup> or less are suitable. Since the duct is 2 ft. wide, consider using OTF-210, 21 inches long, 240 volts, 1250 watts at 21 W/in<sup>2</sup>.

$$\begin{aligned} \text{No. finstrips reqd.} &= \frac{\text{Operating watts}}{\text{Rated W/elem.}} \\ &= \frac{15,000}{1250} \\ &= 12 \text{ Finstrips} \end{aligned}$$

Use 12 OTF-210 Finstrips mounted sideways with narrow edge facing air-stream. Total number of elements installed must be divisible by 3 so they can be connected in a 3 phase delta circuit.

### For heating air ducts with tubular elements in a recirculating oven set at 975°F

Heating air in ducts may be accomplished by using standard tubular elements or by using packaged heater assemblies such as Type ADH.

Steel sheath may be used where the sheath temperature will not exceed 750°F; alloy sheath may be used for sheath temperatures up to 1600°F. Allowable watt densities should be determined by reference to curves G-151-1 through G-156-1, pg. T/24.

As an example, suppose it was determined that approaching air temperatures were to be 975°F at 4 ft/sec air velocity. The temperature is above 750°F so alloy sheath must be used. Using curve G-152-1 allowable watt densities would be 11 W/in<sup>2</sup> for a sheath temperature of 1200°F or 22 W/in<sup>2</sup> for a temperature of 1400°F. A standard ADH heater of proper kW rating, with 22 W/in<sup>2</sup> on the sheath, could be used.

Special ADH duct heaters, derated in direct proportion to the watt densities, could be used where operating conditions require use of element ratings less than the standard 22 W/in<sup>2</sup>.

# Examples for heating air/gases

## Oven heating

**Problem:** An oven with inside dimensions of 2 ft. H x 3 ft. W x 4 ft. D maintained at 350°F contains a steel tray weighing 40 lbs. This oven is charged with 250 lb. of steel parts which are to be raised from 70°F to 350°F in 34 hour. Oven has 2 inches of wall insulation with 400 ft³ per hour of air ventilation. What kW capacity is required?

Weight of steel = 290 lbs.  
 Specific heat of steel = .12 Btu/lb/°F  
 Weight of air = .080 lb/ft³ at 70°F  
 Specific heat of air = .24 Btu/lb/°F  
 Temperature rise = 280°F  
 Heat loss/2 in. insul. = 18 W/h²/hr @ 280°F temp. difference (curve G-126S), page T/22.  
 Surface area/oven = 52 ft²  
 Time = 34 hr.  
 Airflow rate = 400 ft³/hr.  
 For oven applications add 30% to cover door losses and contingencies.

### Solution:

1. Calculate kWh required to heat model.

$$kWh = \frac{W_T \times C_p \times \Delta T}{3412} = 2.86$$

Where:

- $W_T$  = Wt. steel/lbs (290)
- $C_p$  = Spec. ht. stl. (.12)
- $\Delta T$  = Temp rise/°F (280)

2. Calculate kWh required to heat ventilated air

$$kWh = \frac{A_F \times H \times A_{WT} \times C_p \times \Delta T}{3412} = .47$$

Where:

- $A_{WT}$  = Wt. of air (.080)
- $C_p$  = Spec. ht. air (.24)
- $\Delta T$  = Temp. rise (280)
- $H$  = Time/hr (.75)
- $A_F$  = Air flow rate (400)

3. Calculate surface losses

$$kWh = \frac{F \times E \times X \times H}{1000} = .70$$

Where:

- $E$  = Heat loss W/ft²/hr (18)
- $F$  = Surface area ft² (52)
- $H$  = Time/hr (.75)

4. Combine steps 1, 2 and 3.

$$kWh = 2.86 + .47 + .70 = 4.03$$

$$kW = \frac{kWh}{H} = \frac{4.03}{.75} = 5.37$$

For oven applications, add 30% to cover door losses and contingencies. Therefore: required kW = 5.37 x 1.30 = 6.98 kW.

To select the heater Chromalox type OV oven heaters would be suitable for this application. In this case you would use 2 standard OV-38 units rated at 3800 watts each.

## Heating rooms

Although a complete analysis should be performed for room heating using the NOMA handbook or the ASHRAE guide, quick estimates of the kW capacity can be obtained using the following procedure.

**Problem:** A warehouse room measures 20 ft. long x 13 ft. wide x 9 ft. high. The building is poorly constructed and consists of corrugated metal sides with a plywood and tar paper roof. Determine the kW capacity required to maintain the warehouse at 70°F while the outside temperature is 0°F.

### Solution:


1. Calculate the volume of the room. 20 x 13 x 9 = 2,340 ft³.

2. Refer to the curve chart shown. Use curve 4 which corresponds to the designated conditions.

3. If the volume of the room is larger than the chart values divide by 2, 3, 4 etc. until the trial volume fits the curve. (Does not apply in this case.) Then select heater from this volume. Multiply heaters selected by the number used to select the trial volume.

and intersection of 2340 ft³ with curve 4.  
 In this we can see that 9.3 kW is required. Select a 10 kW unit blower heater.

Heater selection: Depending on requirements, types UB, LUH or VUH heaters would be suitable for this application.



W320-28-006

Equipment Sizing & Selection  
Recirculation Condenser



## DESIGN ANALYSIS

Client Westinghouse  
Subject Equipment Sizing & Selection,  
Recirculation Condenser  
Location

WO/Job No. ER 4319  
Date 04-06-94 By Charles O'Neill  
Checked 5/27/94 By *K. Reynolds*  
Revised By

**OBJECTIVE:** The objective of this analysis is to make a rough check of vendor proposals and to recommend a condenser for use in the W-320 tank ventilation system.

### DESIGN INPUTS:

#### Criteria and Sources:

- 1.) Functional Design Criteria WHC-SD-W320-FDC-001 Rev 2.
- 2.) LOI 9359770 Rev 4.

#### Given or Known Data:

- 1.) 235,080 BTU/HR to be removed, from H-2-818479.
- 2.) Air inlet temperature - 95°F, saturated, from H-2-818479.
- 3.) Air outlet temperature - 40° F, saturated, from H-2-818479.
- 4.) Air flow 1090 ACFM @ 70° F, from H-2-818479.
- 5.) Air stream is supersaturated with 100 mg/m<sup>3</sup> of aerosols. The aerosol is composed of 10% solids and 90% liquids. The liquid portion is composed of 80% water and 20% solids in solution. All aerosols are less than 10µm in size, from LOI 9359770 Rev 4.
- 6.) Cooling fluid - 46% Propylene Glycol/Water Solution, from W320-H-007.
- 7.) Condenser will be skid mounted and located <sup>indoors</sup> ~~outdoors~~. *TR*
- 8.) HVAC overall flow diagram as shown on H-2-818470.

#### Methods to be Used:

Standard heat transfer and psychometric equations.

#### References/Sources:

- 1.) ASHRAE Handbook of Fundamentals, 1993.

Client: Westinghouse Hanford Company WO/Job No. ER4319  
 Subject: Equip. Sizing & Selection, Recirc. Conder Date 04-06-94 By Charles O'Neill  
 Selection Checked 5/27/94 By K. Meyers  
 Location: \_\_\_\_\_ Revised \_\_\_\_\_ By \_\_\_\_\_

CALCULATION

EXHAUST AIR STREAM

Inlet Conditions  
95° F Saturated

$$\rho_a = 0.072 \frac{\text{lb}_a}{\text{ft}^3}$$

Defining variables  
for Mathcad

$\text{lb}_a := \text{lb}$   
 $F := R - 460\text{-R}$   
 $\text{Btu} := 778.17\text{-ft}\cdot\text{lb}$

$$C_p = 0.24 \frac{\text{Btu}}{(\text{lb}\cdot\text{F})}$$

$\text{lb}_w := \text{lb}$

$$q_a = 1220 \frac{\text{ft}^3}{\text{min}} \quad \text{Maximum flow rate}$$

$$W_1 = 0.036 \frac{\text{lb}_w}{\text{lb}_a}$$

$$h_{s1} = 63.3 \frac{\text{Btu}}{\text{lb}_a}$$

Outlet Conditions  
40° F Saturated

$$W_2 = 0.0052 \frac{\text{lb}_w}{\text{lb}_a}$$

$$h_{s2} = 15.2 \frac{\text{Btu}}{\text{lb}_a}$$

PROPYLENE GLYCOL/WATER SOLUTION 46 % , 33 ° F

ASHRAE FUNDAMENTALS  
HANDBOOK 1993

$$\rho_s = 65.5 \frac{\text{lb}}{\text{ft}^3}$$

$$C_{ps} = 0.845 \frac{\text{Btu}}{\text{lb}\cdot\text{F}}$$

$$\Delta T = 5\text{-F}$$

Maximum temperature rise allowed. Exchanger Data Sheet

Client: Westinghouse Hanford Company WO/Job No. ER4319  
 Subject: Equip. Sizing & Selection, Recirc. Conde Date 04-06-94 By Charles O'Neill  
 Selection Checked 5/27/94 By K. Meynuk  
 Location: Revised By

CALCULATION:

Exhaust Air

Mass flow rate of exhaust  $m_a = q_a \rho \cdot 60 \frac{\text{min}}{\text{hr}}$   $m_a = 5.27 \cdot 10^3 \cdot \frac{\text{lb}_a}{\text{hr}}$

Heat Transfer  $Q = m_a (h_{s1} - h_{s2})$   $Q = 2.535 \cdot 10^5 \cdot \frac{\text{Btu}}{\text{hr}}$

Water Condensed  $\text{LB}_{\text{h.2o}} = m_a (W_1 - W_2)$   $\text{LB}_{\text{h.2o}} = 162.328 \cdot \frac{\text{lb}_w}{\text{hr}}$

Propylene Glycol

Heat Transferred to Glycol  $Q_g = Q$   $Q_g = 2.535 \cdot 10^5 \cdot \frac{\text{Btu}}{\text{hr}}$

Glycol Flow Rate  $M_g = \frac{Q_g}{\Delta T \cdot C_{ps}}$   $M_g = 6 \cdot 10^4 \cdot \frac{\text{lb}}{\text{hr}}$

$\text{GPM} = \frac{M_g}{\rho_s} \cdot 7.48 \frac{\text{gal}}{\text{ft}^3} \frac{\text{hr}}{60 \cdot \text{min}}$   $\text{GPM} = 114.201 \cdot \frac{\text{gal}}{\text{min}}$

## DESIGN ANALYSIS

Client Westinghouse  
Subject Equipment Sizing & Selection,  
Recirculation Condenser

WO/Job No. ER 4319

Date 04-06-94

Checked *SJZ/94*

Revised

By Charles O'Neill

By *K. Maynard*

By

Location

### ANALYSIS:

The proceeding calculations provide values to make a reasonable check of vendor proposals.

The design and manufacture of heat exchangers is a well developed process that is beyond this analysis. The ability of a shell and tube or a spiral heat exchanger to achieve the desired results is not in question. Instead this discussion will examine how the differences in design of shell and tube and spiral heat exchangers impact the W-320 ventilation system.

The air stream entering the heat exchanger is expected to be super saturated at 95°F. The heat exchanger is to be designed to lower the exiting air stream to 40°F saturated. Both heat exchangers as proposed will meet these conditions.

### SHELL AND TUBE

The shell and tube heat exchanger is a four pass, U-tube unit with the air on the shell side. Air inlet and outlet flanges are mounted vertically on the top with a condensate drain on the bottom. The total length of the exchanger is 102 inches and the diameter is 23 inches including flanges.

#### Sealing

The shell and tube exchanger employs a fixed tubesheet at one end of the exchanger. The tubes are rolled into the sheet. This is a standard design and there is no reason to expect leaks at the tubes if the tube bundle is assembled properly.

#### Drainage/Contamination

The shell and tube exchanger will condense three tenths of a gallon per minute per the data sheet. The condensate will drain through a 3/4 inch outlet on the bottom of the shell. Inside the shell the tubes are supported by baffles that also act to direct the air across the tube bundle. These baffles will have a V notch at the bottom of the shell to allow the condensate to pass to the drain. The condenser can be sloped to promote condensate flow to the drain.

The joint where the tubes are rolled into the tubesheet is a likely spot for contamination to become lodged. Tight quality control will minimize gaps between the tubes and the tubesheet, but cannot eliminate them.

#### Cleaning/Decontamination

Fouling on the inside of the tubes is not a big concern. An inhibited glycol solution at these temperatures will not plate out on the inside of the tubes. The shell side may see some deposits from the insoluble

**DESIGN ANALYSIS**Client Westinghouse  
Subject Equipment Sizing & Selection,  
Recirculation Condenser  
LocationWO/Job No. ER 4319  
Date 04-06-94  
Checked *SPZ/94*  
RevisedBy Charles O'Neill  
By *K. Meyers*  
By

particles that are not washed from the exchanger by the condensate. Chemical cleaning will be required to remove any deposits on the shell side.

Decontamination of the shell and tube exchanger at completion of W-320 would probably be accomplished by chemically flushing the inside of the shell with a nitric acid solution. The tube bundle would have to be pulled to remove any remaining contamination.

**Layout**

The shell and Tube heat exchanger will require 13 sq. ft. of floor space. The ventilation skid layout provides adequate space for the shell and tube heat exchanger. The current layout would allow the exchanger to be mounted above the air heater while still providing room for removing the heater. The location of the air inlet on the top of the unit permits sloping the air duct down towards the tank for drainage of condensate back to the tank.

**Cost**

The cost of the shell and tube exchanger is \$13,600. The vendor making this proposal is well known name in this field so this price is probably a good indicator of what a quality piece of equipment will cost.

**SPIRAL**

The spiral type heat exchanger consists of two sheets of stainless steel that are welded together at one end and then wound into a spiral with a fixed gap between the sheets. The sides of the spiraled sheets are then welded together in such a way as to form two separate channels. The spiral is installed inside a housing and end plates are fitted to each side to seal the channels.

The heat exchanger will be mounted with the spiral in the vertical axis. The air inlet would be on the bottom at the center and the air would spiral outward. The coolant would enter at the side of the housing and spiral inward and leave from the top at the center.

The total size of the unit is 45 inches in diameter and 88 inches tall. It will take 16 sq. ft. of floor space.

**Sealing**

The two channels are sealed from each other by welding the edges of the sheets at each end. The end plates utilize a full face gasket to prevent short circuiting of the fluids. The gasket material can be chosen to meet service conditions.

**Drainage/Contamination**HNF-2483, Rev. 0  
Page E-6

## DESIGN ANALYSIS

Client Westinghouse  
Subject Equipment Sizing & Selection,  
Recirculation Condenser

WO/Job No. ER 4319

Date 04-06-94

Checked *SJZ/af*

Revised

By Charles O'Neill

By *L. Mayne*

By

Location

The spiral heat exchanger will condense four tenths of a gallon per minute per the data sheet. The condensate will drain through a two inch outlet on the bottom end plate. As the condensate forms it falls to the bottom of the exchanger and is pushed outward through the spiral to the drain by the air flow. The spiral exchanger cannot be sloped like the shell and tube to promote drainage.

The welded joint formed at each end of the channels provides a crack for radioactive material to enter. This problem will be minimized because the joint is located at the top of the air channel during fabrication.

### Cleaning/Decontamination

Fouling of the coolant channel is not a concern. The air side channel may see some deposits from the insoluble particles that are not washed from the exchanger by the condensate. Chemical cleaning will be required to remove any deposits on the air side during operation.

Decontamination of the spiral exchanger would be accomplished by chemically washing with a nitric acid solution. If additional cleaning is required the end plates can be removed which exposes both channels for mechanical methods.

### Layout

The major benefit of the spiral exchanger in this application is its compact size. However, the spiral heat exchanger requires the same floor space as the shell and tube unit. The spiral exchanger does not provide any benefits to the layout.

### Cost

The cost of the proposed spiral exchanger is \$38,000. This is twice the cost of the shell and tube. The cost may drop when other vendors are contacted but the spiral exchanger will probably still be more expensive than a shell and tube.

## CONCLUSION

The shell and tube heat exchanger is the preferred choice for this application. The compact size of the spiral exchanger does not affect the size of the ventilation skid which is its major benefit. The shell and tube exchanger can be mounted to promote drainage and the nozzle orientation allows the inlet piping to be sloped to drain back to the tank.

HNF-2483, Rev. 0  
Page E-7

W320-28-007

Chiller Skid System Sizing and  
Selection



<b>ICF KAISER ENGINEERS</b>		<b>DESIGN CALCULATION INDEX</b>				CALC. NO.	SHT. NO.
						HW-1	0
JOB NUMBER	B7059-553	AREA OR BUILDING	CALCULATION DESCRIPTION			DISCIPLINE	
JOB TITLE	TK-241-C-106 HVAC-RECIRC. COND. C.S.		PUMPS & EXPANSION TANKS			HVAC	
CALCULATIONS APPLY TO DRAWINGS AND REVISIONS SHOWN:							
DRAWING	REV.	DRAWING	REV.	DRAWING	REV.	DRAWING	REV.
DESIGN ENGINEER	3/15/94			DISCIPLINE SUPERVISOR			
(SIGNATURE)				(SIGNATURE)			
CALCULATIONS CHECKED				CHIEF DISCIPLINE ENGINEER/CHIEF ARCHITECT			
(SIGNATURE)				(SIGNATURE)			
CALCULATIONS AGREE WITH DESIGN CRITERIA				CALCULATIONS AGREE WITH APPVD. VENDOR DRAWINGS			
(SIGNATURE)				(SIGNATURE)			
CALCULATION REVS.	△	DATES	△	DATES	△	DATES	△
REVISION DESCRIPTION							
DESIGN ENGINEER							
CHECKED	K. M. [Signature]						
CDS							
STATUS:	PRELIMINARY	FINAL	CHECK	VOID	HOLD	OTHER	
REASON FOR VOID OR HOLD:							
INDEX				DESCRIPTION			
SHEET NO.							
1-1	REFERENCES						
2-2	COOLANT FLOW						
3-4	PIPE LOSS, 3"Ø PIPE						
5-7	PIPE LOSS, 4"Ø PIPE						
8-9	PUMP CALCULATIONS						
10-11	PRICE COMPARISON & ENERGY SAVINGS						
12-13	EXPANSION TANK SIZING						
14	EXPANSION LOOP						
15-23	REFERENCE DATA						
24-34	VENDORS DATA						

TK 241-C-106

HWK - RECIRC. COND. COOLING SYS.

DESIGNED BY *[Signature]*

DATE 3/1

CHECKED BY *[Signature]*

DATE 5/11/94

## REFERENCES:

1. PETER LANGOWSKI MEMO, DATED: 1/7/94
2. DOW CHEMICAL DATAS, DOWFROST HD
3. CRANE FLOW OF FLUIDS: LOSSES THROUGH FITTINGS  $\rightarrow$  VALVES

GIVEN: FROM REF. 1 : HEAT LOAD = 250,000 BTUH

2. FROM P. LANGOWSKI " (4/4/94)  
CONDENSER LOSSES = 14751

3. FROM FEB. 18 MEETING AT  
RICHLAND WA. USE GLYCOL  
SOLUTION FOR -20°F AMBIENT  
TEMP.  $\approx$  46% GLYCOL

4. USE LIQUID TEMP. = 31°F

5. FROM DOW CHEMICAL DATA SHEET

a. DENSITY OF 46% PROPYLENE  
GLYCOL = 66.57 #S/FT<sup>3</sup>  
SPECIFIC HEAT = 0.811 - BTU/#FT

TK 241-C-106

HVAC - RECIRC. COND. COOLING SYS.

DESIGNED BY

DATE 3/1/5

CHECKED BY

DATE 5/1/9

TO DETERMINE COOLANT FLOW

$$Q = W C_p \Delta T$$

WHERE:  $Q = 250,000 \text{ BTUH}$

$W = \#/HR$

$C_p = \text{SPECIFIC HEAT} = 0.811 \text{ }^*$

$\Delta T = 36.31 = 5^\circ F$

$$W = \frac{Q}{C_p \Delta T}$$

$$= \frac{250,000 \frac{\text{BTU}}{\text{HR}} \times 7.48 \frac{\text{Gals}}{\text{FT}^3}}{66.57 \frac{\text{#}}{\text{FT}^3} \times 0.811 \frac{\text{BTU}}{\text{#} \cdot ^\circ F} \times 5^\circ F \times 60 \frac{\text{min}}{\text{HR}}}$$

$= 115 \text{ GPM}$

\* HEAT EXCHANGER CAPACITY AT 14 PSI  
PRESSURE DROP = 110 GPM (PER PETER  
LANGOUSKY 4/4/74)

USE 110 GPM

$$\Delta T = \frac{250,000 \times 7.48}{66.57 \times 0.811 \times 110 \times 60} = 5.24^\circ F \text{ } \Delta T$$

\* REF. 2

TK 241-C-106

DESIGNED BY 10

DATE

3-18-94

3" B PIPE

CHECKED BY K. Muehle

DATE

5/11/94

TO DETERMINE PIPE LOSS THRU 3" B PIPE

1. GATE VALVE

$$L/D = 13, \text{ FOR 7 VALVE} = \frac{3}{12} \times 13 \times 7 = 23$$

2. BUTTERFLY VALVE:  $\frac{L}{D} = 40$

$$\text{FOR 4 BUTTERFLY VALVE} = 4 \times \frac{3}{12} \times 40 = 40$$

3. ANGLE VALVE

$$\frac{L}{D} = 145; L = \frac{3}{12} \times 145 = 36$$

4. CHECK VALVE

$$\frac{L}{D} = 135; L = \frac{3}{12} \times 135 = 34$$

5. 45° ELBOWS:

$$\frac{L}{D} = 16; \text{ FOR 12 EL} = 12 \times \frac{3}{12} \times 16 = 48$$

6. FOR 90° ELBOWS

$$\frac{L}{D} = 20 \text{ FOR 30 EL} = 30 \times \frac{3}{12} \times 20 = 150$$

7. AIR SEPARATOR

FROM B & G CAT. (w/o STRAINER) = 9 elbows

$$= \frac{3}{12} \times 9 \times 20 = 45$$

SUB-TOTAL 376

B PIPE LENGTH

638

TOTAL PIPE LENGTH

1014 FT

TK 241-C-108

DESIGNED BY *[Signature]*

DATE

3-28-9

3" PIPE

CHECKED BY *[Signature]*

DATE 5/1/9

FROM DOWS DATA, REYNOLDS #,  $Re = 7757$   
FROM CRANE

FROM CRANE FLOW OF FLUID PAGE A-23  
RELATIVE ROUGHNESS  $e/D$  FOR 3" PIPE = .0006

FOR  $Re = 7757$  &  $e/D = .0006$

$$f = .033$$

$$h_L = f \left( \frac{L}{D} \right) \left( \frac{V^2}{2G} \right)$$

where:

$h_L$  = pipe loss, FT

$f$  = friction factor = .033

$L$  = pipe equivalent length = 1014 FT

$D$  = diameter (FT) =  $\frac{3}{12}$

$V^2$  = velocity, ft/sec (3" @ 110 Gpm) = 4.77

$G$  = 32.2

$$h_L = 0.033 \left( \frac{1014}{\frac{3}{12}} \right) \left( \frac{4.77^2}{2 \times 32.2} \right)$$

$$= 47.28$$

TK 241-C-106  
HVAC - RECIRC. COND. COOLING SYS  
4" PIPE

DESIGNED BY LS DATE 3/1/92  
CHECKED BY L. Meyers DATE 5/11/92

- II TO DETERMINE PUMP HEAD USING 4" PIPE
- 1 FROM REF. 1 TOTAL LENGTH OF PIPE = 638
  2. # NO OF ELBOWS:
    - 45° \_\_\_\_\_ 12
    - 90° \_\_\_\_\_ 16
  3. ADD'L ELBOWS FOR EXPN 8  
 ADD'L ELBOWS AT SKID = 6  
 TOTAL 90° EL - 30
  4. TEES \_\_\_\_\_ 1

FROM CRANE FLOW OF FLUID:  
PAGE A-30, EQUIVALENT  
LENGTH OF FITTINGS:

- GATE VALVES:  $\frac{L}{D} = 13$
- BUTTERFLY VALVES  $\frac{L}{D} = 40$
- ANGLE VALVE  $\frac{L}{D} = 145$
- CHECK VALVES =  $\frac{L}{D} = 135$
- 4" - 45° EL =  $\frac{L}{D} = 16$
- 4" - 90° EL :  $\frac{L}{D} = 20$

CALCULATIONS RE Form No. E-6 Rev. 12-89

TIC 241-C-106

HVAC - RECIRC. COND. COOLING SYS.

4" pipe

DESIGNED BY *[Signature]*

DATE 3/1/93

CHECKED BY *[Signature]*

DATE 5/11/93

EQUIVALENT LENGTH:

1. GATE VALVE (FROM PAID, 7 GATE VALVES)

$$\frac{L}{D} = 13 \text{ FOR } 7^{\circ} \text{ L} = \frac{4 \times 13}{12} \times 7 = 30.33$$

2. BUTTERFLY VALVES

$$\frac{L}{D} = 40 ; \text{ FOR } 4 \text{ B.V.} = \frac{4 \times 40}{12} \times 4 = 53.33$$

3. ANGLE VALVE

$$\frac{L}{D} = 145 ; \text{ L} = \frac{4}{12} \times 145 = 48.33$$

4. CHECK VALVE

$$\frac{L}{D} = 135 ; \text{ L} = \frac{4}{12} \times 135 = 45.0$$

5. 45° ELBOWS

$$\frac{L}{D} = 16 ; \text{ FOR } 12 \text{ EL} ; \text{ L} = \frac{4}{12} \times 16 \times 12 = 64$$

6. 90° ELBOWS

$$\frac{L}{D} = 20 ; \text{ FOR } 30 \text{ EL} = \frac{4}{12} \times 20 \times 30 = 200$$

7. AIR SEPARATOR

FROM B&G CAT. (w/o STRAINER) = 9 ELBOWS

$$= 9 \times \frac{4}{12} \times 20 = 60$$

SUB-TOTAL

504.00

8. TOTAL PIPE LENGTH

638

1139

TK. 241-C-106

DESIGNED BY *man*

DATE 3/11/9

HWC - REGR. COND. COOLING SPS

CHECKED BY *K. Maguire*

DATE 5/11/9

4" PIPE

FROM DOWS DATA, REYNOLDS # 6445

FROM CRANE FLOW OF FLUID, PAGE A-23

RELATIVE ROUGHNESS FOR 4" STEEL PIPE = .00045

FROM A-24, FOR  $Re = 5911 \frac{1}{2}$  REL.

ROUGHNESS = .00045, FRICTION FACTOR = .035

FROM CRANE FLOW OF FLUIDS PAGE 3-4

$$h_L = f \left( \frac{L}{D} \right) \frac{V^2}{2g}$$

where:  $f = .035$  $L = 1139 \text{ FT}$  $D = \text{INTERNAL DIA. IN FEET}$  $V = \text{VELOCITY, FT/SEC}$  $G = 32.2 \text{ FT}^2/\text{SEC}^2$  $h_L = \text{head loss, FT}$ 

$$h_L = 0.035 \frac{(1139 \text{ FT}) \left( \frac{(2.77)^2 \text{ FT}^2}{\text{SEC}^2} \right)}{\left( \frac{4.026 \text{ FT}}{12} \right) \cdot 2 \times 32.2 \frac{\text{FT}}{\text{SEC}^2}}$$


$$= 0.035 \times \frac{1139}{0.3355} \times .1416 = 14.15$$

JK 241-C-106

SIGNED BY [Signature] DATE 3-28-  
CHECKED BY [Signature] DATE 1/11/9

COMPARISON OF PUMP HEAD

	3"φ	4"φ
1. PIPE, VALVES, SEPARATOR LOSS	47.28	14.15
2 CHILLER LOSS = 25FT x 1.46	36.5	36.5
3. CONDENSER LOSS 14 x $\frac{144}{66.57}$	30.28	30.28
4. STRAINER = .18 $\frac{\#}{in^2}$ x 1.46 x 2.31 (CLEAN)	.60	.60
5 CONTROL VALVE = 10 $\frac{\#}{in^2}$ x $\frac{144}{66.57}$	21.63	21.63
	136.29	103.16
10% FS	13.3	10.3
	149.59	113.46
$HP = \frac{GPM \times HD \times Sp. Gr.}{3960 \times EFF.}$ $EFF_{3"} = 56\%$ $EFF_4 = 58\%$ $HP_{3"} = \frac{110 \times 149.59 \times \frac{66.57}{62.4}}{3960 \times .53} = 28.32$ <p>USE — 31 HP</p> $HP_{4"} = \frac{110 \times 113.46 \times \frac{66.57}{62.4}}{3960 \times .53} = 6.34$ <p>USE 7 1/2 HP</p>		



METERS 0 5 10 15  
 FEET 0 5 10 15  
 U.S. GPM 0 25 50 100 150 200 250 300  
 CU. METERS/HR. 0 10 20 30 40 50 60 70

PRICE COMPARISON  
3" PIPE VS 4" PIPE

DESIGNED BY LA DATE 1/4/99  
CHECKED BY L. Muzik DATE 5/11/98

PRICE COMPARISON 3" PIPE VS 4" PIPE	PIPE SIZE	
	3"	4"
1. PIPE, RICKWILL 2.24 THICK INSULATION 638 FT @ \$ 17.00/FT 638 FT @ 20.75/FT	10,846	13,239
2. PUMPS 120 GPM, 150 FT, 10HP 2 @ \$ 6000 120 GPM, 105 FT 7.5HP 2 @ \$ 5,500	12,000	11,100
3. GATE VALVES 7 @ \$ 155 7 @ \$ 225	1085	1575
4. CHECK VALVE 2 @ \$ 125, 2 @ \$ 195	250	390
5. ELBOWS 30 @ \$ 11 30 @ \$ 17	330	510
	24,511	26,814

PRICE DIFF = 26,814 - 24,511 = \$ 2,303

CALCULATIONS KE Form No. E-6 Rev. 12-89

TK 241-C-106

DESIGNED BY \_\_\_\_\_ DATE \_\_\_\_\_

PIPE SIZE SELECTION

CHECKED BY *L. Maguire* DATE 5/1/88

ENERGY SAVINGS:

DIFFERENCE IN PUMP HP:

$$HP_3'' - HP_4'' = 8.36 - 6.34 = 2.02$$

AT \$.055/yr kw-h

$$\begin{aligned} \text{SAVINGS/yr} &= .055 \times 2.02 \text{ HP} \times .746 \frac{\text{KW}}{\text{HP}} \times 24 \frac{\text{HRS}}{\text{day}} \times 365 \frac{\text{day}}{\text{yr}} \\ &= \$726. \sim \end{aligned}$$

$$\text{PAYBACK PERIOD} = \frac{\$2303}{\$726/\text{yr}} = 3.1 \text{ years}$$

YEARS OF OPERATION = 2

USE: 3"  $\phi$  PIPE

10 HP MOTOR PUMP

TK 241-C-106  
RAC. RECIRC. COND. COOLING SYS.

DESIGNED BY me DATE 3/1/90  
CHECKED BY L. Megard DATE 5/1/90

TO SIZE EXPANSION TANK

1. PIPE LENGTH- 638 FT (REF. D)  
SIZE 4"φ

$$VOLUME = \frac{\pi D^2}{4 \times 144} \times 638$$

$$= \frac{\pi (4)^2}{4 \times 144} \times 638 = 56 \text{ cuft}$$

$$GALLONS = 56 \text{ cuft} \times \frac{7.5 \text{ GALS}}{\text{cuft}} = 420 \text{ GALLONS}$$

2. CHILLER 14 GALS.

3. CONDENSER 14 GALS

448 GALS.

450 GALS.

RELATIVE ELEVATION OF SYSTEM

$$\text{AND PUMP} = 646 - 633 = 13' - 0' =$$

$$= 13 \times \frac{66.57}{144} = 6 \text{ PSI}$$

PRESSURIZED TANK SIZING WORKSHEET

FIGURE 2

THINGS YOU MUST KNOW:

LINE	ITEM	Symbol	Reference Table Formula	ANSWER
1.	Total System Water Content	Vs	B, C, D	<u>450s</u> Gal.
2.	Average Design Water Temperature	t	-	<u>325</u> ° F.
3.	Minimum Fill Pressure (Pre-charge) <u>6.8</u> psig (Static) + <u>4</u> psig (top of sys)	Pf	A	<u>70</u> psig
4.	Maximum Operating Pressure	Po	-	<u>75</u> psig
5.	Tank Mounting	-	-	Horiz. <input checked="" type="checkbox"/> Vert.

TANK SIZING AND SELECTION

6.	Net Water Expansion Factor	-	F	<u>1.004</u>
7.	Correction Factor, if Glycol	-	E	<u>1.8</u> , Water = 1
8.	Expansion Volume, Multiply Line (1) <u>450</u> x (6) <u>.004</u> x (7) <u>1.8</u>	Ve	-	<u>3.24</u> Gal.
9.	Acceptance Factor	Ae	G	<u>0.725</u>
10.	Minimum Tank Volume, Divide Line (8) <u>3.24</u> ÷ by (9) <u>.725</u>	Vt -	(6) H	<u>2.35</u> Gal.
11.	Select Tank - See Line (5) Select Tank with Tank and Acceptance Volumes Equal or Greater Than Answers in Line (8) and (10).			
12.	Selection #1 :	Model <u>Sx-30V</u> , Size <u>16</u> (Gal.), Ac <u>6</u> Gal.		
12A.	Alternate Selection: Model _____, Size _____ (Gal.), Ac _____ Gal.			
	With Two Tanks: Model _____, Size _____ (Gal.), Ac _____ Gal.			
	TOTAL:			

JOB NAME \_\_\_\_\_  
 LOCATION \_\_\_\_\_  
 ENGINEER \_\_\_\_\_  
 CONTRACTOR \_\_\_\_\_  
 SALES REPRESENTATIVE \_\_\_\_\_  
 DATE \_\_\_\_\_

HNF-2483, Rev. 0  
 Page F-15

TK 241-C-106

DESIGNED BY *le*

DATE 5-5-79

PIPE EXPANSION

CHECKED BY *le-Meyers*

DATE 5/11/79

ASSUME INSTALLATION TEMPERATURE OF  
PIPE = 85°F

WATER TEMP. = 31°F

$\Delta T = 85 - 31 = 54^\circ F$

FROM RICKWIL CAT. (CAT. PAGE 16-E),  
SEE PAGE 22, PIPE THERMAL EXPANSION  
FOR 54°F  $\Delta T$  IS CALCULATED AS  
FOLLOWS:

TABLE TEMP BASE IS -20°F  
THEREFORE USE THERMAL EXPANSION FOR  
TEMPERATURE = 54 - 20 = 34°F.

BY INTERPOLATION,

THERMAL EXPANSION = 0.389 inch/100 FT

PER PETE LANGOWSKI MEMO 1/7/94,

PIPE LENGTH = 279 FT.

NO. OF ELBOWS = 14

THERMAL EXPANSION FOR 279 FT =

$$279' \times \frac{.389''}{100'} = 1.08''$$

PIPE EXPANSION IS MINIMAL AND  
CAN BE HANDLED BY SYSTEM ELBOWS.

IF PIPING LOOP WILL BE USED, THE  
EXPANSION LOOP DIMENSION PER RICKWIL  
CAT. PAGE 18-E:

$$2H + W = 9.5' \quad \text{WHERE: } W = \frac{H}{2}$$

$$2H + \frac{H}{2} = 9.5; \quad H = 4.3 \quad W = 2$$

Heat Transfer Coefficient and Pressure Drop  
DOWFROST HD Fluid (61.5 % Solution)  
(At 46.3 Percent Weight Glycol)

Flow Rate: 4.77 feet/second	Density: 66.57 lb/ft <sup>3</sup>
Temperature: 31.0 F	Specific Heat: 0.811 Btu/lb-F
Pipe or tube size: 3.068 inches	Thermal Conductivity: 0.2095 Btu/hr-ft-F
	Vapor Pressure: 0.08 psia
	Viscosity: 37.77 lb/hr-ft
	Prandtl No: 146.1
	Reynolds No: 7,757

The correlation for film coefficient is not valid for  $Re < 10,000$ .

RETURN	ESC	M	PrtSc	Q
Next	Prior	Main	Print	Quit
Menu	Screen	Menu	Screen	Now

Heat Transfer Coefficient and Pressure Drop  
DOWFROST HD Fluid (61.5 % Solution)  
(At 46.3 Percent Weight Glycol)

Flow Rate: 2.77 feet/second	Density: 66.57 lb/ft <sup>3</sup>
Temperature: 31.0 F	Specific Heat: 0.811 Btu/lb-F
Pipe or tube size: 4.026 inches	Thermal Conductivity: 0.2095 Btu/hr-ft-F
	Vapor Pressure: 0.08 psia
	Viscosity: 37.77 lb/hr-ft
	Prandtl No: 146.1
	Reynolds No: 5,911

The correlation for film coefficient is not valid for  $Re < 10,000$ .

RETURN	ESC	M	PrtSc	Q
Next	Prior	Main	Print	Quit
Menu	Screen	Menu	Screen	Now

### Schedule (Thickness) of Steel Pipe Used in Obtaining Resistance Of Valves and Fittings of Various Pressure Classes by Test\*

Valve or Fitting ANSI Pressure Classification		Schedule No. of Pipe Thickness
Steam Rating	Cold Rating	
250-Pound and Lower	500 psig	Schedule 40
300-Pound to 600-Pound	1440 psig	Schedule 80
900-Pound	2160 psig	Schedule 120
1500-Pound	3600 psig	Schedule 160
2500-Pound	6000 psig	xx (Double Extra Strong)
	3600 psig	Schedule 160

\*These schedule numbers have been arbitrarily selected only for the purpose of identifying the various pressure classes of valves and fittings with specific pipe dimensions for the interpretation of flow test data; they should not be construed as a recommendation for installation purposes.

### Representative Equivalent Length<sup>†</sup> in Pipe Diameters (L/D) Of Various Valves and Fittings

Description of Product			Equivalent Length In Pipe Diameters (L/D)
Globe Valves	Stem Perpendicular to Run	With no obstruction in flat, bevel, or plug type seat	Fully open 340
		With wing or pin guided disc	Fully open 450
	Y-Pattern	(No obstruction in flat, bevel, or plug type seat)	Fully open 175
		- With stem 60 degrees from run of pipe line - With stem 45 degrees from run of pipe line	Fully open 145
Angle Valves		With no obstruction in flat, bevel, or plug type seat	Fully open 145
		With wing or pin guided disc	Fully open 200
Gate Valves	Wedge, Disc, Double Disc, or Plug Disc		Fully open 13
			Three-quarters open 35
			One-half open 160
		One-quarter open 900	
Pulp Stock		Fully open 17	
		Three-quarters open 50	
		One-half open 260	
		One-quarter open 1200	
Conduit Pipe Line Gate, Ball, and Plug Valves			Fully open 3**
Check Valves	Conventional Swing		0.5 ft... Fully open 135
	Clearway Swing		0.5 ft... Fully open 50
	Globe Lift or Stop; Stem Perpendicular to Run or Y-Pattern		2.0 ft... Fully open Same as Globe
	Angle Lift or Stop		2.0 ft... Fully open Same as Angle
	In-Line Ball		2.5 vertical and 0.25 horizontal ft... Fully open 150
Foot Valves with Strainer		With poppet lift-type disc	0.3 ft... Fully open 420
		With leather-hinged disc	0.4 ft... Fully open 75
Butterfly Valves (8-inch and larger)			Fully open 40
Cocks	Straight-Through		Rectangular plug port area equal to 100% of pipe area Fully open 18
	Three-Way	Rectangular plug port area equal to 80% of pipe area (fully open)	Flow straight through 44
			Flow through branch 140
Fittings	90 Degree Standard Elbow		30
	45 Degree Standard Elbow		16
	90 Degree Long Radius Elbow		20
	90 Degree Street Elbow		50
	45 Degree Street Elbow		26
	Square Corner Elbow		57
	Standard Tee	With flow through run	20
With flow through branch		60	
Close Pattern Return Bend			50
Pipe	90 Degree Pipe Bends		See Page A-27
	Miter Bends		See Page A-27
	Sudden Enlargements and Contractions		See Page A-26
	Entrance and Exit Losses		See Page A-26

\*\*Exact equivalent length is equal to the length between flange faces or welding ends.


†Minimum calculated pressure drop (psi) across valve to provide sufficient flow to lift disc fully.

‡For limitations, see page 2-11. For effect of end connections, see page 2-10.

For resistance factor "K", equivalent length in feet of pipe, and equivalent flow coefficient "C", see pages A-31 and A-32.

# Relative Roughness of Pipe Materials and Friction Factors For Complete Turbulence<sup>18</sup>


18



Data extracted from *Friction Factors for Pipe Flow* by L.F. Moody, with permission of the publisher, The American Society of Mechanical Engineers, 29 West 39th Street, New York.

**Problem:** Determine absolute and relative roughness, and friction factor, for fully turbulent flow in 10-inch cast iron pipe (I.D. = 10.16").  
**Solution:** Absolute roughness ( $\epsilon$ ) = 0.00085. Relative roughness ( $\epsilon/D$ ) = 0.001. Friction factor at fully turbulent flow ( $f$ ) = 0.0190.

### Friction Factors for Any Type of Commercial Pipe<sup>18</sup>



For other forms of the  $R_e$  equation, see page 3-2.

Data extracted from *Friction Factors for Pipe Flow* by L. F. Moody, with permission of the publisher, The American Society of Mechanical Engineers, 29 West 19th Street, New York 18, N. Y.

**Problem:** Determine the friction factor for 10-inch cast iron pipe (10.16" I.D.) at a Reynolds number flow of 30,000.  
**Solution:** The relative roughness (see page A-23) is 0.001. Then, the friction factor ( $f$ ) equals 0.026.

# IDENTIFICATION CODE FOR ARMSTRONG STRAINERS

Strainer Codes are formed by using letter code for body, number code for screen specification followed by abbreviation for connection required. The code is completed by suffixing the connection size and,

for flanged strainers, the flange rating. An AIFL-8-250 is a 6" cast iron strainer with .045" perf. stainless steel screen and 250 lb. flanged connections.

Code	Material
A	Cast Iron 30,000 Min. tensile (ASTM A-278 Cl. 30) or equal
B	Carbon Steel (ASTM A-216 WCB)
C	Chrome Moly Steel (1¼% Chrome, ½% Moly)
D	ASTM A-217 WC6
E	Forged Steel (2¼% Chrome, 1% Moly) ASTM A-182 F22
F	Stainless Steel Type 316 (ASTM A-351 Grade CF8M)
G	Bronze (ASTM B-62)

Code	Screen
1	.045" perf. Stainless Steel (Type 304)
2	24x110 Type 316 Mesh Stainless Steel (.0055" opening)
3	.045" perforated Monel
4	.045" perforated Brass
5	20x20 Mesh Monel (.034" opening)
6	40x40 Mesh Monel (.015" opening)
7	.045" perforated Type 316 Stainless Steel
8	¼" perforated Type 304 Stainless Steel
9	100x100 Mesh Stainless Steel (.0055" opening)
X	Any screen not number coded—specify screen requirement. See Table A-4.

Code	Connection
SC	Screwed
FL	Flanged
SW	Socket Weld
BW	Butt Weld

Chart A-3—Liquid Flow Capacities for all Armstrong Y-Type Strainers, in U.S. Gallons per minute (gpm).




Table B-3—Ratio of Open Area of Screen to Inside Area of Pipe, Armstrong Y-Type Cast Iron Strainers. Color Background Indicates that Back-up Screens Are Employed.

Strainer Size	Total Screen Area, Sq. in.	Inside Area of Pipe, Sq. in.	RATIO—PERFORATED SCREENS							RATIO—WIRE MESH SCREENS				
			¼"	½"	.045"	¼"	⅜"	½"	24x110	20x20	40x40	100x100	200x200	
¾"-½"	5.2	0.30	5.2	5.0	6.4	5.2	6.9	8.8	10.0	4.8	6.6	5.2	2.2	2.5
¾"	7.2	0.53	4.0	3.9	5.0	4.0	5.4	6.9	7.8	3.8	5.3	4.1	1.8	2.0
1"	11.0	0.86	3.8	3.7	4.7	3.8	5.1	6.5	7.4	3.7	5.2	4.0	1.7	1.9
1½"	15.9	1.49	3.2	3.0	3.9	3.2	4.2	5.4	6.1	3.2	4.4	3.4	1.5	1.6
1½"	23.6	2.03	3.4	3.3	4.3	3.4	4.6	5.9	6.7	3.5	4.8	2.8	1.6	1.8
2"	34.4	3.35	3.0	2.9	3.8	3.0	4.1	5.2	5.9	3.2	4.4	2.6	1.5	1.6
2½"	54.4	4.78	3.4	3.3	4.2	3.4	4.5	5.8	6.6	3.3	3.5	2.7	1.7	1.9
3" 125#	74	7.39	1.7	2.9	3.7	3.0	4.0	5.1	5.8	2.9	3.1	2.3	1.5	1.7
3" 250#	87	7.39	2.0	3.4	4.3	3.5	4.7	6.0	6.8	3.5	3.8	2.8	1.8	2.0
4" 125#	123	12.7	1.7	2.8	3.5	2.9	3.8	4.9	5.6	2.8	3.0	2.3	1.5	1.6
4" 250#	145	12.7	2.0	3.3	4.2	3.4	4.5	5.8	6.6	3.4	3.7	2.1	1.8	2.0
5" 125#	194	20.0	1.7	2.8	3.5	2.9	3.8	4.9	5.6	1.7	3.1	1.8	1.5	1.7
5" 250#	245	20.0	2.1	3.5	4.5	3.6	4.9	6.2	7.1	2.2	4.0	2.3	2.0	2.2
6" 125#	272	28.9	1.6	2.7	3.4	2.8	3.1	4.8	5.4	1.6	3.0	1.8	1.5	1.6
6" 250#	317	28.9	1.9	3.1	4.0	3.2	4.3	5.5	6.3	1.9	2.7	2.1	1.7	1.9
8" 125#	464	50.0	1.6	2.6	3.4	2.7	3.7	4.7	5.3	1.6	2.3	1.8	1.5	1.7
8" 250#	550	50.0	1.9	3.1	4.0	3.3	4.4	5.6	6.3	2.0	2.8	2.1	1.8	2.0
10" 125#	733	78.8	1.6	2.7	3.4	2.7	3.7	4.7	5.4	1.7	2.3	1.8	1.5	1.7
12" 125#	1050	113.1	1.6	2.6	3.4	2.7	3.7	4.7	5.3	1.7	2.3	1.8	1.5	1.7
Percentage Open Area			30%*	29%	37%	30%	40%	51%	58%	33.3%*	46.2%*	36%*		

Notes: Cast steel strainers have the same ratios as 250 lb. cast iron except for 150 lb. stainless steel which is the same as 125 lb. cast iron.

\* For unbacked screens.

This table does not apply to forged steel strainers in table D-7.

Performance Adjustment Factors

*Ross Abj...*

Table 3-1 -- Performance Data Adjustment Factors

Fouling Factor	Altitude															
	Sea Level				2000 Feet				4000 Feet				6000 Feet			
	$\Delta T$	CAP	GPM	KW	CAP	GPM	KW	CAP	GPM	KW	CAP	GPM	KW			
0.00025	6	0.987	1.650	0.993	0.997	1.640	1.003	0.992	1.620	1.018	0.999	1.570	1.008			
	8	0.983	1.250	0.997	0.973	1.240	1.007	0.966	1.220	1.025	0.995	1.160	1.035			
	10	1.000	1.000	1.000	0.989	0.980	1.010	0.960	0.970	1.030	0.940	0.940	1.040			
	12	1.007	0.820	1.003	0.987	0.810	1.018	0.966	0.800	1.036	0.843	0.790	1.045			
	14	1.013	0.710	1.007	0.993	0.700	1.017	0.972	0.680	1.036	0.800	0.660	1.048			
	16	1.020	0.640	1.010	1.000	0.550	1.029	0.980	0.620	1.040	0.660	0.550	1.060			
0.00075	6	0.967	1.630	0.983	0.963	1.610	0.983	0.936	1.600	1.002	0.918	1.550	1.012			
	8	0.973	1.230	0.987	0.964	1.220	0.997	0.944	1.200	1.006	0.925	1.160	1.016			
	10	0.980	0.980	0.990	0.970	0.970	1.000	0.950	0.950	1.010	0.934	0.770	1.026			
	12	0.987	0.800	0.993	0.975	0.800	1.003	0.965	0.780	1.015	0.834	0.770	1.026			
	14	0.993	0.690	0.997	0.978	0.680	1.007	0.969	0.650	1.022	0.837	0.660	1.032			
	16	1.000	0.620	1.000	0.980	0.610	1.010	0.960	0.600	1.030	0.540	0.650	1.040			

Figure 3-1 -- Ethylene Glycol Performance Adjustment Factors and Solution Freezing Points




Figure 3-2 -- Evaporator Water Pressure Drop




Table 3-2 -- Ethylene Glycol Pressure Drop Adjustment Factors

LWT	Percent Of Ethylene Glycol					
	0	10	20	30	40	50
0	1.15	1.22	1.30	1.38	1.46	1.55
10	1.12	1.18	1.26	1.34	1.42	1.51
20	1.08	1.15	1.23	1.30	1.39	1.47
30	1.06	1.12	1.19	1.28	1.34	1.43
40	1.03	1.09	1.16	1.23	1.30	1.38
50	1.00	1.06	1.13	1.20	1.27	1.35

*(Reference only, see Appendix Glycol properties in ASHRAE)*

# Pipe Expansion Table


**THERMAL EXPANSION OF PIPE IN INCHES PER 100 FEET**

Pressure Psig	Temp. Degrees Fahr.	Steel Pipe	Stainless Steel 18CR-8NI	Copper Pipe	Pressure Psig	Temp. Degrees Fahr.	Steel Pipe	Stainless Steel 18CR-8NI	Copper Pipe
	-20	0	0	0	135	358	3.012	4.3272	4.356
	0	0.145	.2157	0.204	140	361	3.038	4.3632	4.381
	20	0.293	.4331	0.442	145	364	3.065	4.3992	4.430
	40	0.430	.6522	0.655	150	366	3.084	4.4232	4.454
	50	0.512	.7623	0.772	175	377	3.188	4.5555	4.595
	60	0.593	.8729	0.888	180.9	380	3.211	4.5917	4.628
	80	0.725	1.0953	1.110	200	387	3.272	4.6761	4.718
	100	0.898	1.3195	1.338	232.4	400	3.375	4.8334	4.870
	120	1.055	1.5454	1.570	250	406	3.435	4.9058	4.941
	140	1.209	1.7729	1.794	293.7	420	3.566	5.0751	5.118
	160	1.368	2.0022	2.008	366.1	440	3.740	5.3178	5.358
	180	1.528	2.2331	2.255	451.3	460	3.929	5.5619	5.612
	200	1.691	2.4658	2.500	550.3	480	4.100	5.8068	5.855
2.5	220	1.852	2.6974	2.720	664.3	500	4.296	6.0528	6.110
5	227	1.910	2.7788	2.804	795.3	520	4.487	6.3012	6.352
10	239	2.010	2.9186	2.828	945.3	540	4.670	6.5507	6.614
15	250	2.101	3.0472	3.075	1115.3	560	4.860	6.8013	6.850
20	260	2.183	3.1645	3.189	1308.3	580	5.051	7.0531	7.123
25	266	2.213	3.2349	3.259	1525.3	600	5.247	7.3061	7.388
30	274	2.299	3.3291	3.352	1768.3	620	5.437	7.5571	7.636
35	280	2.350	3.3998	3.422	2041.3	640	5.627	7.8091	7.893
40	286	2.401	3.4707	3.509	2346.3	660	5.831	8.0621	8.153
45	292	2.451	3.5417	3.576	2705	680	6.020	8.3160	8.400
50	297	2.494	3.6009	3.632	3080	700	6.229	8.5709	8.676
55	302	2.536	3.6601	3.689		720	6.425	8.8320	8.912
60	307	2.579	3.7193	3.747		740	6.635	9.0945	9.203
65	312	2.622	3.7786	3.806		760	6.833	9.3581	9.460
70	316	2.656	3.8261	3.853		780	7.046	9.6231	9.736
75	320	2.690	3.8736	3.900		800	7.250	9.8892	9.992
80	324	2.724	3.9211	3.949		820	7.464	10.1526	10.272
85	328	2.759	3.9687	3.998		840	7.662	10.4170	10.512
90	331	2.784	4.0044	4.035		860	7.888	10.6825	10.814
95	335	2.805	4.0521	4.084		880	8.098	10.9490	11.175
100	338	2.845	4.0879	4.121		900	8.313	11.2166	11.360
105	341	2.870	4.1238	4.169		920	8.545	11.4898	11.625
110	344	2.895	4.1596	4.192		940	8.755	11.7642	11.911
115	347	2.920	4.1954	4.227		960	8.975	12.0399	12.180
120	350	2.946	4.2313	4.263		980	9.196	12.3168	12.473
125	353	2.971	4.2672	4.298		1000	9.421	12.5950	12.747
130	355	2.987	4.2912	4.321					

**TYPICAL INSULATION THICKNESSES**

Temperature Ranges	Pipes ¼" thru 3"	Pipes 4" thru 6"	Pipes 8" thru 12"
100°F thru 200°F	1"	1"	1½"
200°F thru 300°F	1"	1½"	2"
300°F thru 400°F	1½"	2½"	3"
400°F thru 600°F	2"	3"	3½"

(VS.) We recommend that temperature range 0°F thru 34°F be vapor sealed.  
 For recommendations on temperatures above 600°F and pipe sizes exceeding 12", contact  
 Intergy, Inc. RICWIL® Piping Systems, 10100 Breckville Rd., Breckville, Ohio 44141



HNF-2483, Rev. 0  
Page F-25

INTERCO, INC., RICHLAND Piping Systems

BRECKSVILLE, OHIO 44141

FOR GRADE "B" STEEL PIPE

23

POWER MACHINE CO.

FAX TRANSMITTA



COMPRESSORS, PUMPS and DRIVES • ENGINEERED SYSTEMS  
KIPARY, INC. EXPORT TRANSACTIONS

TO: ROSS

COMPANY IFC KAISER EUG.

DATE: 3-28-94

FAX NO: 510-419-5355

FAX LOG NO: 94/408

SUBJECT: \_\_\_\_\_

FROM: JORDAN KAUFMAN

NO. OF PAGES 2 INCLUDING COVER SHEET REPLY TO FAX (510) 547-2007

ITEM 1 - CDS: 120GPM @ 150FT  
ONE (1) EACH INGERSOLL DRESSER PUMP MODEL 3X1.5 X 6 SHOX,  
MAGNOSEAL, BASEMOUNTED w/ COUPLAX, AND GUARD TO A 10HP,  
3600 RPM MOTOR (56% EFFICIENCY)  
BUDGET PRICE EACH \$ 6,000.00

ITEM 2 - CDS: 120GPM @ 107FT  
ONE (1) EACH INGERSOLL DRESSER PUMP MODEL 3X1.5 X 6 SHOX,  
MAGNOSEAL, BASEMOUNTED w/ COUPLAX AND GUARD TO A 7.5 HP,  
3600 RPM MOTOR (58% EFFICIENCY)  
BUDGET PRICE EACH \$ 5,500.00

FOB FACTORY

DELV. 4-6 WEEKS

TAX EXTRA  
QUOTE VALID 60 DAYS

**INGERSOLL-RAND.**  
**AIR COMPRESSORS**



**Ingersoll-Dresser Pumps**

5768 SHELLMOUND STREET • EMERYVILLE, CALIFORNIA 94608 • (510) 658-9661 • FAX (510) 547-2007  
151 Bernal Road, Suite 5A, San Jose, California 95119 (408) 365-8700 • FAX (408) 365-0404  
4003 Seaport Blvd., West Sacramento, California 95691 (916) 375-0075 • FAX (916) 375-8534

**DON'T SAY IT** --- Write It!

DATE: January 7, 1994

TO: W.J. McGinley

FROM: Peter H. Langowski *PK* E6-21

Telephone: (509) 376-4226

cc (w/o att.): Ron Davidson, David Shrimpton, John Jurgilewicz, Charlie O'Neill

SUBJECT: Project W-320 Chiller Specification & Design Input

Please accept the following as the input you requested from KEH under Article I.B. of your Work Plan dated 12/30/93.

1. Length of coolant pipe between the chiller skid and condenser.

Per HVAC Overall C-Farm Site Plan H-2-818469, revision 0 dated 1/7/94 (attached). A takeoff of this drawing yields the following (pipe lengths indicated for each supply line and return line; i.e. the total length of piping in the system is 638 feet):

279 feet of pipe below grade (near horizontal)

6 feet of pipe below grade (vertical risers)

+34 feet of pipe above grade (total of both the condenser and the chiller ends)

319 feet total for each supply and return

2. Number of elbows, (long or short radius).

All chilled water piping elbows should be long radius ( $r/D=1.5$ ). For sizing purposes use 14 elbows for each supply and return (i.e. 28 total elbows in the system between the condenser and the chiller skid): 8 @ 90°; and 6 @ 45°.

3. Heat transfer to coolant, Btu/hr.


The Energy Balance drawing H-2-818479 states the heat transfer as being 235,080 Btu/h. Condenser sizing has been completed at 250,000 Btu/h. Use 250,000 Btu/h for calculation purposes.

4. Coolant temperature entering and leaving condenser.

Based on a preliminary selection of a condenser, the entering and leaving condenser temperatures shall be 33°F and 38°F, respectively. Preliminary coolant flow pressure drop through the condenser is 3 psig based on 120 gpm of 40% propylene glycol solution.

# WESTROL SUPERTANKS

DIAPHRAGM, BLADDER  
AND PLAIN STEEL EXPANSION TANKS



HNF-2483, Rev. 0  
Page F-28

**wessels** company


## TYPE NLA EXPANSION TANKS

ASME replaceable bladder type expansion tanks for commercial and industrial heating/cooling systems. Space saving tank comes in sizes of 10 to 2640 gallons.



- ASME Section VIII Construction and Label
- Permanent separation of air and water
- Never waterlogs
- Water is "in the bag". Steel tank never touches water and is not subject to corrosion
- Replaceable Bladder
- Smaller sizes for easier handling, and saves space and installation costs
- Factory pre-charged and field adjustable



NLA 15  
Thru  
NLA 50



NLA 1000  
Thru  
NLA 10000



NLA 85  
Thru  
NLA 800



### Saddles

Size	A	B	Weight
12	10	3	18
14	11	3	19
16	13	3	21
20	14	4	25
24	17	4	28
28	19	4	34
30	21	5	38
36	25	5	52

Model Number	Tank and Acceptance Volume Gallons	Tank Dia.	Tank Height	N.P.T. System Conn.	N.P.T. Aux. Conn.	Shipping Weight Pounds
*NLA 15	7.8	12"	19"	1/2"	-	47
*NLA 20	10.9	12"	25 3/4"	1/2"	-	60
NLA 35	10	12"	25 1/2"	3/4"	-	40
NLA 50	13	14"	25 1/2"	3/4"	-	50
NLA 85	23	16"	37"	1"	1/2"	90
NLA 130	35	20"	37"	1"	1/2"	125
NLA 185	48	20"	49"	1"	1/2"	160
NLA 250	66	24"	49"	1 1/2"	1/2"	210
NLA 300	79	24"	54"	1 1/2"	3/4"	225
NLA 400	106	28"	55"	1 1/2"	3/4"	300
NLA 450	119	30"	54"	2"	3/4"	330
NLA 550	145	30"	67"	2"	3/4"	360
NLA 800	211	36"	66"	2"	3/4"	475
NLA 1000	264	36"	73 1/4"	1 1/2"	-	710
NLA 1200	317	36"	86 7/8"	1 1/2"	-	720
NLA 1400	370	36"	98"	1 1/2"	-	875
NLA 1600	422	48"	71"	1 1/2"	-	1100
NLA 2000	528	48"	84 3/4"	1 1/2"	-	1280
NLA 3000	792	48"	122"	2"	-	1550
NLA 4000	1056	54"	121"	2"	-	2230
NLA 5000	1320	54"	151"	2"	-	2570
NLA 7500	1980	72"	129"	3"	-	4005
NLA 10000	2640	72"	161"	3"	-	4845

125 P.S.I. operating pressure - 240°F maximum temperature at tank  
Factory pre-charged 12 P.S.I.

Prime painted exterior finish

\*Fixed diaphragm design with 2.5 gallons acceptance volume

FAX TRANSMITTAL



COMPRESSORS, PUMPS and DRIVES • ENGINEERED SYSTEMS  
KIPARY, INC. EXPORT TRANSACTIONS

TO: Ross Abjelma

COMPANY: Kaiser

DATE: 2/22/94

FAX NO: 510-419-5355

FAX LOG NO:

SUBJECT: Pumps

FROM: Mike Ambrosi

NO. OF PAGES \_\_\_\_\_ INCLUDING COVER SHEET REPLY TO FAX (510) 547-2007

**INGERSOLL-RAND.**  
**AIR COMPRESSORS**



**Ingersoll-Dresser Pumps**

5768 SHELLMOUND STREET • EMERYVILLE, CALIFORNIA 94608 • (510) 658-9661 • FAX (510) 547-2007  
151 BURNETT ROAD, SUITE 5A SAN JOSE, CALIFORNIA 95119 (408) 365-8700 • FAX (408) 365-0404

# SHOC & SGRP PROCESS PUMPS

29

## CAPABILITIES OF SHOC/SGRP ANSI PROCESS PUMPS

Viscosity (Max):	600 Centipoise 2500 SSU
Temperature (Max):	250 Deg. F for SGRP 250 Deg. F for Process SHOC 500 Deg. F for All Metal SHOC
Working Pressure:	375 psig max.
Entrained Gas (Max):	3% max. by volume
Particles (Max):	100 Micron, 1.5% by weight Contact SPD for Wash Flow Strainer Application
Minimum Flow:	See Back of page 7100.20, sheet 101




### PRESSURE LIMITS, PSI

Refer to Pressure vs. Temperature charts below to determine pressure limits for specific operating conditions. The Maximum Suction Pressure equals the Maximum Working Pressure minus the Differential Pressure.

Category	Material Columns	Maximum Working Pressure		Hydrotest Pressure
		Process Construction	All Metal Construction	
Standard 150# Flanges	DI	200	290	See Note (2)
	S	200	275	
	R	200	235	
	CD4, HC, HB	200	295	
	VE	200	N/A	
Optional 300# Flanges	S, R, CD4, HC, HB (1)	200	375	(2)

NOTES: (1) Ductile iron and VE pumps are not available with 300# Flanges.  
 (2) Hydrotest Pressure is a minimum of 1.15 times the Maximum Working Pressure for SHOC and 1.1 times the Maximum Working Pressure for SGRP.

### PRESSURE VS. TEMPERATURE



## SHOC &amp; SGRP PROCESS PUMPS

## STANDARD CONSTRUCTION

Category	Construction Features	Standard	Optional At Extra Price
Type	Horizontal, End Suction, Single Stage, Top Centerline Discharge, Foot Mounted Back Pullout, Flexible Coupling	X	
Drive	Permanent High Strength Magnet-to-Magnet	X	
Rotation	CW (Clockwise) facing pump coupling (per Hydraulic Institute)	X	
Casing	SHOC & SGRP are interchangeable with HOC2 & GRP respectively	X	
Nozzles	150# R.F. (Flat Face) Flanges 150# R.F. (Raised Face) Flanges (except Col. DI & VE) with grooved finish 300# R.F. (Flat Face) Flanges (except Col. DI & VE) 300# R.F. (Raised Face) Flanges (except Col. DI & VE) with grooved finish	X	X X X
Auxiliary Connections	Material Col. DI and S—50 inch NPT Casing Drain Tap, .38 inch NPT Discharge Gage Tap —38 inch NPT Suction Gage Tap —Casing with no Taps	X	X X
Casing	Material Col. CD4, R, HC, HS—No Taps —50 inch NPT Casing Drain Tap, .38 inch NPT Discharge Gage Tap —38 inch NPT Suction Gage Tap	X	X X
	Material Col. VE (SGRP)—No Taps —250 inch NPT Discharge Gage Tap and .250 inch NPT Casing Drain —250 inch NPT Casing Drain Tap	X	X X
Drain Plug	Machined Head Plug—Col. DI and S Square Head Polypro—Col. VE Machined Head Plug—Col. CD4, R, HC, HS Round Head Plug	X	X X X
Impeller	Semi-Open, Balanced (1) SHOC & SGRP (except for 1-1/2x1x8 SGRP) are interchangeable with HOC2 & GRP respectively	X	
Cover	Non-wetted Casing to Cover fit, Flat Gasket—SHOC only O-Ring Gasket at Cover to Casing fit—SGRP only .25 inch NPT External Flush Tap—Plugged Containment Shell drained internally to Casing External containment shell drain Internal Flush Hole with .25 inch NPT—Not Plugged Wash Flow Strainer—SHOC only	X X X X X	X X
Gaskets & O-Rings	Gaskets—SHOC only (Group 2 includes casing and containment shell gaskets) Containment Shell O-Ring—SHOC (Group 1)  O-Ring—SGRP (includes all O-Rings)	X X X X	X X X X X
Bearing Housing	Shroud Area—.38 inch NPT on top—Standard with Vent —38 inch NPT at bottom—Standard Plugged Grease-for-life lubrication Oil Bath Lubrication, Plastic Trico Oiler Oil Bath Lubrication, Guarded Glass Oiler Oil Mist Connections—(2) .375 inch NPT Taps Labyrinth Oil Seal—Outboard—Dura (bronze, viton) —INPRO (bronze, viton) .25 inch NPT Ball Bearing Temp. Probe Tap	X X X X X X X	X X X X X X
Couplings	All Manufacturers and Types		X
Coupling Guard	OSHA, Steel Non-Sparking Aluminum		X X
Bedplate	Fabricated Steel with 316SS Drip Pan with Drip Lip with Machined Pads with Stainless steel Stills Fiberglass with built-in Drip Pan with Stainless Steel Stills		X X X X X X
Testing	Hydrostatic Test Performance Test NPSH Test Witness Tests	X	X X X

NOTE (1) SHOC Impellers are single plane spin balanced. Single shroud open Impellers cannot be dynamically balanced because they do not have two shrouds on which to perform adjustments. SGRP Impellers, due to the high precision molding, do not require mechanical balancing.

# Magnoseal™

## SHOC & SGR PROCESS PUMPS

31

HNF-2483, Rev. 0  
Page F-33

### STANDARD MATERIALS ALL METAL CONSTRUCTION SHOC ONLY

Material Column	DI	S	CD4	R	HC	HB
General Description	Ductile Iron	316 S.S.	CD4MCu	Alloy 20	Hastelloy C	Hastelloy B
Casing	Ductile Iron (Note 1)	316 S.S. (Cast)	CD4MCu	Alloy 20 (Cast)	Hastelloy C	Hastelloy B
Casing Gasket	Non-Asbestos					
Casing Bolting	Carbon Steel (Bolting)	304 S.S. (Bolting)				
Impeller	Carbon Steel (Cast)	316 S.S. (Cast)	CD4MCu	Alloy 20 (Cast)	Hastelloy C	Hastelloy B
Casing Cover	316 S.S. (Cast)			Alloy 20 (Cast) (Note 2)	Hastelloy C	Hastelloy B
Shaft-pump (internal)	316 S.S.			Alloy 20	Hastelloy C	Hastelloy B
Shaft-Brg Hsg (external)	Carbon Steel (Hot Rolled)					
Inner Magnet Carrier	316L S.S.			Alloy 20	Hastelloy C	Hastelloy B
Outer Magnet Carrier (4)	Ductile Iron			Hastelloy (3)	Hastelloy C	Hastelloy B
Containment Shell	316 / Hastelloy C			Hastelloy (3)	Hastelloy C	Hastelloy B
Shell O-Ring	Viton					
Inner Magnet Cladding	316L S.S.			Alloy 20	Hastelloy C	Hastelloy B
Bearing Housing (4)	Ductile Iron					
Product Lube Bearings	Silicon Carbide					

NOTE 1: On SHOC only the casing is investment cast carbon steel.  
 NOTE 2: Cast R Casing Covers may be provided in Alloy 20 or Hastelloy C at factory option.  
 NOTE 3: Hastelloy C may be specified for specific application.  
 NOTE 4: These parts may be supplied in carbon steel or steel at factory option.

### MATERIAL SPECIFICATIONS

General Description	Specification	General Description	Specification
Ductile Iron	ASTM A395	304 S.S. (Bolting)	ASTM A276 Type 304
316 S.S. (Cast)	ASTM A744 CF8M	316 S.S. (Wrought)	ASTM A276 Type 316
CD4MCu	ASTM A744 CD4MCu	Alloy 20 (Wrought)	ASTM B473
Alloy 20 (Cast)	ASTM A744 CN7M	Carbon Steel (Bolting)	ASTM A193 B7
Hastelloy C	ASTM A494 CW12MW	Carbon Steel (Hot Rolled)	AISI 4140
Hastelloy B	ASTM A494 N12MV	Carbon Steel (Key)	AISI C1018
Carbon Steel (Cast)	ASTM A216 WCB		

**STANDARD MATERIALS  
PROCESS CONSTRUCTION**

Material Column	DI	S	CD4	R	HC	HB	VE (SGRP)
General Description	Ductile Iron	316 S.S.	CD4MCu	Alloy 20	Hastelloy C	Hastelloy B	Glass Reinforced Polymer
Casing	Ductile Iron (Note 1)	316 S.S. (Cast)	CD4MCu	Alloy 20 (Cast)	Hastelloy C	Hastelloy B	GRP
Casing Gasket (O-Ring on SGRP)	Non-Asbestos						Vilon
Casing Bolting	Carbon Steel (Bolting)	304 S.S. (Bolting)					
Impeller	Carbon Steel (Cast)	316 S.S. (Cast)	CD4MCu	Alloy 20 (Cast)	Hastelloy C	Hastelloy B	GRP
Casing Cover		316 S.S. (Cast)		Alloy 20 (Cast) (Note 2)	Hastelloy C	Hastelloy B	GRP
Shaft-pump (internal)		316 S.S.		Alloy 20	Hastelloy C	Hastelloy B	Hastelloy C (3)
Shaft-Eng Hsg (external)			Carbon Steel (Hot Rolled)				
Inner Magnet Carrier		316L S.S.		Alloy 20	Hastelloy C	Hastelloy B	Hastelloy C (3)
Outer Magnet Carrier (4)			Ductile Iron				
Containment Shell			Reinforced Crystalline Polymer				
Shell O-Ring			Vilon				
Inner Magnet Cladding		316L S.S.		Alloy 20	Hastelloy C	Hastelloy B	Hastelloy C (3)
Bearing Housing (4)			Ductile Iron				
Product Lube Bearings			Silicon Carbide				

NOTE 1: On 3x2x6K only the casing is investment cast carbon steel.  
NOTE 2: Col. R Casing Covers may be provided in Alloy 20 or Hastelloy C at factory option.  
NOTE 3: Process fluid compatible material will be provided.  
NOTE 4: These parts may be provided in carbon steel or steel at factory option.

**MATERIAL SPECIFICATIONS**

General Description	Specification	General Description	Specification
Ductile Iron	ASTM A395	304 S.S. (Bolting)	ASTM A276 Type 304
316 S.S. (Cast)	ASTM A744 CF8M	316 S.S. (Wrought)	ASTM A276 Type 316
CD4MCu	ASTM A744 CD4MCu	Alloy 20 (Wrought)	ASTM B473
Alloy 20 (Cast)	ASTM A744 CN7M	Carbon Steel (Bolting)	ASTM A193 B7
Hastelloy C	ASTM A494 CW12MW	Carbon Steel (Hot Rolled)	AISI 4140
Hastelloy B	ASTM A494 N12MV	Carbon Steel (Key)	AISI C1018
Carbon Steel (Cast)	ASTM A216 WCB	GRP	Glass Reinforced Vinyl Ester

HNF-2483, Rev. 0  
Page F-34

Dom. Exp. Dist. on 60C

© 1991 Ingersoll-Rand Company  
Printed in U.S.A.

(OVE




# BELL & GOSSETT

HNF-2483, Rev. 0  
Page F-36

**SUBMITTAL**

A-326C



## The ROLAIRTROL<sup>®</sup> Air Separator Air Control

NOTE: 3" MODELS HAVE NPT NOZZLES.

JOB \_\_\_\_\_

UNIT TAG NO. \_\_\_\_\_

ENGINEER \_\_\_\_\_

CONTRACTOR \_\_\_\_\_

B & G REPRESENTATIVE \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

ORDER NO. \_\_\_\_\_ DATE \_\_\_\_\_

SUBMITTED BY \_\_\_\_\_ DATE \_\_\_\_\_

APPROVED BY \_\_\_\_\_ DATE \_\_\_\_\_

### DESCRIPTION

The Rolairtrol Air Separator is designed with tangential openings to create a low velocity vortex where air is separated and removed from the circulating water. As with all other air separators Airtrol Tank Fittings must be included in the system to properly direct and confine air inside the compression tank.

### CONSTRUCTION

- Body — Models R-2, RL-2, R-2½ and RL-2½: Cast Iron
- Shell — All other models: Steel
- System Strainer ("R" Models only):  
 Models R-2 and R-2½: Have stainless steel strainers with ½" diameter perforations and 63% open area.  
 All other "R" models: Have galvanized steel strainers with ¾" diameter perforations with 53% open area.
- Air Collector Tube: Stainless steel with ½" diameter perforations and 63% open area.
- Baffle/Collector Tube Support Assembly: Steel

### SCHEDULE AND PERFORMANCE CHARACTERISTICS

MODEL NO. AND CAPACITY				SIZE OF TANGENTIAL OPENINGS INCHES		TAGGING INFORMATION	QUANTITY
WITH STRAINER		LESS STRAINER					
MODEL NO.	GPM*	MODEL NO.	GPM*				
R-2	56	RL-2	56	2	NPT		
R-2½	90	RL-2½	90	2½			
R-3	190	RL-3	190	3			
R-4	300	RL-4	300	4			
R-5	500	RL-5	530	5			
R-6	700	RL-6	850	6			
R-8	1300	RL-8	1900	8	FLANGED		
R-10	2000	RL-10	3600	10			
R-12	2750	RL-12	4800	12			
R-14	3400	RL-14	6100	14			
R-16	4400	RL-16	8000	16			
R-18	5200	RL-18	9700	18			
R-20	6300	RL-20	12000	20			
R-22	7400	RL-22	15000	22			
R-24	8500	RL-24	17000	24			

\*PRESSURE DROP: With strainer—14 elbow equivalents    Less strainer— 9 elbow equivalents  
 MAXIMUM DESIGN PRESSURE 125 P.S.I.G.    MAXIMUM OPERATING TEMPERATURE 350°F

### TYPICAL SPECIFICATION

Furnish and install, as shown on plans, a centrifugal type air separator. The unit shall have \_\_\_\_\_ " (NPT/flanged) inlet and outlet connections tangential to the vessel shell. Vessel shell diameter to be three times the nominal inlet/outlet pipe diameter.

The unit shall have an internal stainless steel air collector tube with ½" diameter perforations and 63% open area designed to direct accumulated air to the compression tank via an NPT vent connection at top of unit.

The unit shall have a removable galvanized steel system strainer with ¾" diameter perforations and a free area of not less than five times the cross-sectional area of the connecting pipe. A blowdown connection shall be provided to facilitate routine cleaning of the strainer. (Delete this paragraph if system strainer is not specified.)

Manufacturer to furnish data sheet specifying air collection efficiency and pressure drop at rated flow.

The air separator must be designed, constructed and stamped for 125 psig @ 350°F in accordance with Section VIII, Division I of the ASME Boiler and Pressure Vessel Code, and registered with the National Board of Boiler and Pressure Vessel Inspectors. The air separator(s) shall be painted with one shop coat of light gray air dry enamel.

A manufacturers' Data Report for Pressure Vessels, Form U-1 as required by the provisions of the ASME Boiler and Pressure Vessel Code shall be furnished for each air separator upon request.

Each air separator shall be ITT Bell & Gossett Model No. R-..... (with system strainer) or RL-..... (less system strainer) Rolairtrol Air Separator for.....GPM.






Fig. 4 Viscosity of Calcium Chloride Brine<sup>1</sup>




Fig. 5 Thermal Conductivity of Calcium Chloride Brine<sup>1</sup>

**INHIBITED GLYCOLS**

Ethylene glycol and propylene glycol, inhibited for corrosion control, are used as aqueous freezing point depressants and heat transfer media in heating and cooling systems. Their chief attributes are the ability to lower the freezing point of water, and low volatility and relatively low corrosivity when properly inhibited. A monitoring schedule on glycol fluids helps prevent undesirable inhibitor depletion.

Inhibited ethylene glycol solutions have better physical properties than propylene glycol solutions, especially at lower temperatures. However, the less toxic propylene glycol is preferred for applications involving possible contact with food or beverages. Applications such as snow melting and ice tank systems are described in the 1982 APPLICATIONS and 1984 SYSTEMS VOLUMES.

**Physical Properties<sup>1</sup>**

Ethylene and propylene glycol are colorless, practically odorless liquids, completely miscible with water and many organic compounds. Table 3 shows important properties of the pure materials.

The freezing point vs. composition aqueous mixtures are given in Fig. 10. Pure ethylene glycol freezes at 9°F. The ethylene-glycol-water freezing point curve indicates occurrence of a eutectic, but its exact composition and temperature are unknown, since solutions with freezing points in this range set a viscous, glassy mass that makes it difficult to determine true freezing points. On the dilute side of the eutectic, ice forms from solution on freezing. Freezing velocity of such solutions is often quite slow; but, in time, they set to a hard, solid mass.




Fig. 6 Specific Heat of Sodium Chloride Brine<sup>1</sup>




Fig. 7 Specific Gravity of Sodium Chloride Brine<sup>1</sup>




Fig. 8 Viscosity of Sodium Chloride Brine<sup>1</sup>




Fig. 9 Thermal Conductivity of Sodium Chloride Brine<sup>1</sup>




Fig. 10 Freezing Points of Aqueous Solutions of Ethylene Glycol and Propylene Glycol

boiling point and condensation

for aqueous solutions of ethylene glycol. Note the relatively small increase in boiling point with increase in glycol concentration. Vapor compositions above the boiling point are very low in glycol. Therefore, in open applications, significant cooling is possible.

and 14 give specific gravity vs. composition aqueous solutions of ethylene and propylene glycol. Two important facts: (1) values for propylene glycol are to those of water (when compared with ethylene glycol) and (2) propylene glycol values are maximum at 70% concentration. This makes it difficult to ascertain propylene glycol content of solutions by specific gravity measurements. Control by refractive index measurement or Karl Fischer analysis for water are the preferred laboratory methods for determining composition of propylene glycol solutions.

To convert specific gravity to density, multiply the appropriate value from Fig. 13 or 14 by the water density at the reference temperature (62.37 lb./ft.<sup>3</sup>). Figures 13 and 16 give viscosity for ethylene and propylene glycol-water systems. These plots show a significantly higher viscosity for the propylene glycol solutions, particularly at low temperatures.

Table 3 Summary of Physical Properties

Property	Ethylene Glycol	Propylene Glycol
Molecular Weight	62.07	76.10
Specific Gravity at 68/68 F	1.1155	1.0381
Mass per Unit Volume at 68 F	69.50 lb./ft. <sup>3</sup>	64.68 lb./ft. <sup>3</sup>
Boiling Point in F	388	369
at 760 mm Hg	215	241
at 30 mm Hg	192	185
Vapor at 68 F	0.05	0.07
Freezing Point in F	9.1	Below -76
Viscosity in centipoise		
at 32 F	57.4	243
at 68 F	20.5	49.5
at 104 F	14.319	18.0
Refractive Index, n <sub>D</sub> at 68 F	1.4319	1.4329
Specific Heat, Btu/lb./F	0.561	0.593
Heat of Fusion at 9.1 F		
Heat of Vaporization at 1 atm		
in Btu/lb.	364	296
Heat of Combustion at 68 F		
in Btu/lb.	12850	10,312




Fig. 11 Boiling Point and Condensation of Aqueous Solutions of Ethylene Glycol




Fig. 12 Boiling Point and Condensation of Aqueous Solutions of Propylene Glycol

Secondary Coolants (Brines)




Fig. 13 Specific Gravity of Aqueous Solutions of Ethylene Glycol




Fig. 14 Specific Gravity of Aqueous Solutions of Propylene Glycol

Figures 17 and 18 give specific heats for aqueous solutions of ethylene and propylene glycol. On an equivalent percent-by-mass basis, propylene glycol solutions have higher specific heat values than ethylene glycol solutions, though neither is as efficient as water alone for heat transfer applications.

Figures 19 and 20 give the thermal conductivity for aqueous ethylene glycol and propylene glycol solutions. Note that thermal conductivity of the glycols decreases with increasing temperature, but water dilution offsets this to some degree. Additional physical property data is available from suppliers of ethylene and propylene glycol.

Corrosion Inhibition

Commercial ethylene or propylene glycol, when pure, is generally less corrosive than water to common metals used in construction. Aqueous solutions of these glycols, however, assume the corrosivity of the water from which they are prepared and can become increasingly corrosive with use if not properly inhibited. This is because glycols, like most other organic compounds, are oxidized by air into acidic end products. The amount of oxidation is influenced by such factors as temperature, degree of aeration and, to some extent, the particular combination of metal components to which the glycol solution is exposed.




Fig. 15 Viscosity of Aqueous Solutions of Ethylene Glycol




Fig. 16 Absolute Viscosity of Aqueous Solutions of Propylene Glycol




Fig. 17 Specific Heat of Aqueous Solutions of Ethylene Glycol




Fig. 18 Specific Heat of Aqueous Solutions of Propylene Glycol

Corrosion inhibitors<sup>3</sup> is perhaps most easily understood by classifying additives either as (1) corrosion inhibitors or (2) environmental stabilizers and adjusters. Corrosion inhibitors form a surface barrier that protects the metal from attack. These barriers are usually formed by mechanisms such as adsorption of the inhibitor by the metal, or by reaction of the inhibitor with the metal or perhaps the incipient reaction product. In most cases, metal surfaces are covered by films of their oxides that inhibitors reinforce.

Environmental stabilizers or adjusters, while not corrosion inhibitors in the strict sense, decrease corrosion by stabilizing or favorably altering the overall environment. An alkaline buffer such as borax is an example, since its prime purpose is to maintain an alkaline condition (pH above 7). Some chelating agents function as stabilizers by removing from the solution certain deleterious ions that accelerate the corrosion process or mechanism; however, exercise caution in their use. Certain oxidants, such as sodium chromate, should not be used in conjunction with glycol solutions, because the glycol can oxidize prematurely. Generally, combinations of the two types of additives, inhibitors and stabilizers, offer the best corrosion resistance in a given system. Commercial, inhibited glycols are available from several suppliers.

**Service Considerations**

**Storage and Handling.** Inhibited glycol concentrates are stable, relatively noncorrosive materials with high flash points. Although they can be stored in mild steel, stainless steel or aluminum vessels, or even containers lined with a baked phenolic or vinyl resin coating, may be required. Since chemical properties of an inhibited glycol concentrate differ from those of its dilution, the effect of the concentrate on different containers should be known when selecting storage.

Choose transfer pumps only after considering temperature-viscosity data. Centrifugal pumps with electric motor drives are often recommended. Rubber-impregnated absorbers or its equivalent is a suitable pump packing material. A mechanical seal may also be satisfactory. Mild steel transfer piping with a minimum diameter is suggested. Welded construction is normally used in conjunction with the piping, although flanged and gasketed joints are also satisfactory.




Fig. 19 Thermal Conductivity of Aqueous Solutions of Ethylene Glycol

**Preparation Before Application.** Before an inhibited glycol is charged into a system, remove residual contaminants such as sludge, rust, brine deposits and oil so the contained inhibitor functions properly. Avoid strong acid cleaners; if they are required, consider inhibited acids. Completely remove the cleaning agent before charging with inhibited glycol.

Water of dilution quality must be considered, because water from some sources contains corrosive elements that reduce effectiveness of the inhibited formulation. Surface waters classified as soft (that are low in chloride and sulfate ion content) (less than 100 ppm each) are preferred. Use distilled, deionized, or condensate water to avoid undesirable effects of poor quality water.

The decision to employ an inhibited glycol should be consistent with potential temperature factors. In systems with a high degree of aration, a maximum bulk fluid temperature of 180 F is proposed, but up to 250 F is permissible in a pressurized system if an intake is kept to a minimum. Maximum skin temperatures should not exceed 300 to 325 F, and should be even lower if the hot wall surface area is large in proportion to the quantity of fluid circulated. Nitrogen blanketing often helps minimize oxidation when the system operates at elevated temperatures for extended periods.

Operation below -60 F is not recommended, although slightly lower temperatures are tolerable if the solution temperature is cycled periodically to a higher level.

Install suitable filters because the removal of active sludge and other contaminants is critical. If inhibitors are rapidly and completely adsorbed by such contamination, the fluid is ineffective for corrosion inhibition. Consider such adsorption in filter selections.

**Inhibitor Maintenance.** An important factor in maintaining a glycol solution in relatively noncorrosive condition for a long period is the inhibitor monitoring and maintenance schedule. This cannot be overemphasized. However, a specific schedule is not always easy to establish, since inhibitor depletion rate depends on the particular conditions of use. Analysis of samples immediately after installation, after two to three months, and after six months, should establish the pattern for the schedule. Visual inspection of the solution and filter residue can indicate active corrosion.

In corrosion protection, properly inhibited and maintained glycol solutions provide advantages over brine solutions in most systems. An indefinite service life, however, should not be expected. Avoid indiscriminate mixing of inhibited formulations. Exercise caution in replacing brine systems with inhibited glycols because brine components may be incompatible with glycol formulations.




Fig. 20 Thermal Conductivity of Aqueous Solutions of Propylene Glycol

Table 4 Freezing and Boiling Points of Halocarbon Coolants

Refrigerant	Name	Freezing Point, F	Boiling Point, F
12	Dichlorodifluoromethane	-252	-21.6
11	Trichlorofluoromethane	-168	109.6
90	Methylene Chloride	-142	188.4
1120	Trichloroethylene	-123	

Table 5 Properties of Liquid Methylene Chloride

Temp, F	Vapor Pressure, psia	Specific Heat, Btu/F	Thermal Conductivity, Btu/h-ft <sup>2</sup> -F	Density, lb/ft <sup>3</sup>	Viscosity, Centipoise
140	35.4	0.296	0.074	78.3	0.32
120	19.9	0.285	0.076	79.4	0.34
100	14.5	0.278	0.089	80.5	0.37
80	10.1	0.266	0.081	81.6	0.40
60	6.8	0.254	0.083	82.7	0.44
40	4.3	0.242	0.085	83.8	0.48
32	2.73	0.280	0.087	84.9	0.52
14	1.64	0.278	0.089	87.0	0.59
-4	0.97	0.277	0.091	88.2	0.66
-22	0.53	0.275	0.093	88.2	0.76
-40	0.32	0.274	0.094	89.3	0.88
-58	0.22	0.273	0.096	90.4	1.05
-74	0.10	0.273	0.099	91.5	1.29
-92	0.06	0.273	0.099	92.6	1.68
-112	0.03	0.272	0.101	93.7	2.50

W320-28-008

High Efficiency Metal Filter  
Shielding Input and Flushing Frequency



**DESIGN ANALYSIS**

Client WHC

Subject High Efficiency Metal Filter  
shielding input and flushing frequency

Location 241-C/200 East

WO/Job No. ER4319

Date 6-8-94

Checked 6/13/94

Revised 2/15/96

By PH Langowski

By *B. Price*By *E. P. ...* 2/15/961.0 OBJECTIVE

The objective of this calculation is to determine the shielding and flushing requirements for the High Efficiency Metal Filter (HEMF).

2.0 DESIGN INPUTS2.1 CRITERIA AND SOURCE

DOE General Order 6430.1A

Functional Design Criteria WHC-SD-W320-FDC-001, rev. 2, 1/18/94

2.2 GIVEN DATA

The PSE values are "based on unit liter release source term values for laboratory data (conservative values) of C-106 solids" (ref. 1, p. B-3).

2.3 ASSUMPTIONS

none

2.4 METHODS

Hand calculations and Excel spreadsheet.

2.5 REFERENCES

1. Preliminary Safety Evaluation WHC-SD-WM-PSE-010, rev. 0
2. H-2-818478, rev. 0-33-006
3. calculation W320-E-001, rev. 0
4. Functional Design Criteria, WHC-SD-W320-FDC-001, rev. 2

3.0 CALCULATIONS3.1 Initial Shielding Design Inputs

Based on data gathered from reference 1, a source term was determined for an initial shielding calculation. Table A-3 from ref. 1 (see App A, p. A2), lists a value of 14.0 Rem/Liter equivalent dose to the onsite worker with plume meander. The onsite worker safety class 2 "trigger level" is 5 Rem. Therefore, 5 Rem/14 Rem/Liter = 0.357 Liter is the safety class 2 "trigger level" source term.

Table B-1 from ref. 1 (see App A, p. A3), lists the contribution to the source term from various radionuclides on a per Liter basis. Simple addition of these constituents yields an overall source term of 3.32 Curie/Liter. The values in Table B-1 are assumed to be listed for pure C-106 solids. The FDC states that the aerosol loading consists of 10% of C-106 solids and 90% AY-102 liquids. Therefore, every 3.57 Liter of aerosol entering the ventilation system contains the 0.357 Liter of C-106 solids in question.

Initial source term for shielding analysis is:

$$(0.357 \text{ Liter})(3.32 \text{ Curie/Liter}) = 1.185 \text{ Curie}$$

THIS CALCULATION IS SIMILAR TO REF. 1 EXCEPT FOR THE FOLLOWING: BECAUSE THE "TIME VOLUME" IN REF. 1 DID NOT INCLUDE THE REMOVAL EFFICIENCIES OF THE COMPONENTS UPSTREAM OF THE HEMF, IT WAS NOT USED. THE LIQUIDS IN REF. 1 ARE NOT USED, SINCE WE ARE ONLY INTERESTED IN THE SOLIDS THE HEMF WILL COLLECT.

**DESIGN ANALYSIS**

Client WHC

Subject High Efficiency Metal Filter  
shielding input and flushing frequency

Location 241-C/200 East

WO/Job No. ER4319

Date 6-8-94

Checked 6/13/94

Revised

By PH Langowski

By *B. Bree*

By

3.2 Flushing Frequency Based on Dose

Activity levels by radionuclide as used in ref. 3 along with the mass flow accumulated on the HEMF as shown in ref. 2 are repeated on an Excel spreadsheet in App. A. This spreadsheet then calculates the accumulated dose rate on the HEMF. As modeled, the HEMF will reach the 1.185 Curie level after 72 days of operation (2.4 months). The shielding is designed to mitigate the 1.185 Curie field to 10 mR/h as required by the FDC (ref. 4, p. E-3). Therefore, the HEMF will require flushing every 72 days so as to not exceed the FDC imposed limits. The nonradioactive components at this 1.185 Curie level will total 180 grams.

3.3 Flushing Frequency Based on Pressure

3.3.1 Clean Pressure Drop. Based on information from Pall (see App A), using a HEMF with the following dimensions (A=16", B=38", C=68", vessel volume=36 gallons) yields a 6" w.g. pressure drop at 500 acfm and a 3" w.g. pressure drop at 250 acfm. Pressure drop is known to be linear in clean filters (see Pall Brief in App A).

$$250 \text{ acfm}/3" \text{ w.g.} = 83 \text{ acfm}/1" \text{ w.g.}$$

$$180 \text{ acfm} = 2.16" \text{ w.g.}$$

$$230 \text{ acfm} = 2.76" \text{ w.g.}$$

$$360 \text{ acfm} = 4.32" \text{ w.g.}$$

3.3.2 Dirty Pressure Drop. Based on information from Pall (see App A) a prototype was run at 87 acfm and 7" w.g. clean and then loaded with 19.5 grams of dust and run to a final pressure of 10.5" w.g.

$$(360/87)(19.5 \text{ g}) = 80.7 \text{ g on a unit scaled for 360 acfm at 10.5" w.g. instead of 87 acfm.}$$

$$(7/4.5)(80.7 \text{ g}) = 125.5 \text{ g on a unit scaled for a 4.5" clean pressure drop instead of 7" w.g. clean pressure drop.}$$

$$(125.5/200)(4.5" \text{ w.g.}) = 2.82" \text{ w.g. clean pressure drop if sized for 200 grams loading at 10.5" w.g.}$$

Based on this information, the limiting sizing factor for a 360 acfm unit with 4.5" w.g. maximum clean pressure drop requirement and 10.5" w.g. dirty pressure drop with 200 grams loading will be the dust loading capability. Therefore, the HEMF will be sized by the manufacturer to meet the more stringent dust loading capability requirement.

4.0 FINDINGS & CONCLUSIONS

The HEMF will require flushing based on dose every 72 days. The HEMF pressure drop at this dose due to the nonradioactive components will be the limiting design constraint around which the HEMF specification (W-320-P3) is written.

APPENDIX A

Chd B - Ric 6/13/94

Form 5007 (Rev. 4/93)

<b>Raytheon</b> Engineers & Constructors A Consolidation of Beacor and URS&S  PROJECT <u>241-C-106 Waste Retrieval</u>  SUBJECT <u>Dose Consequences and EHSC</u> <u>Calculations for Determining</u> <u>Safety Classification</u>	GENERAL COMPUTATION SHEET			CALCULATION SET NO. 7362-H-005		REV. 0	CORR. BY NTV	CHK'D BY DGH
	PRELIM.	FINAL X	VOID	DATE 1-11-94		DATE 1-11-94		
	SHEET 3 OF 38			DATE _____		DATE _____		
	J.O. 7362.007							

Table A-2. Unit Liter Release Dose Calculation for Onsite Individual Without Plume Meander

Onsite	EDE, rem/liter (solids)	EDE, rem/liter (supernatant)
Inhalation	4.37E+1	3.42E-2

Table A-3. Unit Liter Release Dose Calculation for Onsite Individual With Plume Meander

Onsite	EDE, rem/liter (solids)	EDE, rem/liter (supernatant)
Inhalation	1.40E+1	1.10E-2

- Per Section 4.2 of Onsite/Offsite Worker Definition (issued as draft for comment by Westinghouse Savannah River Company), a two hour evaluation period is recommended for all offsite calculations to the general public.
- Per Items 9 and 10 of Section 4.2.1, Chapter 4.0 of *Nonreactor Facility Safety Analysis Manual*, WHC-CM-4-46 (Ref. 7), only inhalation and submersion pathways are considered for determining the offsite individual EDE values, as well as for onsite individual EDE values. Per *Safety Classification of Systems, Components, and Structures*, WHC-CM-5.46 (Ref. 8), only EDE values are needed to determine the safety classification of systems, equipment and components.
- Design data for process systems that are considered for the accident analyses are taken from WHC-SD-W320-FDC-001, Rev. 2, Ref. 12.
- It is assumed that the solids/sludge within the Tank AY-102 are not disturbed during sluicing from C-106 to AY-102.
- A ground level point source release is assumed for all the accident scenarios.
- The radioactive inventories included in Appendix B of Ref. 13 for C-106 and AY-102 (with AY-101 supernatant, see Criteria 1 and 14) are best available representative laboratory samples as stated in Appendix C of Ref. 13.

P. A3  
*old P. Rico 6/13/94*

Form 5007 (Rev. 4/93)

<b>Raytheon</b> Engineers & Constructors A Subsidiary of Bechtel and URS  PROJECT <u>241-C-106 Waste Retrieval</u>  SUBJECT <u>Dose Consequences and EHSC Calculations for Determining Safety Classification</u>	GENERAL COMPUTATION SHEET			CALCULATION SET NO. 7362-H-005	REV. 0	COMP. BY <i>RFV</i> DATE 1-11-94	CHK'D BY <i>RFV</i> DATE 1-11-94
	PRELIM.	FINAL X	VOID	SHEET 32 OF 38		DATE	DATE
	J.O. 7362.007						

Table B-1 Radionuclide Source Term (Ref. 13)

ISOTOPE	C-106, SLUDGE (See Notes below)		AY-102, SUPERNATANT(See Notes Below)	
	Bq/L	CURIES/L	Bq/L	CURIES/L
Am-241	5.56E+7	1.50E-3		
C-14	1.23E+4	3.32E-7		
Co-60	4.50E+7	1.22E-3		
Cs-137	1.75E+10	4.73E-1	4.03E+9	1.09E-1
I-129	4.29E+3	1.16E-7		
Pu-239/240	1.42E+8	3.84E-3		
Sr-90	1.05E+11	2.84E+0		
Tc-99	1.16E+7	3.14E-4		
U-238	1.53E+4	4.14E-7		

*3.32*

Notes

1. Values are taken from Ref. 13, See Table C-7 for AY-102 (with AY-101 supernatant) and Table C-9 for C-106 solids
2. Per Criterion 14 on Sh. 5, C-106 will have supernatant from AY-101 via AY-102.
3.  $\text{Curies/L} = (\text{Bq/L}) / (3.7 \times 10^{10})$

### HEMF Sizing Matrix

Flow Rate  
(ACFM) ↓

↓ Dec-93

100

250

500

	Dimensions:	Nozzles:	Dimensions:	Nozzles:	Dimensions:	Nozzles:
2	A: 8" B: 52" C: 78" Vessel Volume: 12	N1: 2" N2: 2" N3: 1" N4: 2"	A: 16" B: 38" C: 68" Vessel Volume: 35	N1: 3" N2: 3" N3: 1" N4: 2"	A: 18" B: 62" C: 93" Vessel Volume: 72	N1: 6" N2: 6" N3: 1" N4: 3"
3	A: 8" B: 36" C: 62" Vessel Volume: 8.5	N1: 2" N2: 2" N3: 1" N4: 2"	A: 16" B: 38" C: 68" Vessel Volume: 36	N1: 3" N2: 3" N3: 1" N4: 2"	A: 20" B: 47" C: 78 Vessel Volume: 67	N1: 6" N2: 6" N3: 1" N4: 3"
4	A: 8" B: 36" C: 62" Vessel Volume: 8.5	N1: 2" N2: 2" N3: 1" N4: 2"	A: 14" B: 37" C: 67" Vessel Volume: 26	N1: 3" N2: 3" N3: 1" N4: 2"	A: 18" B: 46" C: 77" Vessel Volume: 54	N1: 6" N2: 6" N3: 1" N4: 3"
5	A: 8" B: 36" C: 62" Vessel Volume: 8.5	N1: 2" N2: 2" N3: 1" N4: 2"	A: 14" B: 37" C: 67" Vessel Volume: 26	N1: 3" N2: 3" N3: 1" N4: 2"	A: 18" B: 46" C: 77" Vessel Volume: 55	N1: 6" N2: 6" N3: 1" N4: 3"
6	A: 8" B: 36" C: 62" Vessel Volume: 8.5	N1: 2" N2: 2" N3: 1" N4: 2"	A: 8" B: 52" C: 78" Vessel Volume: 12	N1: 3" N2: 3" N3: 1" N4: 2"	A: 16" B: 38" C: 68" Vessel Volume: 36	N1: 6" N2: 6" N3: 1" N4: 3"
7	A: 8" B: 20" C: 46" Vessel Volume: 5	N1: 2" N2: 2" N3: 1" N4: 2"	A: 8" B: 52" C: 78" Vessel Volume: 12	N1: 3" N2: 3" N3: 1" N4: 2"	A: 16" B: 38" C: 68" Vessel Volume: 36	N1: 6" N2: 6" N3: 1" N4: 3"

Vessel Volumes in Gallons

Note: Dimensions Refer To Drawing No. SKA-PASS-HEMF-012

**Pall Corp. Confidential**

This Information Is The Property Of Pall Corporation. And Is Furnished For Use Of The Assigned Recipient Only. No Copies Are To Be Made Of The Material Contained Herein And It Is Not To Be Divulged To Others. Either Within Or Outside Pall Corporation Without Specific Approval Of An Officer Of Pall Corporation.

W-320  
 ckd G. Que 6/13/94  
 AS

REVISION	DATE

# Pall High Efficiency Metal Filter


REMOVAL EFFICIENCY: 99.97% @ 0.3 MICRONS

MATERIALS OF CONSTRUCTION:

HOUSING: 304 SS  
 ELEMENTS: 316L SS

NOZZLES:

- N1: INLET
- N2: OUTLET
- N3: CLEANING INLET
- N4: CLEANING DRAIN



		UNLESS OTHERWISE SPECIFIED ALL DIMENSIONS ARE IN INCHES.	
SURFACE FINISH <input checked="" type="checkbox"/> POLISHED <input type="checkbox"/> ANTI-CORROSION	DIMENSIONS TOL. ± .005 ± .010 ± .015 ± .020 ± .030 ± .040 ± .050 ± .060 ± .070 ± .080 ± .090 ± .100 ± .125 ± .150 ± .175 ± .200 ± .250 ± .300 ± .375 ± .450 ± .562 ± .700 ± .875 ± 1.000 ± 1.250 ± 1.500 ± 1.875 ± 2.250 ± 2.750 ± 3.375 ± 4.000 ± 4.750 ± 5.500 ± 6.375 ± 7.250 ± 8.250 ± 9.375 ± 10.500 ± 11.750 ± 13.125 ± 14.625 ± 16.250 ± 18.000 ± 20.000	FINISH POLISHED ANTI-CORROSION	DIMENSIONS TOL. ± .005 ± .010 ± .015 ± .020 ± .030 ± .040 ± .050 ± .060 ± .070 ± .080 ± .090 ± .100 ± .125 ± .150 ± .175 ± .200 ± .250 ± .300 ± .375 ± .450 ± .562 ± .700 ± .875 ± 1.000 ± 1.250 ± 1.500 ± 1.875 ± 2.250 ± 2.750 ± 3.375 ± 4.000 ± 4.750 ± 5.500 ± 6.375 ± 7.250 ± 8.250 ± 9.375 ± 10.500 ± 11.750 ± 13.125 ± 14.625 ± 16.250 ± 18.000 ± 20.000
DRIVEN BY PNEUMATIC ELECTRIC RELEASED	TYPE 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50	CLEANING INLET CLEANING DRAIN INLET OUTLET	THE INFORMATION IN THIS CATALOG IS THE PROPERTY OF PALL CORPORATION. IT IS TO BE USED ONLY FOR THE PURCHASE OF PALL PRODUCTS. IT IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF PALL CORPORATION.
SCALE: 1/8" = 1"		ASSY, HEMF	
PALL UNPATENTED SEPARATION SYSTEMS A DIVISION OF PALL CORPORATION 1000 W. 10TH AVENUE DENVER, CO 80202		PALL UNPATENTED SEPARATION SYSTEMS A DIVISION OF PALL CORPORATION 1000 W. 10TH AVENUE DENVER, CO 80202	

## BACKGROUND

Test of dust holding capacity and efficiency of a Pall metal HEPA grade filter per ASHRAE Standard 52-76 is summarized in a recent report, (see Technical Brief HEMF-IV which follows). Testing was carried out by Air Filter Testing Laboratories, Inc. (AFTL).

The tested filter was subsequently cleaned by backwash with water. It has been retested per ASHRAE Standard 52-76, and the results are reported herein.

## FILTER REGENERATION

The contaminant laden filter was shipped from AFTL to Pall's facilities in Cortland, New York, for backwash cleaning. The outlet end of the filter was mounted to a tube sheet connected via 2" pipe to a pressure vessel. An in-line ball valve at the filter outlet was used to control (reverse) flow of water. The tube sheet was so positioned to suspend the filter into an open 55 gallon drum to facilitate visual inspection of the filter during cleaning procedures. Differential pressure across the filter in reverse flow was thus against atmosphere, and it was measured using a pressure gauge installed close to the tube sheet.

Backwash cleaning consisted of the following sequence.

1. Static soak 15 minutes in water.
2. Reverse flush with water at 2 psid for 50 seconds. Some loosening of contaminant was noted visually. An estimated 10% of the contaminant was dislodged.
3. Reverse flush with water at 8 psid for 10 seconds. Substantial majority of the contaminant remaining evident to visual inspection was dislodged.
4. Reverse flush with water at 7 psid for 15 seconds. Little further cleaning apparent to visual inspection.

## RESULTS

After cleaning the filter as indicated above, Pall shipped it back to AFTL, where pressure drop vs. flow rate was measured prior to re-challenge in accordance with ASHRAE 52-76. Pressure drop as function of flow rate is given in Figure 1. At rated flow, pressure drop was 1.38" H<sub>2</sub>O. This compares with 1.3" H<sub>2</sub>O prior to initial challenge.

Re-challenge under conditions identical with those of cycle 1 showed an ingress of 371gm of ASHRAE test dust required post-backwash to produce terminal pressure differential of 10" H<sub>2</sub>O, as shown in Figure 2.

This compares with 374gm in cycle 1. As in cycle 1, effluent quality was superior to the cleanest measurable per ASHRAE Standard 52-76. The shape of Figure 2 is in close analogy with the corresponding curve generated during cycle 1, indicating comparable dynamics of contaminant accumulation.

## CONCLUSION

Backflush with water provided >99% regeneration of dust capacity, and near complete restoration of clean pressure drop. Excellent effluent quality was maintained, without measureable change resulting from backwash.

Figure 1. Clean Filter Device (After Cleaning)





Figure 2. Dust Fed vs. Resistance



ASHRAE TEST OF PALL METAL  
HEPA FILTERS

A test of dust holding capacity and filter efficiency of a Pall metal HEPA grade filter was performed per ASHRAE Standard 52-76, by the Air Filter Testing Laboratories, Inc. (AFTL), Crestwood, KY.

The following graphical data were provided directly to Pall's Scientific and Laboratory Services Department by AFTL. Testing was performed at rated flow, producing an initial pressure differential of 1.3" H<sub>2</sub>O.

Pressure drop as a function of flow rate is given in Figure 3.

Figure 3. Clean Filter Device





Figure 4. Dust Fed vs. Resistance



Pressure drop as a function of dust loading is given in Figure 4. Increase in differential is linear to approximately 4.3" H<sub>2</sub>O, after which an increase in rate is evident. This is consistent with cake formation, a well characterized plugging mechanism for glass fiber HEPA filters. In the present test, pressure drop increase accelerates apparently starting from the point at which cake within the pleats is deep enough to reduce effective surface area, increasing face velocity. This interpretation is also consistent with post-test visual inspection.

Per AFTL's Mr. David J. Murphy, 20 gm of ASHRAE dust found at the housing bottom at termination of air flow may have resulted either from settling during challenge; or have fallen off the element with flow termination.

Also per Mr. Murphy, effluent quality was superior to the cleanest measurable per ASHRAE Standard 52-76. Arrestance was recorded at 100%.

## BACKGROUND

On December 2-3, 1992, a group comprised of Hanford, Kaiser Engineering, Lawrence Livermore, and Pall personnel met at facilities of Pall Land and Marine Division (PLM), New Port Richey, Florida, to witness efficiency and backwash test of Pall's stainless steel Melter Off-Gas filter assembly for Battelle. Reported in PASS Technical Report 7, the assembly was shown before and after vigorous backwash to provide filter efficiency equivalent to two stages of HEPA filter in series<sup>(1)</sup>.

Also discussed were remaining test requirements for Pall's all stainless steel Zone 1 filter, to provide single stage HEPA equivalent efficiency. Revised test protocols for a "Fine Particle Dust Challenge," and "Moisture Challenge Test" were agreed to and circulated to all meeting participants. These are attached as Appendix 1. Pall agreed to undertake completion of these tests and to report by January 8, 1993.

Purpose of the Fine Particle test is to demonstrate dust holding capacity and filter regenerability without loss of integrity, following challenge using smaller diameter particles (more penetrating size distribution) than those found in ASHRAE Test Dust<sup>(2)</sup>. It should be noted that ASHRAE Test Dust is formulated to simulate ambient air-borne dust as encountered by filters in HVAC applications.

Present Tests of Pall metal filter technology to ASHRAE Standard 52.1-1992, performed by the Air Filter Test Laboratories, Inc., have been summarized<sup>(3)</sup>. The siliceous dust component of the ASHRAE contaminant is comprised of PTI SAE Fine Test Dust<sup>(4)</sup>.

Pall's Scientific and Laboratory Services Department (SLS) has carried out the Fine Particle Dust Challenge, and the results are herein reported. The Moisture Challenge Test has also been completed by SLS, and the results are reported in reference<sup>(5)</sup>.

## TEST METHODS


Test protocol is given in Appendix I, Section IIA, attached. Tests employed a Pall Zone 1 filter module, 6" OD by 15.75" in length. Note: The same filter was then tested by Moisture Challenge (Appendix I, Section IIB), without further cleaning or other treatment<sup>(5)</sup>.

HNF-2483, Rev. 0  
Page G-11

### 1. Fine Dust Challenge.

The Zone 1 module was housed downstream of a Pall Centrisep® unit designed to operate at 87 CFM plus 10% scavenge flow, in accordance with Appendix I. The test system is shown schematically in Figure 1.

Figure 1. Test Stand Configuration for Fine Dust Loading.



Challenge was carried out by educting PTI SAE Fine Test Dust at approximately 260 gm per hour to the upstream Centrisep unit via a venturi at sonic throat conditions, and a diffuser cone. Effluent of the Centrisep unit flowed directly to the Zone 1 filter. Pressure drop across the Zone 1 filter was monitored using a calibrated Magnehelic gauge.

Photographic views of the test stand are given as Photos A and B.

### 2. Contaminant Particle Mass/Size Distribution.

Mass distribution was monitored by isokinetic sampling in conjunction with a calibrated Particle Measuring Systems LAS-X laser spectrophotometer to measure particle counts influent to the Zone 1 filter (Figure 1).

In separate tests using the Figure 1 configuration but without the Zone 1 filter, the LAS-X counter was found to demonstrate a sharp distinction between PTI SAE Fine Test Dust and Centrisep effluent of this contaminant.

The LAS-X counter resolves particle diameter into 16 channels or "bins", to as small as 0.09 µm; the largest bin is >3.0 µm. Count in a given bin is reproducible to ±10%<sup>(0)</sup>. Two TSI Model 3302 diluters were used in series at a total 10,000 fold dilution, to prevent count sensor saturation.

- 3. PTI SAE Fine Test Dust removal efficiency of the Centrisep unit was measured at 88.1% by weight (11.9% transmission).
- 4. Particle counts with and without the Centrisep unit in place at equal dust aspiration rate are given in Table 2. Background counts prior to dust ingress were of the order of 10% in channels 1 - 3, and at  $\leq$  2% in higher channels.

Average counts per minute are virtually identical with and without Centrisep processing in the .09  $\mu$ m - 2  $\mu$ m ranges (bins 1 to 13), demonstrating 0% particle rejection. Between 2.5 and 3.0  $\mu$ m, 35% rejection of counts is demonstrated; >3  $\mu$ m the rejection rate is at 65%. These data indicate measureable efficiency for the Centrisep unit down into the 2.0 - 2.5  $\mu$ m diameter range.

The count and gravimetric efficiency data are consistent. Mass distribution is a cubic function of particle radius, and larger particles strongly predominate mass even at lower count.

By Coulter counter test, PTI reports the volume (i.e.

mass) of particles greater than 10  $\mu$ m in diameter in PTI SAE Fine Test Dust as 43%. Reported fraction greater than 20  $\mu$ m is 27%. This determination is made in liquid, under conditions to promote disagglomeration potentially more rigorous than the standard method in air (employed here) of transport through a converging/diverging nozzle under sonic conditions.

Thus, count data (Table 2) together with the substantial volume significance of particles >10  $\mu$ m in untreated dust, confirm Centrisep effluent particle mass distribution to be highly skewed toward smaller diameters. Centrisep processed dust is expected to be substantially more penetrating than untreated PTI SAE Fine Test Dust.

- 5. Fine Particle Dust load on the Zone 1 filter to 10" H<sub>2</sub>O differential was 19.5 gm. This is obtained by applying the gravimetric reduction factor measured for the upstream Centrisep unit to the total weight of dust aspirated.

Pressure drop vs. Fine Dust loading of the Zone 1 filter module is given as Figure 2. Linear trend of

Photo C. Representative Zone 1 module appearance at outset of Protocol IIA, Appendix I.




Photo D. Photographic record of appearance of tested element at conclusion of Protocol IIA, Appendix I.





Figure 2.  $\Delta P$  vs. Weight Loaded.



pressure drop increase at constant flow rate indicates a cake building mechanism of contaminant accumulation. Visual inspection of the element after dust loading showed a uniform color change consistent with that of the ingressed dust. However, no cake could be detected visually or at 10X magnification.

- 6. Particle counts taken during challenge are given in Table 3. Background counts prior to dust ingestion were at a level comparable with that reported in section 4, above.

Although total feed rate varied somewhat, % size (and therefore % mass) distribution (Table 3) was reproducible with that of Centrisep effluent in Table 2.

- 7. Maximum reverse pressure drop during backwashes is given in Table 1.




Photo E. Following dust loading to 10" H<sub>2</sub>O over clean pressure drop per test Protocol IIA, Appendix 1, the photographic record of appearance of tested element was prepared.

Table 2. Particle size distribution PTI SAE fine test dust with and without stripping by a Pall Centricep.

With Centricep Channel Numbers	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Channel range in $\mu\text{m}$	0.09-0.11	0.11-0.15	0.15-0.20	0.20-0.25	0.25-0.30	0.30-0.40	0.40-0.50	0.50-0.65	0.65-0.80	0.80-1.00	1.00-1.25	1.25-1.50	1.50-2.00	2.00-2.50	2.50-3.00	>3.0
Average count	73.17	190.3	372.3	384.7	323.2	526.1	390.3	356.8	209.5	156.8	112.2	68.83	74.5	34.58	20	34.58
% Total count	2.20	5.72	11.19	11.56	9.71	15.81	11.73	10.72	6.30	4.71	3.37	2.07	2.24	1.04	0.60	1.04
Without Centricep Channel Numbers	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Channel range in $\mu\text{m}$	0.09-0.11	0.11-0.15	0.15-0.20	0.20-0.25	0.25-0.30	0.30-0.40	0.40-0.50	0.50-0.66	0.65-0.80	0.80-1.00	1.00-1.25	1.25-1.50	1.50-2.00	2.00-2.50	2.50-3.00	>3.0
Average count	76	200	393	385	319	511	369	347	194	147	113	72	87	48	31	99
% Total count	2.23	5.89	11.60	11.37	9.42	15.07	10.89	10.24	5.71	4.33	3.32	2.12	2.57	1.41	0.92	2.91

Note: With Centricep = An average of 12 one minute counts.  
 Without Centricep = An average of 11 one minute counts.

W320-H-008

Project W-320 Mass Balance Analysis (see ref. 2 and 3 for stream numbers, mass flows, and DF assumptions)

Stream 15 HEMF/total pot

Radionuclide	activity (Ci/g)	flow (l/d/min)	flow (Ci/min)	flow (mCi/min)	total Curie	total flow (lpm)
C-14	4.46E+00	2.00E+01	2.00E-13	4.46E-11	2.07E-08	4.64E-04
Ce-60	1.13E+03	2.00E+03	2.00E-09	1.71E-09	2.07E-04	1.83E-04
Cr-50	1.37E+02	4.20E+06	4.20E-06	3.07E-06	4.35E-01	3.17E+00
Y-90	5.45E+05	4.20E+06	4.20E-06	7.71E-06	4.35E-01	7.98E-04
Tc-99	1.70E-02	3.40E+02	3.40E-10	2.00E-08	3.52E-05	2.07E+00
Sb-125	1.04E+03	2.20E+04	2.20E-08	2.12E-08	2.28E-03	2.19E+03
I-129	1.73E-04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Cs-137	8.66E+01	1.30E+06	1.30E-06	1.50E-05	1.38E-01	1.58E+00
mBa-137	5.38E+08	1.60E+06	1.60E-08	2.97E-12	1.66E-01	3.09E-01
Ce-144	3.19E+03	9.30E+08	9.30E-08	2.92E-08	9.63E-03	3.07E-03
Eu-154	2.73E+02	2.30E+04	2.30E-08	8.42E-08	2.39E-03	8.77E-03
Pu-239	6.20E-02	4.00E+03	4.00E-09	6.45E-05	4.14E-04	6.65E-04
Pu-240	2.28E-01	6.30E+01	6.30E-11	1.09E-06	6.52E-06	2.86E-02
Am-241	3.43E+00	3.60E+03	3.60E-09	1.09E-06	3.72E-06	1.03E-01
			1.14E-05	1.19E+00		14 milligrams

total = 1.19E Curie safety class 2 "trigger level"

Assume upstream components function properly (DF = 1.25 \* 3 \* 20 = 75)

time = 103,511 minutes  
1,725 hours  
72.4 months

Flush every 2 and one half months end on final decon before removal.

Assuming no removal upstream of the HEMF

1,390 minutes  
23 hours  
1 days

Administrative radiation measurements every day to verify permanent rad monitor.  
Administrative reading can be made on exterior of shielding. If less than 10 mR/h then criteria is met.

Stream 16 HEPA1  
HEMF/DF = 3000  
0.000395 Curie

Radiation Shielding Study had 50 mRem/hr contact on housing after 0.0682 Curie collected. 173 flushes of the HEMF. HEPA1 will not require changing out until the end of the project.

260 G. B. Grew 6/17/99

Page A11

W320H-008

Project W-320 Mass Balance Analysis (see ref. 2 and 3 for stream numbers, mass flows, and DF assumptions)

Stream 15 HEM/Fiscal pot

Contaminant	flow (mg/min)	total milligram
NH3	0.00E+00	0.00E+00
Al	9.00E-02	9.32E+03
Sh	5.80E-05	6.00E+00
As	2.20E-05	2.28E+00
Ba	4.30E-03	4.45E+02
Bi	4.70E-04	4.87E+01
B	3.00E-04	3.11E+01
Cd	3.00E-04	3.11E+01
Ca	1.60E-02	1.66E+03
Cr	2.40E-03	2.48E+02
Co	1.10E-05	1.14E+00
Cu	2.80E-04	2.90E+01
Fe	6.10E-02	6.31E+03
La	7.60E-03	7.87E+02
Pb	3.80E-03	3.93E+02
Mg	4.20E-03	4.35E+02
Mn	8.90E-03	9.21E+02
Hg	2.80E-04	2.90E+01
Ni	1.60E-03	1.66E+02
Pd	1.30E-04	1.35E+01
P	1.10E-02	1.14E+03
K	3.90E-03	4.04E+02
Sr	8.70E-06	9.01E-01
Si	4.00E-02	4.14E+03
Ag	9.60E-04	9.94E+01
Nb	5.10E-01	5.28E+04
Sr	1.30E-04	1.35E+01
U	7.50E-04	7.76E+01
Zn	2.50E-04	2.55E+01
Zr	2.20E-03	2.28E+02
CN	5.20E-05	5.38E+00
F	4.70E-03	4.87E+02
OH	5.90E-02	6.11E+03
PO3	1.20E-01	1.24E+04
SO3	6.50E-02	6.73E+03
NO3	4.10E-01	4.24E+04
NO2	1.10E-01	1.14E+04
ClO3	3.60E-03	3.93E+02
CO3	1.50E-01	1.55E+04
EDTA	2.60E-03	3.00E+02
HEPA	2.30E-03	2.38E+02
OHC	4.40E-02	4.55E+03
C-14	4.9E-11	0.64E-06
Cr-60	1.77E-09	1.83E-04
Cr-30	3.07E-05	3.17E+01
Y-80	7.71E-09	7.98E-04
Tc-99	2.03E-05	2.07E+00
Sb-125	2.12E-06	2.19E-03
P-129	0.00E+00	0.00E+00

Page 2 of 2

W320-H-008

Project W-320 Mass Balance Analysis (ref. 2.3 for stream numbers, flows, DF inputs, etc.)

Cs-137	1.50E-05	1.55E+00
mBe-137	2.97E-12	3.08E-07
Ce-144	2.92E-08	3.02E-03
Eu-154	8.42E-08	8.72E-03
Pu-239	6.45E-05	6.68E+00
Pu-240	2.76E-07	2.86E-02
Am-241	1.05E-06	1.09E-01

total = 1.743  
 180393  
 180  
 4.96  
 9.46

milligrams  
 grams  
 pressure drop from loading \* w.g.  
 total pressure drop \* w.g.  
 minutes  
 hours  
 days  
 months

Assume upstream components function properly  
 time = 103.511  
 1.725  
 72  
 2.4

$180393 / 103.511 = 1.74$  mg/min

Flush every 2 and one half months and on final decon before removal.

W320-28-011

Exhaust Skid Stack Sizing and Fan  
Sizing

# CALCULATION IDENTIFICATION AND INDEX

Page 1 of 1

Date

3-28-95

This sheet shows the status and description of the attached Design Analysis sheets.

Discipline 28/HVAC

WO/Job No. ER4319

Calculation No. <sup>28</sup> W320 H-011

Project No. & Name W-320 Tank 241-C-106 Waste Retrieval

**W320-28-011**

Calculation Item Exhaust Skid Stack Sizing and Fan Sizing

These calculations apply to:

Dwg. No. N/A

Rev. No. N/A

Dwg. No. N/A

Rev. No. N/A

Other (Study, CDR) Procurement Specifications:

W-320-P1 Exhaust Skid

Rev. No. preliminary

The status of these calculations is:

- Preliminary Calculations
- Final Calculations
- Check Calculations (On Calculation Dated )
- Void Calculation (Reason Voided )

Incorporated in Final Drawings?

Yes  No

This calculation verified by independent "check" calculations?

Yes  No

No

Original and Revised Calculation Approvals:

	Rev. 0 Signature/Date	Rev. 1 Signature/Date	Rev. 2 Signature/Date
Originator	<i>P.H. Langmuir</i> 3-28-95	<i>Danmyer</i> 2/13/96	
Checked by	<i>R. P. M. T.</i> 3/28/95	<i>R. P. M. T.</i> 2/13/96	
Approved by	<i>P.H. Langmuir</i> 3-28-95	<i>R. P. M. T.</i> 2/13/96	
Checked Against Approved Vendor Data		<i>Charles T. Li</i> 4/4/98	

### INDEX

Design Analysis Page No.	Description
i	Calculation Identification and Index
1	Objective, Design Inputs, Calculations
2-3	Calculations cont.
4	Findings & Conclusions
A1-A9	Appendix A: References, Psychrometric Chart, Vendor Data

# DESIGN ANALYSIS

Client WHC

Subject Exhaust Skid Stack Sizing &amp; Fan Sizing

WO/Job No. ER4319

Date 3-28-95

Checked 3/28/95

Revised

By PH Langowski

By *PH*

By

Location 241-C/200 East

## 1.0 OBJECTIVE

The objective of this calculation is to determine the stack sizing required for input to the Exhaust Skid procurement specification. The calculation shall also size the pressure drop on the Exhaust Skid for fan sizing input to the Exhaust Skid procurement specification and estimate heating coil and exhaust fan power requirements.

## 2.0 DESIGN INPUTS

### 2.1 CRITERIA AND SOURCE

DOE General Order 6430.1A

Functional Design Criteria WHC-SD-W320-FDC-001, rev. 2, 1/18/94

### 2.2 GIVEN DATA

1. Upstream pressure drop information from W320-H-018, rev. 1

### 2.3 ASSUMPTIONS

no major assumptions, see text for minor assumptions.

### 2.4 METHODS

Hand calculations.

### 2.5 REFERENCES

1. W320-P1 rev. 0 (IFA draft date 3-29-95) Procurement Specification, Exhaust Skid Ventilation Air Cleanup Trains
2. W320-H-018 rev. 1 Calculation, Pressure Loss Upstream of the Exhaust Skid
3. 1993 ASHRAE Fundamentals
4. SDC 5.1 rev. 7
5. W320-P41 rev. 0 (IFA draft date March 1995) Procurement Specification, Isokinetic Air Sampler Stack Monitor
6. 1985 ASHRAE Fundamentals

## 3.0 CALCULATIONS

### 3.1 Stack Sizing

Stack sizing was originally performed by offsite author based on 4" diameter stack, modeling the Exhaust Skid as a 9' tall building. The stack size was changed to a 6" diameter stack to facilitate support of the relocated stack monitor instruments directly on the stack (see ref. 5, App. A). The 6" stack size will be examined with the same logic per ASHRAE Fundamentals (ref. 3) Chapter 14 information except a 6' tall building air intake assumption shall be used instead of 9' tall. The nearest building air intake is not close enough to warrant attention. The 6" stack has a 7" diameter stack head (ref. 5).

The larger diameter stack size drops us below the recommended ASHRAE limit of 2000 fpm since  $180 \text{ cfm}/[(\pi)(7/12)^2/4]=674 \text{ fpm}$ , and at 360 cfm yields 1347 fpm. With a

# DESIGN ANALYSIS

Client WHC  
 Subject Exhaust Skid Stack Sizing & Fan Sizing  
 Location 241-C/200 East

WO/Job No. ER4319  
 Date 3-28-95  
 Checked 3/28/95  
 Revised  
 By PH Langowski  
 By *R. Pina*  
 By

7 mph wind speed (ref. 4) which equals  $(7)(5280)/60=616$  fpm, we find that  $V_e$  is not 1.5 times as high as the wind speed  $U_d$ . Using equation 24, it is seen that the additional downwash height  $h_d$  is equal to  $(2.0)(7/12)(1.5)(1)674/616=1.91$  ft.

Using Equation 25, the plume rise,  $h_r$ , is calculated as  $(3.0)(674/616)(7/12)=1.91$  ft. Equation 26 shows that  $h_r$  and  $h_d$  cancel each other out. The capped height of the stack above the fictional Exhaust Skid building,  $h_{sc}$ , is therefore determined using Equations 1 and 5 with the 1:5 slope. From Equation 1,  $R=6.5^{0.67}26^{0.33}=10.3$  ft. From Equation 5,  $L_r=(1)(10.3)=10.3$  ft. For the 1:5 sloping plume to not enter the recirculation region of Figure 3,  $h_{sc}$  must be greater than  $(26.5+10.3)/5=7.4$  ft. The total stack height must therefore be greater than the sum of the height of the building (6 ft.) and  $h_{sc}$ . Therefore, the total stack height must be greater than  $6+7.4=13.4$  ft. This minimum stack height will yield a suitable design. Ref. 5 shows a total stack and head height of 20'.

### 3.2 Exhaust fan sizing

From ref 2 calculation, the upstream pressure drops are as follows:

condition	minimum exhaust 180 scfm	maximum exhaust 360 scfm
clean & dry components	18.6" w.g.	24.4" w.g.
dirty & wet components	33.9" w.g.	34.5" w.g.

The pressure losses on the Exhaust Skid are estimated at 180 scfm as follows:

component	reference	loss in. w.g.
shutoff valve, 6"	ref. 6, 7-5, $C_o=0.50$ $(180)/[(\pi)(6/12)^2/4]=917$ fpm, $V_p=0.052$	$(0.50)(0.052)=0.026$
electric heating coil	ref. 2, similar to recirculation heating coil	0.060
transition to square	use $C_o=0.50$	$(0.50)(0.052)=0.026$
inlet test section, 24"x24"	assumed negligible	0.000
HEPA filter, 24"x24"	$(180/1000)(1)=0.18$ , assumes 1000 cfm size filter	0.18
combination test section, 24"x24"	assumed negligible	0.000

## DESIGN ANALYSIS

Client WHC  
 Subject Exhaust Skid Stack Sizing & Fan Sizing

WO/Job No. ER4319  
 Date 3-28-95 By PH Langowski  
 Checked 5/28/95 By *T. P. ...*  
 Revised By

Location 241-C/200 East

HEPA filter, 24"x24"	(180/1000)(1)=0.18, assumes 1000 cfm size filter	0.18
outlet test section, 24"x24"	assumed negligible	0.000
transition to round	assumed negligible	0.000
shutoff valve, 6"	ref. 6, 7-5, $C_o=0.50$ $(180)/[(\pi)(6/12)^2/4]=917$ fpm, $V_p=0.052$	(0.50)(0.052) =0.026
stack & duct misc., 6"	20'(0.3" w.g./100')	0.060
stack head, 7"	ref. 3, SD2-6, $C_o=1.00$	0.052
		total 0.610

18.6 + 0.6 = 19.2" w.g. at 180 scfm (clean & dry). Round down to 19" for use in ref. 1.

The pressure losses on the Exhaust Skid are estimated at 360 scfm as follows:

component	reference	loss in. w.g.
shutoff valve, 6"	ref. 6, 7-5, $C_o=0.50$ $(360)/[(\pi)(6/12)^2/4]=1833$ fpm, $V_p=0.210$	(0.50)(0.210) =0.105
electric heating coil	ref. 2, similar to recirculation heating coil, use 0.100 as heating coil sized for variable flow will probably have a higher pressure drop than normal at the high end.	0.100
transition to square	use $C_o=0.50$	(0.50)(0.210) =0.105
inlet test section, 24"x24"	assumed negligible	0.050
HEPA filter, 24"x24"	filter loaded to 4" w.g.	4.000
combination test section, 24"x24"	assumed negligible	0.050
HEPA filter, 24"x24"	filter loaded to 2" w.g. (note that the project documentation shows that the maximum allowable across both filters is 5.9" w.g.)	2.000
outlet test section, 24"x24"	assumed negligible	0.050

## DESIGN ANALYSIS

Client WHC  
 Subject Exhaust Skid Stack Sizing & Fan Sizing  
 Location 241-C/200 East

WO/Job No. ER4319  
 Date 3-28-95 By PH Langowski  
 Checked 3/28/95 By *R. P. ...*  
 Revised 2/13/96 By *Sammy ...* 2/13/96

transition to round	assumed negligible	0.000
shutoff valve, 6"	ref. 6, 7-5, $C_p=0.50$ $(360)/[(\pi)(6/12)^2/4]=1833 \text{ fpm}$ , $V_p=0.210$	(0.50)(0.210) =0.105
stack & duct misc., 6"	20' (1.0" w.g./100')	0.200
stack head, 7"	ref. 3, SD2-6, $C_p=1.00$	0.210
		total 6.975

$34.5 + 7.0 = 41.5$ " w.g. at 360 scfm (dirty, wet). Round up to 42" for use in ref. 1.

The brakehorsepower required is estimated based on vendor data (App. A) of fan operating at 360 acfm at 40.8" w.g. at 140F & density=0.0644 (309 scfm at density=0.075). The 5.95 bhp with a 90% efficiency motor is equivalent to a 6.61 hp motor requirement. A 7.5 hp nameplate motor should be sufficient.

### 3.3 Exhaust heating coil sizing, 60% relative humidity

The normal maximum heating coil size would be required for the case of 360 scfm entering air at 40F saturated and the design exiting condition of 60% relative humidity at 53F (see psychrometric chart, App. A). The enthalpy change between these two states is  $18.3 - 15.3 \text{ Btu/lb}_{da} = 3.0 \text{ Btu/lb}_{da}$ . At the entering density of  $12.696 \text{ ft}^3/\text{lb}_{da}$ , this yields (360 scfm)( $3.0 \text{ Btu/lb}_{da}$ )/( $12.696 \text{ ft}^3/\text{lb}_{da}$ ) = 85.07 Btu/min (5104 Btu/h, or 1.5 KW).

The maximum upset heating coil size would be required for the case of 360 scfm entering air at 120F saturated and the design exiting condition of 60% relative humidity at 139F (see psychrometric chart, App. A). The enthalpy change between these two states is  $131 - 119.5 \text{ Btu/lb}_{da} = 11.5 \text{ Btu/lb}_{da}$ . At the entering density of  $16.519 \text{ ft}^3/\text{lb}_{da}$ , this yields (360 scfm)( $11.5 \text{ Btu/lb}_{da}$ )/( $16.519 \text{ ft}^3/\text{lb}_{da}$ ) = 250.06 Btu/min (15,007 Btu/h, or 4.4 KW).

2.1

# DESIGN ANALYSIS

Client WHC  
Subject Exhaust Skid Stack Sizing & Fan Sizing  
Location 241-C/200 East

WO/Job No. ER4319  
Date 3-28-95  
Checked 3/28/95  
Revised 2/12/96

By PH Langowski  
By *R. King*  
By *Danny Engen* *E. King* 3/12/96

## 4.0 FINDINGS & CONCLUSIONS

The Exhaust Skid stack sizing of 20' total (including stack head) will be adequate.

The Exhaust Skid fan will be required to be selected for the following pressure loss conditions. The fan motor will be required to be approximately 7.5 hp.

	minimum exhaust	maximum exhaust
	180 scfm	360 scfm
design condition	19" w.g.	42" w.g.

The Exhaust Skid heating coil will be approximately 1.5 KW under normal operating conditions. In the upset condition, ~~21.4~~ KW will be required. The heating coil with SCR control shall be capable of operating across a power range up to ~~4.4~~ KW.

2 KW

APPENDIX A

HNF-2483, Rev. 0  
Page H-7

*Handwritten:*  
3-28-95  
RP 3/28/95

CHAPTER 14

AIRFLOW AROUND BUILDINGS

<i>Flow Patterns</i> .....	14.1	<i>Estimating Intake Contamination</i> .....	14.10
<i>Wind Pressures on Buildings</i> .....	14.3	<i>Exhaust Stack Design</i> .....	14.11
<i>Wind Effects on System Operation</i> .....	14.8	<i>Heat Rejection Equipment</i> .....	14.15
<i>Building Internal Pressure and Flow Control</i> .....	14.9	<i>Scale Model Simulation and Testing</i> .....	14.15
<i>Atmospheric Dispersion of Building Exhaust</i> .....	14.9	<i>Symbols</i> .....	14.16

**A**IRFLOW around buildings affects worker safety, process and building equipment operation, weather and pollution protection at inlets, and the ability to control environmental factors of temperature, humidity, air motion, and contaminants. Wind causes surface pressures that vary around buildings, changing intake and exhaust system flow rates, natural ventilation, infiltration and exfiltration, and interior pressure. The mean flow patterns and turbulence of wind passing over a building can cause a recirculation of exhaust gases to air intakes. This chapter contains information for evaluating flow patterns, estimating wind pressures and air intake contamination, and solving problems caused by the effects of wind on intakes, exhausts, and equipment. Related information can be found in Chapters 11, 13, 23, and 24 of this volume; in Chapters 25, 27, and 47 of the 1991 Applications volume; and in Chapters 26, 31, 36, and 37 of the 1992 Systems and Equipment volume.

FLOW PATTERNS

Buildings of an even moderately complex shape, such as L- or U-shaped structures formed by two or three rectangular blocks, can generate flow patterns too complex to generalize for design. To determine flow conditions influenced by surrounding buildings or topography, a wind tunnel or water channel test of scale models or tests of existing buildings are required. However, if a building is oriented perpendicular to the wind, it can be considered as consisting of several independent rectangular blocks. Only isolated rectangular block buildings will be discussed here. Hosker (1984, 1985) reviews the effects of nearby buildings.

The mean speed of wind approaching a building increases with height above the ground (Figure 1). Both the upwind velocity profile shape and its turbulence level strongly influence flow patterns and surface pressures. A stagnation zone exists on the upwind wall. The flow separates at the sharp edges to generate recirculating flow zones that cover the downwind surfaces of the building (roof, sides, and leeward walls) and extend for some distance into the wake. If the building has sufficient length  $L$  in the windward direction, the flow will reattach to the building (Figure 2) and may generate two distinct regions of separated recirculating flow—on the building and in its wake.

Surface flow patterns on the upwind wall are largely influenced by approach wind characteristics. Higher wind speed at roof level causes a larger stagnation pressure on the upper part of the wall than near the ground, which leads to downwash on the lower one-half to two-thirds of the building (Figure 1). On the upper one-quarter to one-third of the building, the surface flow is directed upward over the roof. For a building whose height  $H$  is three or four times the width  $W$  of the upwind face, an intermediate zone exist between the upwash and downwash regions, where the surface streamlines pass horizontally around the building. The

downwash on the lower surface of the upwind face separates from the building before it reaches ground level and moves upwind to form a vortex that can generate high velocities close to the ground. This ground level upwind vortex is carried around the sides of the building in a U shape (Figure 1b) and is responsible for the suspension of dust and debris that can contaminate air intakes close to ground level.

Recirculation and High Turbulence Regions

For wind perpendicular to a building wall, the height  $H$  and width  $W$  of the upwind building face determine the flow patterns shown in Figure 3. According to Wilson (1979), the scaling length  $R$  which combines these dimensions is:

$$R = B_s^{0.67} B_L^{0.33} \quad (1)$$

where  $B_s$  is the smaller and  $B_L$  the larger of the dimensions  $H$  and  $W$ . When  $B_L$  is larger than  $8B_s$ , use  $B_L = 8B_s$  in Equation (1). For buildings with varying roof levels or with wings separated by at least a distance  $B_s$ , only the height and width of the building face below the portion of the roof in question should be used to calculate  $R$ . Wilson (1976) indicates that for a flat-roofed building, the recirculation region maximum height  $H_c$  at location  $X_c$ , and reattachment lengths  $L_c$  and  $L_r$  shown in Figures 3 and 17 are:

$$H_c = 0.22R \quad (2)$$

$$X_c = 0.5R \quad (3)$$

$$L_c = 0.9R \quad (4)$$

$$L_r = 1.0R \quad (5)$$

The downwind boundary of the rooftop recirculation region may be approximated by a straight line sloping downward from  $H_c$  to the roof at  $L_c$ . The dimensions of the recirculation zones are somewhat sensitive to the intensity and scale of turbulence in the approaching wind. High levels of turbulence from upwind obstacles may decrease the coefficients in Equations (2) through (5) by up to a factor of 2. Turbulence in the recirculation region and in the approaching wind also causes the reattachment locations on Figure 2 to fluctuate.

To account for changes in roof level, penthouses, and equipment housings and enclosures, the scaling length  $R$  of each of these obstacles should be calculated from Equation (1) using the dimensions of the upwind face of the obstacle. The recirculation region for each obstacle may be calculated from Equations (2), (3), and (4). The length  $L_r$  of the recirculation region downwind from the obstacle, or from the entire building, is given by Equation (5), with  $R$  based on the dimensions of the downwind face of the obstacle. The high turbulence region boundary  $Z_2$  in Figure 17 follows a 1:10 (5.7°) downward slope from the top of the recirculation regions at  $X_c$  or  $L_c$ . When an obstacle is close to the

The preparation of this chapter is assigned to TC 2.5, Air Flow Around Buildings

AI

W320-A-01 Rev. 0 APR 3-83-95  
20 7/3/85




Fig. 1 Flow Patterns around Rectangular Building




Fig. 2 Surface Flow Patterns and Building Dimensions




Fig. 3 Flow Recirculation Regions and Exhaust to Intake Stretched String Distances (Wilson 1982)

AZ

W370-H011 REV 0 APR 3-28-9  
29 7/20/15

wind directions, when the exhaust is uncapped ( $\beta = 1$ ) and  $U_H > 0.5$ . A value of  $B_1 = 0.0204$  should be used if  $V_e/U_H$  or the stack is capped ( $\beta = 1$ ) and the wind is at  $45^\circ$  to the upwind wall, or if there is no significant atmospheric turbulence, for example, at roof level of high-rise buildings, or in flat rural surroundings (Wilson and Chui (1987), Chui and Wilson (1988)).

Equations (19), (20), and (21) imply that minimum dilution does not depend on the location of either the exhaust or intake, only on the distance  $S$  between them. This is true when exhaust and intake locations are on the same building wall or on the roof. The dilution may increase if the intake and exhaust are located on different faces, as indicated by the  $M$  factor in Equation (18). For roof exhausts with wall intakes, the results of Li and Meroney (1983) suggest that  $B_1 \approx 0.20$  in Equation (21).

For buildings less than about 330 ft high and also less than twice as high as the surrounding buildings, atmospheric turbulence makes a significant contribution to exhaust gas dilution. Wilson (1976, 1977) gives surface concentration contours for flat-roofed buildings in a simulated approach wind typical of an urban area. Flush vents with small exhaust velocity make these results suitable for estimates for capped exhaust stacks or louvered exhaust vents.

The effect of atmospheric turbulence is relatively insignificant for high-rise buildings taller than 330 ft and also twice the average building height for 3000 ft upwind. On these high-rise buildings, where the effects of atmospheric turbulence are small, Wilson and Chui (1987) found that maximum surface concentrations for 10-min exposures were two to ten times higher than on an equivalent low-rise building. A dilution coefficient of  $B_1 = 0.02$  should be used for high-rise buildings.

When exhaust from several collecting stations is combined in a single vent or in a tight cluster of stacks, the effective exhaust area  $A_e$  will increase, causing the minimum dilution in Equation (19) to decrease. To qualify as a cluster, the stacks must all lie within a two-stack diameter radius of the middle of the group. Stacks lined up in a row do not act as a single stack, as shown by Gregoric *et al.* (1982). However, the exhaust concentration  $C_e$  of each contaminant will decrease by mixing with other exhaust streams, and the plume rise will increase due to the higher momentum in the combined jets. For combined vertical exhaust jets, the roof level intake concentration  $C$  in Equation (12) will almost always be lower than the intake concentration caused by separate exhausts. Where possible, exhausts should be combined before release to take advantage of this increase in overall dilution.

### Critical Wind Speed and Dilution

At very low wind speed, the exhaust jet from an uncapped stack will rise high above roof level, producing a large exhaust dilution  $D_{min}$  at a given intake location. Likewise, at high wind speed, the dilution will also be large because of the longitudinal stretching of the plume by the wind. Between these extremes, a critical wind speed exists at which the least dilution will occur for a given exhaust and intake location. This critical, absolute minimum dilution  $D_{crit}$  may be used to determine if an exhaust vent will be safe under all wind conditions. The critical wind speed for an uncapped vertical exhaust ( $\beta = 1.0$ ) can be evaluated by finding the absolute minimum in Equations (19), (20), and (21). It is closely approximated by

$$U_{crit}/V_e = 2.9B_1^{-0.33}(S/A_e^{0.5})^{-0.67} \quad (22)$$

where  $U_{crit}$  is the critical wind speed producing the smallest minimum dilution for an uncapped vertical exhaust with negligible stack height. This critical dilution  $D_{crit}$  may be found by using Equation (22) in Equation (19). For  $S/A_e^{0.5} > 5$ , this minimum is closely approximated by

$$D_{crit} = 1 + 7.0B_1^{0.67}(S/A_e^{0.5})^{1.33} \quad (23)$$

The critical dilution in Equation (23) depends only on distance from the exhaust and not on the exhaust velocity  $V_e$ . However, increasing the exhaust velocity increases the critical wind speed in Equation (22), usually causing this worst-case critical dilution to occur less frequently.

To assess the severity of the hazard caused by intake contamination, it is useful to know how often the worst case  $D_{crit}$  is likely to occur. The number of hours per year during which the dilution is no more than a factor of 2 higher than the critical minimum value may be estimated from weather records by finding the fraction of time that the wind speed lies in the range from  $0.5 U_{crit}$  to  $3.0 U_{crit}$  (Wilson 1982, 1983). This fraction is then multiplied by the fraction of time the local wind direction lies in a sector  $\pm 22.5^\circ$  on each side of the line joining the exhaust and intake location.

## EXHAUST STACK DESIGN

Before discharge, exhaust contamination should be reduced by filters, collectors, and scrubbers. Central exhaust systems that combine flows from many collecting stations should always be used where safe and practical. By combining several exhaust streams, central systems dilute intermittent bursts of contamination from a single station. However, in some cases, separate exhaust systems are mandatory. The nature of the contaminants to be combined, the recommended industrial hygiene practice, and the applicable safety codes need to be considered. Halitsky (1966) and Briggs (1984) present methods for estimating the trajectory of jets and the subsequent dispersion of jet plumes.

Separate exhaust stacks should be grouped in a tight cluster to take advantage of the larger plume rise of the resulting combined jet. In addition, a single stack from a central exhaust system or a tight cluster of stacks allows building air intakes to be placed as far as possible from the exhaust location. As shown in Figure 3, the effective stack height  $h_e$  is the portion of the exhaust stack that extends above local recirculation zones and upwind and downwind obstacles. Wilson and Winkel (1982) demonstrated that stacks terminating below the level of adjacent walls and architectural enclosures do not effectively reduce roof-level exhaust contamination. To take full advantage of their height, stacks should be located on the highest roof of a building. Where architectural enclosures are used to mask rooftop equipment, stacks must extend above the height  $H_e$  of the flow recirculation zone over the enclosure to prevent exhaust contamination of equipment within the enclosure.

### Required Stack Exhaust Velocity

High stack discharge velocity and temperature increase plume rise and reduce intake contamination by increased jet dilution and by the elevated plume trajectory. However, high discharge velocity is a poor substitute for increased stack height.

As shown in Figure 15, stacks should have vertically directed uncapped exhaust jets. Stack caps which deflect the exhaust jet have a detrimental effect on both minimum dilution and critical wind speed. In any case, conical stack caps often do not eliminate rain, because rain does not usually fall straight down. Changnon (1966) shows that periods of heavy rainfall are often accompanied by high winds that deflect the raindrops under the cap and into the stack. A stack velocity of about 2500 fpm prevents condensed moisture from draining down the stack and keeps rain from entering the stack. Even when there are drains in the stack, the exhaust velocity should be maintained above 2000 fpm to provide adequate plume rise and jet dilution. Where stack condensate is corrosive, the body of the stack should be sized for a velocity of 1000 fpm.

AB

W320-H-01 Rev 0

18

or less, and a drain provided for the condensate (Anonymous 1964). The stack tip should have a converging cone (Figure 15B) to provide the required high-velocity discharge of 2000 to 3000 fpm. For intermittently operated systems, protection from rain and snow should be provided by stack drains as shown in Figures 15F through 15J.

**Stack Height to Avoid Exhaust Entrainment**

To avoid entrainment of exhaust gases into the wake, stacks must terminate above the flow recirculation height  $H_r$ . Where stacks or exhaust vents discharge within this recirculation region,




Fig. 15 Stack Designs Providing Vertical Discharge and Rain Protection

gases rapidly diffuse to the roof and may enter ventilation intakes or other openings. Figure 1 shows that this effluent will flow into the zone of recirculating flow behind the downwind face and will, in some cases, be brought back up onto the roof.

A high velocity exhaust with  $V_e$  at least 1.5 times as large as the wind speed  $U_H$  at roof height is essential not only to provide good initial dilution near the stack, but also to avoid stack wake downwash, which can reduce or eliminate plume rise. Downwash of the exhaust into the stack wake, shown in Figure 16, is caused by the low-pressure region which develops in the wake on the lee side of the stack. In situations where exhaust velocity cannot be maintained at a value larger than 1.5 times the wind speed, an additional downwash height  $h_d$  (see Figure 16) should be added to the stack height  $h_s$ . For a vertically directed jet from an uncapped stack ( $\beta = 1.0$ ), Briggs (1973) recommends

$$h_d = 2.0d(1.5\beta V_e / U_H) \quad (24)$$

for  $V_e / U < 1.5$ , where  $d = (4A_e / \pi)^{0.5}$  is the effective stack diameter. Rain caps are frequently used on stacks of gas-and oil-fired furnaces and package ventilation units. These units will have  $\beta = 0$ , so  $h_d = 3.0d$ , and this should be added to the nominal height  $h_s$  to avoid flue gas contamination of roof-mounted equipment and air intakes.

The design procedure for selecting an appropriate stack height starts by calculating the height  $H_r$  of a stack with a rain cap and, therefore, no plume rise. For an uncapped vertical exhaust, the minimum rise  $h_r$  of the bent-over exhaust jet is estimated, and the




Fig. 16 Reduction of Effective Stack Height by Stack Wake Downwash




Fig. 17 Design Procedure for Required Stack Height to Avoid Contamination (Wilson 1979)

A4

W3011-01 rev 28

capped height  $h_{sc}$  is lowered by an amount  $h_r$  to give credit for plume rise (see Figure 16).

The capped stack height  $h_{sc}$  required to avoid excessive exhaust gas reentry is estimated by assuming that the plume spreads upward and downward from  $h_{sc}$  with a 1:5 slope (11.3°), as shown in Figure 17. The first step is to raise the capped height  $h_{sc}$  until the lower edge of the 1:5 sloping plume avoids contact with all recirculation (zone 1) boundaries on rooftop obstacles such as air intake housings, architectural screens, or penthouses. The size of these recirculation zones, shown in Figures 3 and 17, are calculated using Equations (2), (3), and (4).

If air intakes are located on the downwind wall, the lower edge of the plume, sloping down at 1:5, must lie above the downwind edge of the roof when a nontoxic exhaust contaminant, such as an odor or water vapor, is being dealt with. For a toxic contaminant that requires a large dilution factor at the wall intake, the lower edge of the plume should lie above the flow recirculation zone in the wake downwind of the building. The boundary of the building wake recirculation, shown in Figures 1, 3, and 17, is defined by a horizontal line extending a distance  $L_r$  from the downwind edge of the roof. The recirculation length  $L_r$  is calculated from Equation (5).

For an uncapped stack, the plume rise  $h_r$  due to the vertical momentum of the exhaust is estimated from Briggs (1984) as

$$h_r = 3.0(V_e/U_H)d \quad (25)$$

where the wind speed  $U_H$  is the maximum design wind speed for which air intake contamination must be avoided. The required height  $h_r$  of the uncapped stack extending above local recirculation zones and obstacles is

$$H_S = h_{sc} - h_r + h_d \quad (26)$$

If the minimum recommended exhaust velocity of  $V_e = 1.5 U_H$  is maintained, plume downwash  $h_d = 0$ , and  $h_r = 4.5d$ ; thus, an uncapped stack can be made  $4.5d$  shorter than a capped one.

The largest flow recirculation, high turbulence, and wake regions occur when wind is normal to the upwind wall of the building. Required stack heights should be the largest of the heights determined for all four directions for which the wind is normal to a building wall.

### Estimating Critical Dilution for Exhaust Stacks

The geometric design for avoiding excessive contamination does not give any estimate of the worst case critical dilution  $D_{crit}$  between the stack and an air intake. In this section,  $D_{crit}$  will be estimated for a predetermined stack height.

An increase in stack height or in exhaust velocity ratio  $V_e/U_H$  reduces roof-level contamination by keeping the high concentrations on the plume centerline far enough above the roof so that the intakes see only intermittent concentrations in the fringes of the plume. In addition, stack height or high exhaust velocity increases the critical wind speed at which the absolute minimum dilution occurs. This higher critical wind speed often reduces significantly the number of hours per year that high intake contamination (i.e., low dilution) will be observed.

Using a Gaussian plume dispersion equation, with a plume spread standard deviation of 0.14S, and an uncapped vertical exhaust jet with no buoyancy and with plume rise inversely proportional to wind speed, the critical wind speed  $U_{crit}$  at which the smallest minimum dilution  $D_{crit}$  observed is

$$\frac{U_{crit,0}}{U_{crit}} = (Y + 1)^{0.5} - Y^{0.5} \quad (27)$$

where  $U_{crit,0}$  is the critical wind speed for a flush (zero stack height) vertical exhaust, computed from Equation (22). The influence of stack height on the worst case critical dilution for the standard 10-min exposure time may be calculated from

$$\frac{D_{crit}}{D_{crit,0}} = \frac{U_{crit}}{U_{crit,0}} \exp[Y + Y^{0.5}(Y + 1)^{0.5}] \quad (28)$$

where  $Y = 12.6(h_r/S)^2$ , and  $D_{crit,0}$  is the dilution at critical wind speed for a flush vertical exhaust with no stack height, from Equation (23). Equations (27) and (28) are reliable only for  $Y < 2.0$ . Close to the stack, where  $Y > 2.0$ , use  $Y = 2.0$  in Equations (27) and (28). Because both wind speed and turbulence intensity vary strongly with height above the building roof, the plume rise of the exhaust jet may not be inversely proportional to wind speed; normally its behavior is between  $\Delta h \propto U^{-0.4}$  and  $U^{-1.0}$ . Thus, Equations (27) and (28) are only approximations. Because buoyancy is not included, the added rise due to buoyancy provides a factor of safety, particularly at low wind speed.

Because Equations (27) and (28) give the effect of a stack relative to a flush exhaust with  $h_r = 0$ , they are useful for assessing the advantages of increasing stack height as a remedial measure. By comparing two different heights, this calculation allows the relative benefits of a stack to be estimated without knowing any details of the contaminant concentrations or exhaust velocity in the existing stack. For example, the stack height required using the simple geometrical design procedure in the following section will have  $h_r/S$  of at least 0.2. Equations (27) and (28) show that the critical wind speed  $U_{crit}$  for this stack height will be about a factor of 2 larger, and the critical dilution  $D_{crit}$  about eight times more than for the vertical jet from an uncapped exhaust with zero effective stack height.

**Example 1.** The stack height  $h_r$  of the uncapped vertical exhaust on the building shown in Figure 3 must be specified to avoid excessive contamination of air intakes A and B by stack gases. The stack has a diameter  $d$  of 1.64 ft and an exhaust velocity  $V_e$  of 1770 fpm. It is located 52.5 ft from the upwind edge of the roof. The penthouse has its upwind wall (with intake A) located 98.4 ft from the upwind edge of the roof, a height of 13.1 ft, and a length of 23.0 ft in the wind direction. The top of intake A is 6.56 ft below the penthouse roof. The building has a height  $H$  of 49.2 ft and a length of 203 ft. The top of intake B is 19.7 ft below roof level. The width (measured into the page) of the building is 164 ft, and the penthouse is 29.5 ft wide. What are the required stack heights  $h_r$  for both nontoxic and highly toxic exhaust contaminants for a design wind speed specified at a factor of 2 higher than the annual average hourly wind speed of 9.32 mph at a nearby airport with anemometer height  $H_{ref}$  of 32.8 ft? The building is located in unshielded suburban terrain.

**Solution:** The first step is to set the height  $h_{sc}$  of a capped stack by projecting lines with 5:1 slopes upwind from points of potential plume impact. For intake A, the highest point of impact is the top of the recirculation zone on the roof of the penthouse. To find the height of this recirculation zone, start with Equation (1).

$$R = (13.1)^{0.67}(29.5)^{0.33} = 17.2 \text{ ft}$$

Then use Equations (2) and (3):

$$H_c = 0.22(17.2) = 3.77 \text{ ft}$$

$$X_c = 0.5(17.2) = 8.60 \text{ ft}$$


With the 5:1 slope of the lower plume boundary shown in Figure 17, the capped stack in Figure 3 must be

$$h_{sc} = 0.2(98.4 - 52.5 + 8.60) + 3.77 = 14.7 \text{ ft}$$


above the penthouse roof to avoid intake A. For intake B on the downwind wall, the plume boundary from the stack in Figure 3 must lie above the end of the roof for nontoxic exhaust gas or the end of the building flow recirculation zone for highly toxic exhaust gas. For this recirculation zone, from Equation (1):

AS


W3




PARTIAL PLAN (EXHAUST SKID)




EXHAUST RADIATION MONITORING CAB FRONT VIEW B



EXHAUST RADIATION MONIT CAB/EXH STACK ARR. VIEW A



DETAIL 1  
ENLARGED VIEW



CABINET MOUNTING DETAIL

BEST AVAILABLE COPY

NOTES:  
1. TUBES TO BE INSTALLED BY OTHER PERSONNEL FROM RADIATION MONITORING CABINET.

FROM W320-P4

rev 0  
ITF Mod 95

FIGURE 4  
EXHAUST RADIATION MONITORING  
CABINET/EXH STACK

PAGE 22

AB


W320

Call rev 0 PRR  
3-28-85

7/2 3/24/85

THE NEW YORK BLOWER COMPANY

=FAN=TO=SIZE=



FAN INFORMATION

Pressure Blower - AL  
 Belt Drive MATL: Alumin  
 Size: 2606  
 Tag : **2DT**  
 Date: 3/1/1994  
 CFM : 360 SP : 40.80  
 OV : 1800 *why not 40*  
 RPM : 3406 BHP: 5.95  
 DEN : 0.0644  
 TEMP: 140 DEG F  
 SE : 38.6% ME : 38.8%  
 \*\* LEFT-OF-PEAK \*\*

CUSTOMER

EXHAUST SKID  
 3/4/94 J Thomas  
 91044-013  
 PAGE 13 OF 13  
 W320-4-011

YOUR REPRESENTATIVE

VIKING SALES COMPANY INC.

P.O. BOX 80065  
 ALBUQUERQUE, NM  
 87198  
 Phone: (505) 268-8939  
 FAX : (505) 268-8908

A7





ASHRAE PSYCHROMETRIC CHART NO. 1

NORMAL TEMPERATURE  
BAROMETRIC PRESSURE 29.921 INCHES OF MERCURY  
COPRIGHT 1963



SEA LEVEL

AMERICAN SOCIETY OF HEATING, REFRIGERATING AND AIR-CONDITIONING ENGINEERS, INC.



AF  
W3204-01 100 O RR 3-28-65  
3/29/65

## DISTRIBUTION SHEET

To Distribution	From JW Bailey	Page 1 of 1 Date 25 July 1998			
Project Title/Work Order Project W-320 Tank 106-C, HNF-2483, HVAC Calculations, Vol. 1		EDT No. 622241 ECN No. n/a			
Name	MSIN	Text With All Attach.	Text Only	Attach./ Appendix Only	EDT/ECN Only
JW Bailey W-320 Project Files		S2-48 R1-29			