*** RMIS View/Print Document Cover Sheet ***

This document was retrieved from the Boeing ISEARCH System.

Accession #: D196071696

Document #: SD-WM-DA-205

Title/Desc:
241AZ101 PUMP REMOVAL TROUGH ANALYSIS

OCT 18 1995
STA#3

ENGINEERING DATA TRANSMITTAL

1. EDT 603710

To: (Receiving Organization)	3. From: (Originating Organization)	4. Related EDT No.:
Distribution	B. L. Coverdell H5-57 Analytical Services	NA
5. Proj./Prog./Dept./Div.:	6. Cog. Engr.:	7. Purchase Order No.:
C01909	M. E. Manthei S2-48	NA
8. Originator Remarks: Supporting document for review/release. (1) Computer Tape		9. Equip./Component No.: NA 10. System/Bldg./Facility: NA
11. Receiver Remarks:		12. Major Assm. Dwg. No.: H-2-83768 & H-2-83769 13. Permit/Permit Application No.: NA 14. Required Response Date: ASAP

15. DATA TRANSMITTED

(A) Item No.	(B) Document/Drawing No.	(C) Sheet No.	(D) Rev. No.	(E) Title or Description of Data Transmitted	(F) Approval Designator	(G) Reason for Transmittal	(H) Originator Disposition	(I) Receiver Disposition
1	WHC-SD-WM-DA-205	NA	0	241AZ101 PUMP REMOVAL TROUGH ANALYSIS	3QS	1	1	

16. KEY

Approval Designator (F)	Reason for Transmittal (G)	Disposition (H) & (I)
E, S, Q, D or N/A (see WHC-CM-3-5, Sec.12.7)	1. Approval 4. Review 2. Release 5. Post-Review 3. Information 6. Dist. (Receipt Acknow. Required)	1. Approved 4. Reviewed no/comment 2. Approved w/comment 5. Reviewed w/comment 3. Disapproved w/comment 6. Receipt acknowledged

17. SIGNATURE/DISTRIBUTION (See Approval Designator for required signatures)

(G) Reason	(H) Disp.	(J) Name (K) Signature (L) Date (M) MSIN	(J) Name (K) Signature (L) Date (M) MSIN	(G) Reason	(H) Disp.
1	1	Cog.Eng. M. E. Manthei M E Manthei 10/9/95 S2-48			
1	1	Cog. Mgr. J. E. Van Beek J E Van Beek 10/9/95 S2-48			
1	1	QA R E. Clayton R E Clayton 10/9/95 K9-33			
1	1	Safety G. E. McPherson G E McPherson S2-41			
		Env.			
1	1	AS Mngr. R. M. Boger R M Boger 9/29/95 H5-57			
1	1	Indep. Review J. L. Julyk J L Julyk 9/29/95 E6-46			

18. B. L. Coverdell 9-29-95
B. L. Coverdell
Signature of EDT Originator Date

19. M. E. Manthei M E Manthei 10/9/95
Authorized Representative for Receiving Organization Date

20. J. E. Van Beek J E Van Beek 10/9/95
Cognizant Manager Date

21. DOE APPROVAL (if required)
Ctrl. No.
[] Approved
[] Approved w/comments
[] Disapproved w/comments

BD-7400-172-2 (04/94) GEF097

THIS PAGE INTENTIONALLY
LEFT BLANK

RELEASE AUTHORIZATION

Document Number:	WHC-SD-WM-DA-205, REV 0
Document Title:	241AZ101 Pump Removal Through Analysis
Release Date:	10/17/95

This document was reviewed following the procedures described in WHC-CM-3-4 and is:

APPROVED FOR PUBLIC RELEASE

WHC Information Release Administration Specialist:

Kara Broz 10/17/95

Kara Broz

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

This report has been reproduced from the best available copy. Available in paper copy. Printed in the United States of America. To obtain copies of this report, contact:

Westinghouse Hanford Company - Document Control Services
P.O. Box 1970, Mailstop H6-08, Richland, WA 99352
Telephone: (509) 372-2420; Fax: (509) 376-4989

THIS PAGE INTENTIONALLY
LEFT BLANK

SUPPORTING DOCUMENT

1. Total Pages 81

2. Title	3. Number	4. Rev No.
241AZ101 PUMP REMOVAL TROUGH ANALYSIS	WHC-SD-WM-DA-205	0

5. Key Words	6. Author
Trough Truss Stress Analysis 241AZ101	Name: B. L. Coverdell BL Coverdell Signature Organization/Charge Code AS / C01909

7. Abstract

As part of the current Hanford mission of environmental cleanup, various long length equipment must be removed from highly radioactive waste tanks. The removal of equipment will utilize portions of the Equipment Removal System for Project W320 (ERS-W320), specifically the 50 ton hydraulic trailer system. Because the ERS-W320 system was designed to accommodate much heavier equipment it is adequate to support the dead weight of the trough, carriage and related equipment for 241AZ101 pump removal project. However, the ERS-W320 components when combined with the trough and its' related components must also be analyzed for overturning due to wind loads.

Two troughs were designed, one for the 20 in diameter carriage and one for the 36 in. diameter carriage. A proposed 52 in. trough was not designed and, therefore is not included in this document. In order to fit in the ERS-W320 strongback the troughs were design with the same widths. Structurally, the only difference between the two troughs is that more material was removed from the stiffener plates on the 36 in trough. The reduction in stiffener plate material reduces the allowable load. Therefore, only the 36 in. trough was analyzed.

8. **RELEASE STAMP**

OFFICIAL RELEASE
BY WHC
DATE OCT 18 1995
STA# 3

THIS PAGE INTENTIONALLY
LEFT BLANK

241AZ101 PUMP REMOVAL TROUGH ANALYSIS

September 29, 1995

PREPARED BY: B L Coverdell 9-29-95
B. L. Coverdell, Advanced Engineer DATE

REVIEWED BY: J L Julyk 9/29/95
J. L. Julyk, Engineer DATE

REVIEWED BY: James A Tuck 29 Sept. '95
J. A. Tuck, Advanced Engineer DATE

APPROVED BY: T C Mackey 9/29/95
T. C. Mackey, Principle Engineer DATE

APPROVED BY: R M Boger 9/29/95
R. M. Boger, Manager DATE

Westinghouse Hanford Company
Hanford Operations and Engineering Contractor
for the
U. S. Department of Energy
Richland, Washington

THIS PAGE INTENTIONALLY
LEFT BLANK

CHECKLIST FOR INDEPENDENT REVIEW

Document Reviewed 241AZ101 PUMP REMOVAL TROUGH (Overall Review)

Author B. L. Coverdell

Yes	No	N/A	
[✓]	[ ]	[ ]	Problem completely defined.
[✓]	[ ]	[ ]	Necessary assumptions explicitly stated and supported.
[✓]	[ ]	[ ]	Computer codes and data files documented.
[✓]	[ ]	[ ]	Data used in calculations explicitly stated in document.
[✓]	[ ]	[ ]	Data checked for consistency with original source information as applicable.
[✓]	[ ]	[ ]	Mathematical derivations checked including dimensional consistency of results.
[✓]	[ ]	[ ]	Models appropriate and used within range of validity or use outside range of established validity justified.
[✓]	[ ]	[ ]	Hand calculations checked for errors.
[✓]	[ ]	[ ]	Code run streams correct and consistent with analysis documentation.
[✓]	[ ]	[ ]	Code output consistent with input and with results reported in analysis documentation.
[✓]	[ ]	[ ]	Acceptability limits on analytical results applicable and supported. Limits checked against sources.
[✓]	[ ]	[ ]	Safety margins consistent with good engineering practices.
[✓]	[ ]	[ ]	Conclusions consistent with analytical results and applicable limits.
[✓]	[ ]	[ ]	Results and conclusions address all points required in the problem statement.

J. L. Julyk, Reviewer

9/29/95
Date

CHECKLIST FOR INDEPENDENT REVIEW

Document Reviewed WELD ANALYSIS (Appendix E)

Author B. L. Coverdell

Yes	No	N/A	
[✓]	[ ]	[ ]	Problem completely defined.
[✓]	[ ]	[ ]	Necessary assumptions explicitly stated and supported.
[✓]	[ ]	[ ]	Computer codes and data files documented.
[✓]	[ ]	[ ]	Data used in calculations explicitly stated in document.
[✓]	[ ]	[ ]	Data checked for consistency with original source information as applicable.
[ ]	[ ]	[✓]	Mathematical derivations checked including dimensional consistency of results.
[✓]	[ ]	[ ]	Models appropriate and used within range of validity or use outside range of established validity justified.
[ ]	[ ]	[✓]	Hand calculations checked for errors.
[✓]	[ ]	[ ]	Code run streams correct and consistent with analysis documentation.
[✓]	[ ]	[ ]	Code output consistent with input and with results reported in analysis documentation.
[✓]	[ ]	[ ]	Acceptability limits on analytical results applicable and supported. Limits checked against sources.
[✓]	[ ]	[ ]	Safety margins consistent with good engineering practices.
[✓]	[ ]	[ ]	Conclusions consistent with analytical results and applicable limits.
[✓]	[ ]	[ ]	Results and conclusions address all points required in the problem statement.

James A Tuck
J. A. Tuck, Reviewer

29 Sept. '95
Date

CONTENTS

Page

1.0 INTRODUCTION 1

2.0 SUMMARY OF RESULTS 1

3.0 DISCUSSION 2
3.1 CONSTRAINTS 2
3.2 CRITERIA 3
3.3 GEOMETRY 4
3.4 FINITE-ELEMENT MODEL 4
3.4.1 DEAD WEIGHT 5
3.4.2 LIVE LOADS 5
3.4.3 WIND LOAD 5
3.4.4 SNOW LOAD 5
3.4.5 SEISMIC LOAD 5
3.4.6 TRANSPORTATION LOAD 6
3.4.7 LOAD CASES AND LOAD CASE COMBINATIONS 6
3.5 OVERTURNING 7
3.6 NATURAL FREQUENCY DETERMINATION 7
3.7 EXCITATION FREQUENCY 7

4.0 RESULTS AND CONCLUSIONS 7
4.1 TROUGH STRUCTURAL MEMBERS 7
4.2 AISC CODE EVALUATION 8
4.3 WELD CONNECTION EVALUATION 8
4.4 OVERTURNING ANALYSIS 8
4.5 FREQUENCY ANALYSIS 8
4.6 TRANSPORTATION ANALYSIS 9
4.7 BOLTED CONNECTION ANALYSIS 9

5.0 REQUIREMENTS 9

6.0 REFERENCES 10

APPENDICES

Appendix A: Internal Memo from DST Retrieval Projects to T. C. Mackey A-1
Appendix B: Wind Load Calculations B-1
Appendix C: Finite-Element Analysis of 36 in. Trough C-1
Appendix D: AISC Code Check D-1
Appendix E: Welded Connection Evaluation E-1
Appendix F: Overturning Analysis F-1
Appendix G: Frequency Analysis G-1
Appendix H: Carriage Maximum Wheel Load Calculations H-1
Appendix I: Bolted Connection Analysis I-1

FIGURES

Figure 1: Load chart for the 50 ton hydraulic trailer when used with the 36 in. and 20 in troughs. 2

1.0 INTRODUCTION

As part of the current Hanford mission of environmental cleanup, various long length equipment must be removed from highly radioactive waste tanks. The removal of equipment will utilize portions of the Equipment Removal System for Project W320 (ERS-W320), specifically the 50 ton hydraulic trailer system. Because the ERS-W320 system was designed to accommodate much heavier equipment it is adequate to support the dead weight of the trough, carriage and related equipment for the 241AZ101 pump removal project. However, the ERS-W320 components when combined with the trough and its' related components must also be analyzed for overturning due to wind loads.

Two troughs were designed, one for the 20 in. diameter carriage and one for the 36 in. diameter carriage. A proposed 52 in. trough was not designed and, therefore is not included in this document. In order to fit in the ERS-W320 strongback the troughs were design with the same widths. Structurally, the only difference between the two troughs is that more material was removed from the stiffener plates on the 36 in trough. The reduction in stiffener plate material reduces the allowable load. Therefore, only the 36 in. trough was analyzed.

The scope of this task was to determine the structural adequacy of the 36 in. and 20 in. trough and the combined system of; the 241AZ101 trough, the carriage and the ERS-W320 hydraulic trailer system. Specific elements of this task were:

- Determine design loads.
- Determining the adequacy of structural members to support design loads.
- Evaluate welded connections for code compliance
- Evaluate connections between the trough and the strongback.
- Evaluate ERS-W320 hydraulic trailer system for overturning when combined with the lighter 241AZ101 equipment.
- Determine if coupling will occur between the trough's natural frequency and the excitation frequency due to wind (resonance).
- Evaluate the trough for transportation loads.

This design is in accordance with *Standard Architectural-Civil Design Criteria, Design Loads for Facilities* (DOE-RL 1993a) and is designated safety class 3. The design and fabrication is in accordance with the *Manual of Steel Construction* (AISC, 1989). The welding and weld inspection is in accordance with the *Structural Welding Code for Steel* (AWS 1994). The analysis of the structural components of the 241AZ101 troughs considers dead load and 125% of the live loads. An allowable stress of one-third yield is used for all critical structural components on the basis of requirements in DOE-RL 1993b. Adherence to DOE-RL 1993b is not a code requirement, however, this added factor of safety is appropriate.

2.0 SUMMARY OF RESULTS

The 20 in. and 36 in. trough shown on drawings H-2-83768 (WHC 1995b) and H-2-83769 (WHC 1995c) respectively, were found to be structurally adequate to accommodate the equipment removal efforts. The load chart in figure 1 shows the maximum possible loadings for the 241AZ101 equipment removal system. The allowable stresses were evaluated based on a safety factor of three applied to the yield stress of the material. Descriptions of the finite-element analyses as well as evaluations of the welds are contained in the appendices of this report. The input and output files for this model are archived on a ¼ in. magnetic tape.



SIDE VIEW, 50 TON HYDRAULIC TRAILER WITH 20' OR 36' TRUSS
NO CARRIAGE, EQUIPMENT OR RIGGING
MAXIMUM EQUIVALENT LOADING = 4,000 LB POINT LOAD



SIDE VIEW, 50 TON HYDRAULIC TRAILER WITH 20' OR 36' TRUSS AND CARRIAGE
MAXIMUM LOAD DISTRIBUTION (NOTE: MAXIMUM CARRIAGE WHEEL LOAD IS 2,100 LB)

Figure 1: Load chart for the 50 ton hydraulic trailer when used with the 36 in. and 20 in troughs.

3.0 DISCUSSION

The purpose for the 241AZ101 trough is to allow an existing piece of equipment, the 50 ton hydraulic trailer system designed for project ERS-W320, to be used in the removal of smaller pieces of equipment. The trough is designed to maximize the strength to weight ratio by using structural tubing as the main structural members. Where additional strength is required solid bars are used. The analysis was performed using COSMOS/M finite-element analysis software (SRAC 1994) on a Silicon Graphics, Indigo^2 workstation. A three dimensional model was created using a combination of beam elements and four noded shell elements.

3.1 CONSTRAINTS

The constraints listed below are used to provide physical limitations on the geometry and functionality of the equipment. The **Double Shell Tank Retrieval Projects** group provided a set of functional requirements (see Appendix A). These are used as the following design criteria:

- Each trough must interface with the strongback shown on drawing H-2-83717 (WHC 1994a).
- Each trough must accommodate the loads outlined in the Internal Memo shown in Appendix A (the 52 in. trough design is excluded).

- Both troughs must interface with the 36 in diameter carriage and 20 in carriage shown on drawings H-2-83768 (WHC 1995b) and H-2-83769 (WHC 1995c) respectively.
- The trough must accommodate the installation of equipment during removal activities.

3.2 CRITERIA

The design criteria define the position on the allowable stresses used in the 241AZ101 36 in. and 20 in. trough designs. The troughs are designed to meet the requirements of DOE-RL 1993b, however, this document is vague on the practical application of the allowable stresses for use in analysis and design. DOE-RL 1993b specifies basic allowables of one-third of tensile yield strength only.

So that all design/analysis personnel use a consistent set of limits, the following interpretation of DOE-RL 1993b will be used for the structural analysis of the 241AZ101 troughs. For combined stresses, the AISC 1989 approach will be used (see Chapter H of AISC 1989).

A36 Structural Steel F_y=36 kip/in^2

Bending (F_b), Tension (F_t) and Axial Compression (F_a - where buckling is not a concern and there are no bending moments):

$F_b = F_t = F_a = \frac{1}{3}F_y = 12$ kip/in^2

Shear:

$F_v = 0.4*F_y/2 = 7.2$ kip/in^2

Bearing:

$F_p = \frac{1}{3}F_y = 12$ kip/in^2

A500 Structural Tubing F_y=42 kip/in^2

Bending (F_b), Tension (F_t) and Axial Compression (F_a - where buckling is not a concern and there are no bending moments):

$F_b = F_t = F_a = \frac{1}{3}F_y = 14$ kip/in^2

Shear:

$F_v = 0.4*F_y/2 = 8.4$ kip/in^2

Bearing:

$F_p = \frac{1}{3}F_y = 14$ kip/in^2

Connections

Note: The bolting of the trough to the strongback shall be performed in accordance with WHC-SD-W320-DA-003 (WHC 1994b).

Note: The bolting of the carriage to the tough shall be performed in accordance with WHC-SD-TP-ANAL-005 (WHC 1995d).

Bolts: Use AISC 1989 allowables divided by 2

Welds: 7.2 kip/in^2 on effective area for A36 material and 8.4 kip/in^2 on effective area for A500 tube steel (effective area = effective throat times the weld length)
Special case for fillet welds on A36 material only - check stress on the weld leg, not the weld throat (do not use the 0.707 factor to determine throat area).

Discussion

Three considerations influenced the development of these allowables.

- DOE-RL 1993b refers to allowables based on yield strength only, not ultimate strength. Therefore, the allowables used herein are based on yield strength (i.e., 1/3 of yield). Some parameters, such as bearing, typically are expressed in terms of an ultimate failure condition. However, basing allowables on yield satisfies both DOE-RL 1993b and ANSI 1986. Also, selecting allowables that are conservative is acceptable for the 241AZ101 pump removal project because it is new design; changes can be incorporated easily at the design stage.

- A popular interpretation of DOE-RL 1993b and ANSI 1986 permits uses of various ratios of the allowables specified in AISC 1989. Although AISC 1989 is a nationally recognized code for buildings constructed of structural steel, using it in conjunction with DOE-RL 1993b and ANSI 1986 requirements as the basis for material allowables results in inconsistencies in safety factors. Therefore, AISC 1989 is not used as the basis for structural steel allowables; instead, the allowables were developed exclusively from DOE-RL 1993b, ANSI 1986, and the first principles of failure theory. These allowables are more conservative than AISC 1989 allowables.

- A definitive interpretation of DOE-RL 1993b and ANSI 1986 allowables requires research into a variety of topics. To date, there are no firm commitments within Westinghouse to pursue a definitive interpretation of DOE-RL 1993b and ANSI 1986 allowables for use at the Hanford Site. This interpretation of allowables should be considered as conservative.

3.3 GEOMETRY

In order to achieve the best strength to weight ratio, AISC structural shapes in combination with stiffener plates located at regular intervals along the length of the trough were used. Several different sizes of either angle, structural tubing and bar are used to provide the needed strength (see drawings WHC 1995b and WHC 1995c). Structural tubing was used in most places, however, solid bars were used in areas of anticipated high stress. In the analysis the angle shapes and the two 2 ½ x 1 ½ x 3/16 in. tube steel back to back were also considered a structural component of the trough. This was done to ensure that they would be adequate supports for the carriage.

3.4 FINITE-ELEMENT MODEL

The finite-element model was generated using the finite-element code COSMOS/M. The name of the finite-element model generated is AZTR_BLC11B. This model uses two major element types; the four noded SHELL4T element and the three noded BEAM3D element. A linear elastic analysis was performed on the structure using the load cases and load cases combinations listed in Section 3.4.7.

3.4.1 DEAD WEIGHT

The dead weight of the trough in the horizontal and vertical position was determined by applying a gravitational acceleration in the global negative Y direction and the global negative X direction respectively. When the trough is in the horizontal position the reaction of the strongback on the trough is significant. The strongback tends to "open" the trough while the trough resists and has the tendency to act in the opposite direction, "closing". To model this effect, an existing FEA model of the strongback was used. The model was modified by placing a small beam between the two upper trough attachment points and applying the reaction forces from the strongback to the trough. After the FEA model was run for solution, the tensile stress in the added beam was determined. The forces induced in the beam was incorporated into the trough model as part of the dead weight load to simulate the opening of the strongback.

3.4.2 LIVE LOADS

Two live loads were considered; 1) The combination of a 4,200 lbf uniform load distributed over the length of the trough and a 2,000 lbf point load applied at the top end of the trough. 2) A 5,000 lbf point load applied at the top end of the trough.

The combination of the 4,200 lbf distributed load and the 2,000 lbf point load represents the weight of the 36 in. carriage, bagging, rigging and any extra equipment (see Appendix A). The 5,000 lbf point load at the top end of the trough represents the equivalent loading of a 4,200 lbf uniform load plus the 2,000 lbf point load at the top end of the trough. It is also used to represent the maximum rated point load of 4,000 lb at the top end of the trough. A 125% impact factor is used (1.25 x 4,000 lb = 5,000 lbf) to verify that the trough is load tested for 5,000 lbf resulting in a 4,000 lbf load rating.

3.4.3 WIND LOAD

The most conservative method for calculating the wind load pressure distribution is to use the surface area of the carriage device. The calculations for determining the linear pressure load to apply to the FEA model are shown in Appendix B. From ASCE 1993, the minimum wind pressure loading was determined to be 10 lbf/ft^2. A linear pressure loading of 2.5 lbf/in was calculated and applied to the FEA model in two load cases over the entire 770.5 in. length of the trough. The first location was on the lower chord of the trough and the second location was on one of the upper chords of the trough.

3.4.4 SNOW LOAD

Since the trough and related equipment are not to be used during snow conditions, snow loading was not considered in this analysis.

3.4.5 SEISMIC LOAD

Seismic loads are not considered for the trough supporting the 36 in. carriage, its related equipment and the bag and rigging (see Appendix A) in the horizontal position. The reason for this is

that the 1.5*g* transportation load will govern. In the vertical position seismic loads are not considered due to the short period that the trough and related equipment will be vertical.

3.4.6 TRANSPORTATION LOAD

For transportation, the *Code of Federal Regulations* (DOT 1989) requires that a 1.5*g* acceleration be considered in the vertical, lateral and longitudinal directions. This load is applied to the horizontal trough and it will not be combined with any other loads, since, the trough is transported empty. Another consideration is that the horizontal trough is supported in three places; the lower strongback attachment point, the upper strongback attachment point and the top of the trough itself. However, in the FEA only the attachments to the strongback are modelled. This is conservative.

3.4.7 LOAD CASES AND LOAD CASE COMBINATIONS

ASCE 1993 specifies that structural steel equipment be checked for adequacy by applying several loads and load combinations. It was determined that the most conservative load case for both the horizontal and vertical load case is dead load + live load + wind (DL+LL+W). Below is a list of load cases and load case combination input into the FEA model AZTR_BLC11B:

- Load Case 1 Dead load of the horizontal trough represented by a -386.4 ft/s^2 acceleration in the global Y direction.
- Load Case 2 A 4,200 lb uniform live load represented by a line pressure of 5.45 lb/in. over the 770.5 in. length of the horizontal trough.
- Load Case 3 A 4,200 lb uniform live load represented by eleven 382 lb forces placed at equal intervals along the length of the horizontal trough (used to verify the results of Load Case 2).
- Load Case 4 A 2,000 lb vertical point load on the tip of the horizontal trough.
- Load Case 5 A 5,000 lb vertical point load on the tip of the horizontal trough
- Load Case 6 This is a 2.5 lb/in. line load used to represent wind on the 770.5 in. length of the lower chord of the trough.
- Load Case 7 This is a 2.5 lb/in. line load used to represent wind on the 770.5 in. length of the upper chord of the trough.
- Load Case 8 Dead load of the vertical trough represented by a -386.4 ft/s^2 acceleration in the global X direction.
- Load Case 9 Three 1,667 lb forces were used to represent the vertical load on the trough due to the test weight.
- Load Case 10 A 1.5*g* lateral acceleration used to represent a transportation load.
- Combination 51 Load Case 1 + Load Case 2 + Load Case 4 (dead load of trough + live load due to carriage + equipment load).
- Combination 52 Load Case 1 + Load Case 3 + Load Case 4 (dead load of trough + live load due to carriage + equipment load).
- Combination 53 Load Case 1 + Load Case 5 + Load Case 6 (dead load of trough + test weight live load + wind load on lower chord of trough).
- Combination 54 Load Case 1 + Load Case 5 + Load Case 7 (dead load of trough + test weight live load + wind load on upper chord of trough).
- Combination 55 Load Case 8 + Load Case 9 + Load Case 7 (dead load of trough + test weight live load + wind load on upper chord of trough all).

3.5 OVERTURNING

Wind on the vertical trough and carriage will result in an overturning moment. The overturning moment is resisted by the weight of the trailer, strongback, trough, carriage, bag, rigging and various other equipment. Since, the weight of the trough and its' associated equipment is significantly less than that of the ERS-W320 shipping container and mixer pump, the possibility of overturning was analyzed and is shown in Appendix F.

3.6 NATURAL FREQUENCY DETERMINATION

The trough was analyzed to determine if coupling of the natural frequency and an excitation frequency (resonance) could occur. The natural frequency of the trough was determined to be 4.15 hz (see Appendix G). The natural frequency was determined by creating a FEA model of the trough loaded with the 5,000 lb test weight. The test weight was included in the model and represented by a 5,000 lb mass. The ERS-W320 hydraulic trailer system has a 20 hz frequency design. This frequency is significantly high enough that it will not effect the frequency of the trough. For this reason, the boundary conditions modelling the trough attachment points to the strongback were modeled as fixed.

3.7 EXCITATION FREQUENCY

Since resonance is being investigated in the trough structure, an induced vibration was determined. Vortex shedding due to a 15 mph wind[1] was determined to cause the only induced vibration in the trough. Vortex shedding is the periodic change in side pressure on a shape due to wind. When the sparse frame of the trough is compared to the large cylindrical shape of the carriage, the carriage will cause worse vortex shedding. For this reason, the carriage was considered as the only device causing vortex shedding.

For the given Reynolds number, an upper and lower bound exist for the excitation frequency (see Blevins 1977). Appendix G contains the hand calculations showing the range of the excitation frequency to be 1.8 hz to 2.8 hz.

4.0 RESULTS AND CONCLUSIONS

The results of this analysis show that the trough is structurally adequate for the equipment removal conditions evaluated. The input and output files for this model are backed up on the attached ¼ in. magnetic tape.

4.1 TROUGH STRUCTURAL MEMBERS

The structural members forming the trough are; structural tubing, bars, angle and stiffening plates located at intervals along the length of the trough. The first six von Mises stress plots in

[1] Tank Farms only operates in winds gusting to 15 mph or less.

Appendix C are of the beam shapes comprising the trough. The maximum stress from these first six plots is 13,300 lbf/in^2. This stress is in excess of the allowables described in Section 3.2., however, an AISC code evaluation on these beams shows that they are adequate to withstand the applied load combinations (see Section 4.2 and Appendix D). The remaining seven maximum von Mises stress plots in Appendix C are of the stiffeners and other plate members comprising the trough. The maximum stress from the remaining plots is 15,200 lbf/in^2 from load case 55. In this load case the maximum von Mises stress appears in the top stiffener plate of the trough when the trough is in the vertical position. This stress exceeds the allowable, however, it is due to the simplified way in which the 5,000 lbf test load was modeled. For this reason, the maximum stress in the top plate is discounted, resulting in a maximum stress of 4,590 lbf/in^2. This is well below the allowable stress of 12,000 lbf/in^2 (see the final stress plot in Appendix C).

4.2 AISC CODE EVALUATION

An AISC code evaluation was performed on all tube steel, bar, and angle members to determine their adequacy for bending, shear, axial tension, axial compression and stress interaction (see Appendix D). Bending, shear and axial tension stresses were determined using the proper forces and/or moments from the FEA model. Axial compression was determined by calculating the effective length (k*l/r) and using tables within AISC 1989. Adequacy to resist stress interaction was determined using the interaction equation (see Chapter H of AISC 1989). All beams were determined to be adequate to the resultant stresses and interaction of stresses per AISC criteria.

4.3 WELD CONNECTION EVALUATION

The welds were sized and analyzed in accordance with the requirements of AWS D1.1 including Section 9. Using a spreadsheet developed in *Quattro Pro* (Borland 1994), each of the stress components (P/A, Ms/Ss, Mt/St) for each of the welded joints were input into the spreadsheet and a margin of safety calculated for each of the welds. The welds are appropriately sized and structurally adequate. The output for this spreadsheet can be found in Appendix E.

4.4 OVERTURNING ANALYSIS

The analysis in Appendix F determined that the ERS-W320 equipment when combined with the lighter; trough, carriage and related equipment in the vertical position will adequately resist an overturning moment due to 10 lb/ft^2 wind load.

4.5 FREQUENCY ANALYSIS

Comparison of the excitation frequency (1.8 to 2.8 hz) to the natural frequency (4.2 hz), shows that there will be no coupling of the two frequencies and, therefore, resonance will not occur.

4.6 TRANSPORTATION ANALYSIS

The trough is adequate to support its own dead weight during transportation as determined by load case 10 of the FEA.

4.7 BOLTED CONNECTION ANALYSIS

Comparison of the 25,000 lbf ERS-W320 design connection load (WHC 1995a, Page A-52) to the resultant reaction forces, from the FEA (Appendix I), shows that the four A325 bolts (ASTM 1995c) are adequate to connect the troughs to the ERS-W320 strongback.

Attachment of the carriage to the trough is described, analyzed and detailed in WHC 1995d. Also, the trough ¾ in. top plate is analyzed to determine its adequacy for connecting the carriage and trough assemblies.

5.0 REQUIREMENTS

Several requirements must be met for the combination of the ERS-W320 components to be safely used in conjunction with the 241AZ101 removal equipment. These requirements are:

- 15 mph is the maximum wind speed allowed when the 241AZ101 removal equipment is in the vertical position.
- The loads are not to exceed those specified on the load chart shown in Figure 1.
- The bolting sequence for attaching the trough to the strongback shall be performed similarly to the bolting sequence for attaching the 241C106 shipping container to the strongback (WHC 1994b).
- The maximum carriage wheel load is 2,100 lb per the calculations in Appendix H.
- Attachment of the toughs to the ERS-W320 strongback must be completed using four A325 structural steel bolts.
- The carriage must be bolted to the trough as specified in WHC 1995d.

6.0 REFERENCES

AISC, 1989, *Manual of Steel Construction, Allowable Stress Design*, Ninth Edition, American Institute of Steel Construction, Inc., Chicago, Illinois.

ANSI, 1986, *Special Lifting Devices for Shipping Containers Weighing 10,000 Pounds (4500 kg) or More*, American National Standards Institute, New York, New York.

ASCE, 1993, *Minimum Design Loads for Buildings and Other Structures*, Revision 7-93, American Society of Civil Engineers, New York, New York.

ASTM, 1995a, *Standard Specification for Structural Steel*, A36/A36M-88c, American Society for Testing and Materials, Philadelphia, Pennsylvania.

ASTM, 1995b, *Standard Specification for Cold-Formed Welded and Seamless Carbon Steel Carbon Steel Structural Tubing in Rounds and Shapes*, A500-84, American Society for Testing and Materials, Philadelphia, Pennsylvania.

ASTM, 1995C, *Standard Specification for High-Strength Bolts for Structural Steel Joints*, A325-88, American Society for Testing an Materials, Philadelphia, Pennsylvania.

AWS, 1994, *Structural Welding Code for Steel*, AWS D1.1-94, American Welding Society, Miami, Florida.

Blevins, R. D., 1977, *Flow-Induced Vibration*, Van Norstrand Reinhold and Company, New York, New York.

Borland, 1994, *Quattro Pro*, Version 5, Borland, Orem, Utah.

DOE-RL, 1993a, *Standard Architectural-Civil Design Criteria, Design Loads for Facilities*, Hanford Plant Standard SDC-4.1 Revision 12, U.S. Department of Energy, Richland Field Office, Richland, Washington.

DOE-RL, 1993b, *Hanford Site Hoisting and Rigging Manual*, DOE-RL-92-36, U.S. Department of Energy Richland Field Office, Richland, Washington.

DOT, 1989, *Code of Federal Regulations*, Title 49 CFR III part 393, U. S. Department of Transportation, Washington D. C.

SRAC, 1994, *COSMOS/M*, Version 1.71, Structural Research and Analysis Corporations, Santa Monica, California. Note: *COSMOS/M* is a trademark of Structural Research and Analysis Corporation.

Troitsky, M. S., 1982, *Tubular Steel Structures - Theory and Design*, James F. Lincoln Arc Welding Foundation, Cleveland, Ohio.

UCRL-1990, *Design and Evaluation Guidelines for U.S. Department of Energy Facilities Subjected to Natural Phenomena Hazards*, UCRL-15910, University of California Research Laboratory, Livermore, California.

WHC, 1994a, *STRONGBACK*, drawing H-2-83717 Rev. 0, Sht. 1-13, Westinghouse Hanford Company, Richland, Washington.

WHC, 1994b, *Bolting Sequence for Attaching the Container to the Strongback*, WHC-SD-W320-DA-003, Westinghouse Hanford Company, Richland, Washington.

WHC, 1995a, *Structural Analysis of the Equipment Removal System for Tanks 241C106 and 241AY102*, WHC-SD-W320-DA-001, Westinghouse Hanford Company, Richland, Washington.

WHC, 1995b, *TROUGH ASSEMBLY 36 IN DIA X 64 FT LONG*, drawing H-2-83768 Rev. 0, Sht. 1-9, Westinghouse Hanford Company, Richland, Washington.

WHC, 1995c, *TROUGH ASSEMBLY 20 IN DIA X 64 FT LONG*, drawing H-2-83769 Rev. 0, Sht. 1-9, Westinghouse Hanford Company, Richland, Washington.

WHC, 1995d, *241AZ101 20 in. and 36 in. Carriage Assembly Analysis*, WHC-SD-TP-ANAL-005, Westinghouse Hanford Company, Richland, Washington.

THIS PAGE INTENTIONALLY
LEFT BLANK

Appendix A: Internal Memo from DST Retrieval Projects to T. C. Mackey

THIS PAGE INTENTIONALLY
LEFT BLANK

Westinghouse Hanford Company **Internal Memo**

From: DST Retrieval Projects 7F520-MEM-94-09
Phone: 372-2682 R3-27
Date: November 29, 1994
Subject: PROJECT W-151, "TANK 101-AZ WASTE RETRIEVAL SYSTEM," REMOVAL EQUIPMENT, TROUGH RE-DESIGN

To: T. C. Mackey

cc:

R. E. Clayton	R3-27	R. B. Pan	H5-53
S. R. Crow	G2-03	J. E. Van Beek	R3-27
K. D. Junt	S2-01	W-151 File	R3-27
R. N. Kyle	S2-01	Project File	R1-28
M. E. McKinney	R3-27	MEM File/LB	R3-27
E. M. Nordquist	R3-27		

DST Retrieval Projects requests the services of Westinghouse Hanford Company (WHC) Structural to re-design the trough assemblies for the 20", 36", and 52" removal equipment systems.

SCOPE

The trough re-design shall proceed from the conceptualized approach and provide two troughs (20" and 36") which can be utilized with the Project W-320 tilt trailer and a 52" trough which can be used with the 101-SY tilt trailer. The troughs shall be designed to meet the following minimum load requirements:

SIZE	CARRIAGE WT.	EQUIPMENT WT.	BAG & RIGGING WT.	TOTAL
20"	2100 lbs	500 lbs	400 lbs	3000 lbs
36"	3700 lbs	2000 lbs	500 lbs	6200 lbs
52"	5600 lbs	14500 lbs	600 lbs	20700 lbs

WHC Structural is authorized to provide a trough design with increased load carrying capacity (closer to the maximum loads of the tilt trailer) provided the design is consistent with the conceptual approach (design of structure and type of material) and cost impacts are minimal.

WHC Structural shall provide a complete re-design of the trough assemblies. The re-design shall be documented with an Engineering Change Notice (ECN) and be a complete revision to the existing drawings. WHC Structural shall utilize the existing drawing numbers for the troughs.

SCHEDULE

WHC Structural is requested to initiate re-design of the trough assembly upon receipt of this letter. The trough re-design shall be split into two phases. The first phase shall provide the designs for the 20" and 36" troughs. The first phase re-design shall be completed by January 20, 1995

THIS PAGE INTENTIONALLY
LEFT BLANK

Appendix B: Wind Load Calculations

THIS PAGE INTENTIONALLY
LEFT BLANK

ICF KAISER
HANFORD COMPANY DESIGN ANALYSIS

Calc. No.
Revision 0
Page No. 1 of

ent: Westinghouse Hanford Company
Subject: 241AZ Truss Wind Analysis
Location: 200 E /

WO/Job No. C01909
Date: 06/28/95
Checked: 9/29/95
Revised:

By: B. L. Coverdell
By:
By:

PURPOSE:

Determine the effective wind load that on the AZ truss given that this is safety class 3 equipment.

ASSUMPTIONS:

All wind loading will be transmitted to the AZ truss via the 64 ft carriage.

DESCRIPTION:

Two load cases must be considered when analyzing the AZ truss; the truss in the lowered position and in then in the upright position

NOTE: The AZ truss has very little cross-sectional area, however, when the 64 ft carriage is in place it has a significant cross-section. The cross-sectional area of the 64 ft carrage will be used to determine the wind loading and that loading will be applied to the truss.

WIND CALCULATIONS FOR AZ TRUSS IN LOWER POSITION

Exposure category is C from DOE-RL 1993, Page 11.

$I := 1.07$ Importance factor from DOE-RL 1993, Page 11.

$V := 70 \cdot mph$ Fastest wind speed from DOE-RL 1993, Page 11.

$K_z := 0.8$ Velocity pressure exposure coefficient from ASCE 7-93, Table 6, Page 12.

$q_z := 0.00256 \cdot \frac{lbf \cdot sec^2}{ft^4} \cdot K_z \cdot (I \cdot V)^2$ $q_z = 24.715 \cdot \frac{lbf}{ft^2}$ The velocity pressure from ASCE 1993, Page 11, Equation 3.

$G_h := 1.32$ Gust response factor from ASCE 7-93, Table 8, Page 15.

$h := 64 \cdot ft$ $D := 3 \cdot ft$ Respective height and length of the 64 ft carriage.

$\frac{h}{D} = 21.333$ Used to determine C_f in ASCE 1993, Table 12, Page 21.

$C_f := 1.2$ Force coefficient from ASCE 1993, Table 12, Page 21. NOTE: this value is conservative.

$A_f := h \cdot D$ $A_f = 192 \cdot ft^2$ Cross-sectional area of the carriage.

$F := q_z \cdot G_h \cdot C_f A_f$ $F = 7516 \cdot lbf$ Wind load to be applied to the AZ truss.

$p_z := if\left(\frac{F}{h \cdot D} < 10 \cdot \frac{lbf}{ft^2}, 10 \cdot \frac{lbf}{ft^2}, \frac{F}{h \cdot D}\right)$ $p_z = 39.148 \cdot \frac{lbf}{ft^2}$ If pressure less than 10 lbf/ft^2 use 10 lbf/ft^2 else use calculated pressure (ASCE 1993, Page 9, 6.4.2.1).

$P_l := p_z \cdot D$ $P_l = 9.79 \cdot \frac{lbf}{in}$ The load per length of carriage. For use in the finite-element model.

WIND CALCULATIONS FOR AZ TRUSS IN UPRIGHT POSITION

Exposure category is C from DOE-RL 1993, Page 13.

$I := 1.07$ Importance factor from DOE-RL 1993, Page 13.

$V := 15 \cdot mph$ Fastest operational wind speed with in Tank Farms. It should be noted that this is winds gusting to speed, not a contiuous wind speed (conservative).

ICF KAISER
HANFORD COMPANY **DESIGN ANALYSIS**

Calc. No.
Revision 0
Page No. 2 of

ant: Westinghouse Hanford Company
Subject: 241AZ Truss Wind Analysis
Location: 200 E /

WO/Job No. C01909
Date: 06/28/95 By: B. L. Coverdell
Checked: 9/29/95 By:
Revised: By:

$K_z := 1.24$ Velocity pressure exposure coefficient from ASCE 7-93, Table 6, Page 12.

$q_z := 0.00256 \cdot \frac{lbf \cdot sec^2}{ft^4} \cdot K_z \cdot (I \cdot V)^2$ $q_z = 1.759 \cdot \frac{lbf}{ft^2}$ The velocity pressure from ASCE 1993, Page 11, Equation 3.

$G_h := 1.19$ Gust response factor from ASCE 7-93, Table 8, Page 15.

$h := 64 \cdot ft$ $D := 3 \cdot ft$ Respective height and length of the 64 ft carriage.

$\frac{h}{D} = 21.333$ Used to determine C_f in ASCE 1993, Table 12, Page 21.

$C_f := 1.2$ Force coefficient from ASCE 1993, Table 12, Page 21. NOTE: this value is conservative.

$A_f := h \cdot D$ $A_f = 192 \cdot ft^2$ Cross-sectional area of the carriage.

$F := q_z \cdot G_h \cdot C_f A_f$ $F = 482 \cdot lbf$ Wind load to be applied to the AZ truss.

$p_z := if\left(\frac{F}{h \cdot D} < 10 \cdot \frac{lbf}{ft^2}, 10 \cdot \frac{lbf}{ft^2}, \frac{F}{h \cdot D}\right)$ $p_z = 10 \cdot \frac{lbf}{ft^2}$ If pressure less than 10 lbf/ft^2 use 10 lbf/ft^2 else use calculated pressure (ASCE 1993, Page 9, 6.4.2.1).

$P_l := p_z \cdot D$ $P_l = 2.5 \cdot \frac{lbf}{in}$ The load per length of carriage. For use in the finite-element model.

REFERENCES:

ASCE 1993, *Minimum Design Loads for Buildings and Other Structures*, Revision 7-93, American Society of Civil Engineers, New York, New York.

DOE-RL 1993, *Standard Arch-Civil Design Criteria*, DOE-RL-SDC 4.1 Revision 12, Westinghouse Hanford Company, Richland, Washington.

Appendix C: Finite-Element Analysis of 36 in. Trough

THIS PAGE INTENTIONALLY
LEFT BLANK



Maximum Von Mises Stress Plot Of Beam Members Only For Load Case 10



Maximum Von Mises Stress Plot Of Beam Members Only For Load Case 51



Maximum Von Mises Stress Plot Of Beam Members Only For Load Case 52



Maximum Von Mises Stress Plot Of Beam Members Only For Load Case 53



Maximum Von Mises Stress Plot Of Beam Members Only For
Load Case 54



Maximum Von Mises Stress Plot Of Beam Members Only For Load Case 55



Maximum Von Mises Stress Plot Of Plate Members Only For
Load Case 10



Maximum Von Mises Stress Plot Of Plate Members Only For Load Case 51



Maximum Von Mises Stress Plot Of Plate Members Only For
Load Case 52



Maximum Von Mises Stress Plot Of Plate Members Only For Load Case 53



Maximum Von Mises Stress Plot Of Plate Members Only For
Load Case 54



Maximum Von Mises Stress Plot Of Plate Members Only For Load Case 55



Maximum Von Mises Stress Plot Of Plate Members Only For
Load Case 55 (Top Plate Removed)

THIS PAGE INTENTIONALLY
LEFT BLANK

Appendix D: AISC Code Check

THIS PAGE INTENTIONALLY
LEFT BLANK

ICF KAISER
HANFORD COMPANY

DESIGN ANALYSIS

Calc. No.
Revision 0
Page No. 1 of

Client: Westinghouse Hanford Company
Project: 241AZ Truss Buckling Analysis
Location: 200 E /

WO/Job No. C01909
Date: 06/28/95
Checked: 7/19/95
Revised:

By: B. L. Coverdell
By:
By:

PURPOSE:

The calculations below determine the structural adequacy of the AISC shapes (AISC 1989) used in the construction of the 241AZ Truss.

ASSUMPTIONS:

$k := 1$ This value of k is conservative for this application (AISC 1989, Table C-C2.1). All columns are fixed at either end.

All forces and moments are taken from the finite-element model AZTR_BLC11B, (SRAC 1994). See the attached sheet listing the forces and moments. Due to the inability of the computer program to show whether the maximum axial force is compression or tension, it was assumed to be compressive. This is conservative.

$E := 30 \cdot 10^6 \cdot psi$ The modulus of elasticity for all structural steel in this analysis.

$Fy_{ts} := 46000 \cdot psi$ Yield stress for all structural tubing (ASTM A500, Gr. B).

$Fy := 36000 \cdot psi$ Yield stress for all other sections (ASTM A36).

These calculations do not consider torsional buckling.

For simplicity, all sections are considered to be non-compact. This is conservative.

DESCRIPTION:

The actual axial forces and bending moments are taken from the finite-element model AZTR_BLC11B (SRAC 1993) and are used to determine the actual axial, shear and bending stress. The allowable stresses are then determined and compared to the actual stresses. All the stresses are then used in an interaction equation from AISC 1989.

CALCULATIONS:

TS 6" x 6" x 3/8" Real Constant #1 in the finite-element model

Properties of structural shape.

$S := 13.9 \cdot in^3$ section modulus

$r_x := 2.27 \cdot in$ radius of gyration about the x axis

$r_y := r_x$ radius of gyration about the y axis (square shape)

$l := 69.25 \cdot in$ maximum column length

$A := 8.08 \cdot in^2$ cross sectional area

Determine the allowable stresses on the beam.

$k \cdot l = 5.771 \cdot ft$ effective length

$P_a := 201 \cdot 10^3 \cdot lbf$ The allowable axial compressive load from AISC, 1989, page 3-42 using 6 for kl (no interpolation).

$F_a := \frac{P_a}{A}$ $F_a = 24876.238 \cdot psi$ Allowable axial compressive stress of the column.

$F_v := 0.4 \cdot Fy_{ts}$ $F_v = 18400 \cdot psi$ Allowable shear stress per AISC 1989, Page 5-49, F4-1.

ICF KAISER
HANFORD COMPANY

DESIGN ANALYSIS

Calc. No.
Revision 0
Page No. 2 of

Client: Westinghouse Hanford Company
Subject: 241AZ Truss Buckling Analysis
Location: 200 E /

WO/Job No. C01909
Date: 06/28/95 By: B. L. Coverdell
Checked: 7/19/95 By:
Revised: By:

$F_{bx} := 0.60 \cdot Fy_{ts}$ $F_{bx} = 27600 \cdot psi$ Allowable bending stress per AISC 1989, Page 5-48, F3-3.

$F_{by} := F_{bx}$ Conservative to use a value of 0.6 for bending about both axis.

Determine the actual shear, axial and bending stresses in the shape and compare them with the allowables.

Axial forces and bending moments on the beam. Determined from the finite-element model AZTR_BLC11B, SRAC, 1993.

$F_r := 76444.9 \cdot lbf$ $V_s := 1597.9 \cdot lbf$ $V_t := 1665.2 \cdot lbf$

$M_s := 26969 \cdot lbf \cdot in$ $M_t := 26093.7 \cdot lbf \cdot in$

$f_a := \frac{F_r}{A}$ $f_a = 9461.002 \cdot psi$ Maximum compressive stress in the beam.

$f_v := \frac{\sqrt{V_s^2 + V_t^2}}{A}$ $f_v = 285.625 \cdot psi$ Maximum shear stress in the beam.

$f_{bx} := \frac{M_t}{S}$ $f_{bx} = 1877.245 \cdot psi$ Maximum bending stress about major axis of beam.

$f_{by} := \frac{M_s}{S}$ $f_{by} = 1940.216 \cdot psi$ Maximum bending stress about major axis of beam.

$x := f_a \le F_a$ $x = 1$ $x := f_v \le F_v$ $x = 1$

$x := f_{bx} \le F_{bx}$ $x = 1$ $x := f_{by} \le F_{by}$ $x = 1$

Since all the resultants equal 1 or true then the actual stresses are less then the allowables and, therefore, this section of calculations is adequate per AISC 1989.

Check interaction equation for compression.

$\frac{f_a}{F_a} = 0.38$ Since the resultant is greater than 0.15, use the equation H1-1 per AISC 1989, page 5-54.

$F'_{ex} := \frac{12 \cdot \pi^2 \cdot E}{23 \cdot \left(\frac{k \cdot l}{r_x}\right)^2}$ $F'_{ex} = 165991.775 \cdot psi$ Euler stress for x axis bending divided by a factor of safety per AISC, page 5-54.

$F'_{ey} := \frac{12 \cdot \pi^2 \cdot E}{23 \cdot \left(\frac{k \cdot l}{r_y}\right)^2}$ $F'_{ey} = 165991.775 \cdot psi$ Euler stress for y axis bending divided by a factor of safety per AISC, page 5-54.

$C_{mx} := 0.85$ Compression coefficient. Determined from AISC, page 5-55.

$C_{my} := C_{mx}$ Compression coefficient. Determined from AISC, page 5-55.

ICF KAISER
HANFORD COMPANY

Calc. No.
Revision 0
Page No. 3 of

DESIGN ANALYSIS

Client: Westinghouse Hanford Company
Subject: 241AZ Truss Buckling Analysis
Location: 200 E /

WO/Job No. C01909
Date: 06/28/95
Checked: 7/19/95
Revised:

By: B. L. Coverdell
By:
By:

$$\frac{f_a}{F_a} + \frac{C_{mx} \cdot f_{bx}}{\left(1 - \frac{f_a}{F'_{ex}}\right) \cdot F_{bx}} + \frac{C_{my} \cdot f_{by}}{\left(1 - \frac{f_a}{F'_{ey}}\right) \cdot F_{by}} = 0.505$$

Since the resultant is less than or equal to 1, the beam is adequate to support the load per AISC 1989.

TS 4" x 4" x 3/8" Real Constant #2 in the finite-element model

Properties of structural shape.

$S := 5.35 \cdot in^3$ section modulus

$r_x := 1.45 \cdot in$ radius of gyration about x axis.

$r_y := r_x$ radius of gyration about x axis.

$l := 69.25 \cdot in$ maximum column length

$A := 5.08 \cdot in^2$ cross sectional area

Determine the allowable stresses on the beam.

$k \cdot l = 5.771 \cdot ft$ effective length

$P_a := 115 \cdot 10^3 \cdot lbf$ The allowable axial compressive load from AISC, 1989, page 3-42 using 6 for kl (no interpolation).

$F_a := \frac{P_a}{A}$ $F_a = 22637.795 \cdot psi$ Allowable axial compressive stress of the column.

$F_v := 0.4 \cdot Fy_{ts}$ $F_v = 18400 \cdot psi$ Allowable shear stress per AISC 1989, Page 5-49, F4-1.

$F_{bx} := 0.60 \cdot Fy_{ts}$ $F_{bx} = 27600 \cdot psi$ Allowable bending stress per AISC 1989, Page 5-48, F3-3.

$F_{by} := F_{bx}$ Conservative to use a value of 0.6 for bending about both axis.

Determine the actual shear, axial and bending stresses in the shape and compare them with the allowables.

Axial forces and bending moments on the beam. Determined from the finite-element model AZTR_BLC11B, SRAC, 1993.

$F_r := 41495.4 \cdot lbf$ $V_s := 1332.7 \cdot lbf$ $V_t := 914.8 \cdot lbf$

$M_s := 15971.6 \cdot lbf \cdot in$ $M_t := 9379.7 \cdot lbf \cdot in$

$f_a := \frac{F_r}{A}$ $f_a = 8168.386 \cdot psi$ Maximum compressive stress in the beam.

$f_v := \frac{\sqrt{V_s^2 + V_t^2}}{A}$ $f_v = 318.201 \cdot psi$ Maximum shear stress in the beam.

$f_{bx} := \frac{M_t}{S}$ $f_{bx} = 1753.215 \cdot psi$ Maximum bending stress about major axis of beam.

ICF KAISER
HANFORD COMPANY

DESIGN ANALYSIS

Calc. No.
Revision 0
Page No. 4 of

ent: Westinghouse Hanford Company
ubject: 241AZ Truss Buckling Analysis
Location: 200 E /

WO/Job No. C01909
Date: 06/28/95
Checked: 7/19/95
Revised:

By: B. L. Coverdell
By:
By:

$f_{by} := \frac{M_s}{S}$ $f_{by} = 2985.346 \cdot psi$ Maximum bending stress about major axis of beam.

$x := f_a \le F_a$ $x = 1$ $x := f_v \le F_v$ $x = 1$

$x := f_{bx} \le F_{bx}$ $x = 1$ $x := f_{by} \le F_{by}$ $x = 1$

Since all the resultants equal 1 or true then the actual stresses are less then the allowables and, therefore, this section of calculations is adequate per AISC 1989.

Check interaction equation for compression.

$\frac{f_a}{F_a} = 0.361$ Since the resultant is greater than 0.15, use the equation H1-1 per AISC 1989, page 5-54.

$F'_{ex} := \frac{12 \cdot \pi^2 \cdot E}{23 \cdot \left(\frac{k \cdot l}{r_x}\right)^2}$ $F'_{ex} = 67728.407 \cdot psi$ Euler stress for x axis bending divided by a factor of safety per AISC, page 5-54.

$F'_{ey} := \frac{12 \cdot \pi^2 \cdot E}{23 \cdot \left(\frac{k \cdot l}{r_y}\right)^2}$ $F'_{ey} = 67728.407 \cdot psi$ Euler stress for y axis bending divided by a factor of safety per AISC, page 5-54.

$C_{mx} := 0.85$ Compression coefficient. Determined from AISC, page 5-55.

$C_{my} := C_{mx}$ Compression coefficient. Determined from AISC, page 5-55.

$\frac{f_a}{F_a} + \frac{C_{mx} \cdot f_{bx}}{\left(1 - \frac{f_a}{F'_{ex}}\right) \cdot F_{bx}} + \frac{C_{my} \cdot f_{by}}{\left(1 - \frac{f_a}{F'_{ey}}\right) \cdot F_{by}} = 0.527$ Since the resultant is less than or equal to 1, the beam is adequate to support the load per AISC 1989.

TS 4" x 2" x 5/16" Real Constant #3 & 4 in the finite-element model

Properties of structural shape.

$S_x := 2.66 \cdot in^3$ section modulus about major axis

$S_y := 1.71 \cdot in^3$ section modulus about minor axis

$r_x := 1.31 \cdot in$ radius of gyration about x axis

$r_y := 0.743 \cdot in$ radius of gyration about y axis

$l := 81 \cdot in$ maximum column length

$A := 3.11 \cdot in^2$ cross sectional area

ICF KAISER
HANFORD COMPANY

DESIGN ANALYSIS

Calc. No.
Revision 0
Page No. 5 of

ent: Westinghouse Hanford Company
ubject: 241AZ Truss Buckling Analysis
Location: 200 E /

WO/Job No. C01909
Date: 06/28/95
Checked: 7/19/95
Revised:

By: B. L. Coverdell
By:
By:

Determine the allowable stresses on the beam.

$k \cdot l = 6.75 \cdot ft$ effective length

$P_a := 36 \cdot 10^3 \cdot lbf$ The allowable axial compressive load from AISC, 1989, page 3-52 using 7 for kl (no interpolation).

$F_a := \frac{P_a}{A}$ $F_a = 11575.563 \cdot psi$ Allowable axial compressive stress of the column.

$F_v := 0.4 \cdot Fy_{ts}$ $F_v = 18400 \cdot psi$ Allowable shear stress per AISC 1989, Page 5-49, F4-1.

$F_{bx} := 0.60 \cdot Fy_{ts}$ $F_{bx} = 27600 \cdot psi$ Allowable bending stress per AISC 1989, Page 5-48, F3-3.

$F_{by} := F_{bx}$ Conservative to use a value of 0.6 for bending about both axis.

Determine the actual shear, axial and bending stresses in the shape and compare them with the allowables.

Axial forces and bending moments on the beam. Determined from the finite-element model AZTR_BLC11B, SRAC, 1993.

$F_r := 17961.2 \cdot lbf$ $V_s := 178.3 \cdot lbf$ $V_t := 922.1 \cdot lbf$

$M_s := 5435.3 \cdot lbf \cdot in$ $M_t := 5333.9 \cdot lbf \cdot in$

$f_a := \frac{F_r}{A}$ $f_a = 5775.305 \cdot psi$ Maximum compressive stress in the beam.

$f_v := \frac{\sqrt{V_s^2 + V_t^2}}{A}$ $f_v = 301.987 \cdot psi$ Maximum shear stress in the beam.

$f_{bx} := \frac{M_t}{S_x}$ $f_{bx} = 2005.226 \cdot psi$ Maximum bending stress about major axis of beam.

$f_{by} := \frac{M_s}{S_y}$ $f_{by} = 3178.538 \cdot psi$ Maximum bending stress about major axis of beam.

$x := f_a \le F_a$ $x = 1$ $x := f_v \le F_v$ $x = 1$

$x := f_{bx} \le F_{bx}$ $x = 1$ $x := f_{by} \le F_{by}$ $x = 1$

Since all the resultants equal 1 or true then the actual stresses are less then the allowables and, therefore, this section of calculations is adequate per AISC 1989.

Check interaction equation for compression.

$\frac{f_a}{F_a} = 0.499$ Since the resultant is greater than 0.15, use the equation H1-1 per AISC 1989, page 5-54.

ICF KAISER
HANFORD COMPANY

DESIGN ANALYSIS

Calc. No.
Revision 0
Page No. 6 of

ent: Westinghouse Hanford Company
Object: 241AZ Truss Buckling Analysis
Location: 200 E /

WO/Job No. C01909
Date: 06/28/95
Checked: 7/19/95
Revised:

By: B. L. Coverdell
By:
By:

$$F'_{ex} := \frac{12\cdot\pi^2\cdot E}{23\cdot\left(\frac{k\cdot l}{r_x}\right)^2} \qquad F'_{ex} = 40406.103\cdot psi$$

Euler stress for x axis bending divided by a factor of safety per AISC, page 5-54.

$$F'_{ey} := \frac{12\cdot\pi^2\cdot E}{23\cdot\left(\frac{k\cdot l}{r_y}\right)^2} \qquad F'_{ey} = 12998.164\cdot psi$$

Euler stress for y axis bending divided by a factor of safety per AISC, page 5-54.

$C_{mx} := 0.85$ Compression coefficient. Determined from AISC, page 5-55.

$C_{my} := C_{mx}$ Compression coefficient. Determined from AISC, page 5-55.

$$\frac{f_a}{F_a} + \frac{C_{mx}\cdot f_{bx}}{\left(1 - \frac{f_a}{F'_{ex}}\right)\cdot F_{bx}} + \frac{C_{my}\cdot f_{by}}{\left(1 - \frac{f_a}{F'_{ey}}\right)\cdot F_{by}} = 0.747$$

Since the resultant is less than or equal to 1, the beam is adequate to support the load per AISC 1989.

TWO TS 2 1/2" x 1 1/2" 3/16" BACK TO BACK ON 1 1/2" SIDES Real Constant #7 in the finite-element model

Properties of built-up shape.

$$A := \left[1.5\cdot in\cdot 2.5\cdot in - \left(1.5\cdot in - \frac{3}{8}\cdot in\right)\cdot\left(2.5\cdot in - \frac{3}{8}\cdot in\right)\right] \qquad A = 1.359\cdot in^2$$

Cross-sectional area of a single TS.

$l := 69.25\cdot in$ Length of column.

Determine the moment of inertia, section modulus and radius of gyration of the built-up shape.

$$d := \frac{1.5\cdot in}{2} \qquad d = 0.75\cdot in$$

Distance to centroidal axis of a single TS to combined centroidal axis.

$$I_x := \frac{1.5\cdot in\cdot(2.5\cdot in)^3}{12} - \frac{\left(1.5\cdot in - \frac{3}{8}\cdot in\right)\cdot\left(2.5\cdot in - \frac{3}{8}\cdot in\right)^3}{12} \qquad I_x = 1.054\cdot in^4$$

Moment of inertia for a single TS about the x axis.

$$I_y := \frac{2.5\cdot in\cdot(1.5\cdot in)^3}{12} - \frac{\left(2.5\cdot in - \frac{3}{8}\cdot in\right)\cdot\left(1.5\cdot in - \frac{3}{8}\cdot in\right)^3}{12} \qquad I_y = 0.451\cdot in^4$$

Moment of inertia for a single TS about the y axis.

$I_{x'} := 2\cdot I_x$ $I_{x'} = 2.107\cdot in^4$ Combined moment of inertia for back to back TS's.

$I_{y'} := 2\cdot\left(I_y + A\cdot d^2\right)$ $I_{y'} = 2.431\cdot in^4$ Combined moment of inertia for back to back TS's.

$$S_{x'} := \frac{I_{x'}}{\frac{2.5\cdot in}{2}} \qquad S_{x'} = 1.686\cdot in^3$$

section modulus about x axis

ICF KAISER
HANFORD COMPANY

Calc. No.
Revision 0
Page No. 7 of

DESIGN ANALYSIS

ent: Westinghouse Hanford Company
bject: 241AZ Truss Buckling Analysis
Location: 200 E. /

WO/Job No. C01909
Date: 06/28/95
Checked: 7/19/95
Revised:

By: B. L. Coverdell
By:
By:

$S_{y'} := \frac{I_{y'}}{1.5 \cdot in}$ $S_{y'} = 1.621 \cdot in^3$ section modulus about y axis

$r_x := \sqrt{\frac{I_{x'}}{2 \cdot A}}$ $r_x = 0.88 \cdot in$ The radius of gyration about the x axis for this beam.

$r_y := \sqrt{\frac{I_{y'}}{2 \cdot A}}$ $r_y = 0.946 \cdot in$ The radius of gyration about the y axis for this beam.

Determine the allowable stresses on the beam.

$\frac{k \cdot l}{r_x} = 78.662$ Slenderness ratio (used minimum radius of gyration).

$F_a := 19210 \cdot psi$ Allowable axial compressive stress of the column from AISC, 1989, page 3-17 using 79 for kl/r (no interpolation).

$F_v := 0.4 \cdot Fy_{ts}$ $F_v = 18400 \cdot psi$ Allowable shear stress per AISC 1989, Page 5-49, F4-1.

$F_{bx} := 0.60 \cdot Fy_{ts}$ $F_{bx} = 27600 \cdot psi$ Allowable bending stress per AISC 1989, Page 5-48, F3-3.

$F_{by} := F_{bx}$ True for a box member per AISC 1989.

Determine the actual shear, axial and bending stresses in the shape and compare them with the allowables.

Axial forces and bending moments on the beam. Determined from the finite-element model AZTR_BLC11B, SRAC, 1993.

$F_r := 2252.4 \cdot lbf$ $V_s := 178.3 \cdot lbf$ $V_t := 7.1 \cdot lbf$

$M_s := 45.7 \cdot lbf \cdot in$ $M_t := 3464.7 \cdot lbf \cdot in$

$f_a := \frac{F_r}{2 \cdot A}$ $f_a = 828.469 \cdot psi$ Maximum compressive stress in the beam.

$f_v := \frac{\sqrt{V_s^2 + V_t^2}}{2 \cdot A}$ $f_v = 65.634 \cdot psi$ Maximum shear stress in the beam.

$f_{bx} := \frac{M_t}{S_x}$ $f_{bx} = 1302.519 \cdot psi$ Maximum bending stress about major axis of beam.

$f_{by} := \frac{M_s}{S_y}$ $f_{by} = 26.725 \cdot psi$ Maximum bending stress about major axis of beam.

$x := f_a \leq F_a$ $x = 1$ $x := f_v \leq F_v$ $x = 1$

$x := f_{bx} \leq F_{bx}$ $x = 1$ $x := f_{by} \leq F_{by}$ $x = 1$

ICF KAISER
HANFORD COMPANY

DESIGN ANALYSIS

Calc. No.
Revision 0
Page No. 8 of

ent: Westinghouse Hanford Company
Subject: 241AZ Truss Buckling Analysis
Location: 200 E /

WO/Job No. C01909
Date: 06/28/95
Checked: 7/17/95
Revised:

By: B. L. Coverdell
By:
By:

Check interaction equation for compression.

$\frac{f_a}{F_a} = 0.043$ Since the resultant is less than 0.15, use the following equations per AISC, page 5-54.

$\frac{f_a}{F_a} + \frac{f_{bx}}{F_{bx}} + \frac{f_{by}}{F_{by}} = 0.091$ Since the resultant is less than or equal to 1, the beam is adequate to support the load per AISC 1989.

ANGLE 2" x 2" x 1/4" Real Constant #9 in the finite-element model

Properties of structural shape.

$S := 0.247 \cdot in^3$ section modulus

$r_x := 0.609 \cdot in$ radius of gyration about x axis

$r_y := 0.609 \cdot in$ radius of gyration about y axis

$l := 69.25 \cdot in$ maximum column length

$A := 0.938 \cdot in^2$ cross sectional area

Determine the allowable stresses on the beam.

$\frac{k \cdot l}{r_x} = 113.711$ slenderness ratio

$F_a := 0.6 \cdot Fy$ Allowable axial compressive stress of the column from AISC, 1989, page 3-16 using 114 for kl/r (no interpolation).

$F_v := 0.4 \cdot Fy$ $F_v = 14400 \cdot psi$ Allowable shear stress per AISC 1989, Page 5-49, F4-1.

$F_{bx} := 0.60 \cdot Fy$ $F_{bx} = 21600 \cdot psi$ Allowable bending stress per AISC 1989, Page 5-46, F1-5.

$F_{by} := F_{bx}$ True for an equal side angle.

Determine the actual shear, axial and bending stresses in the shape and compare them with the allowables.

Axial forces and bending moments on the beam. Determined from the finite-element model AZTR_BLC11B, SRAC, 1993.

$F_r := 3304.1 \cdot lbf$ $V_s := 431.4 \cdot lbf$ $V_t := 419.2 \cdot lbf$

$M_s := 2563.7 \cdot lbf \cdot in$ $M_t := 2638.8 \cdot lbf \cdot in$

$f_a := \frac{F_r}{A}$ $f_a = 3522.495 \cdot psi$ Maximum compressive stress in the beam.

$f_v := \frac{\sqrt{V_s^2 + V_t^2}}{A}$ $f_v = 641.287 \cdot psi$ Maximum shear stress in the beam.

ICF KAISER
HANFORD COMPANY

DESIGN ANALYSIS

Calc. No.
Revision 0
Page No. 9 of

Client: Westinghouse Hanford Company
Subject: 241AZ Truss Buckling Analysis
Location: 200 E /

WO/Job No. C01909
Date: 06/28/95
Checked: 7/14/95
Revised:

By: B. L. Coverdell
By:
By:

$f_{bx} := \frac{M_t}{S}$ $f_{bx} = 10683.401 \cdot psi$ Maximum bending stress about major axis of beam.

$f_{by} := \frac{M_s}{S}$ $f_{by} = 10379.352 \cdot psi$ Maximum bending stress about major axis of beam.

$x := f_a \le F_a$ $x = 1$ $x := f_v \le F_v$ $x = 1$

$x := f_{bx} \le F_{bx}$ $x = 1$ $x := f_{by} \le F_{by}$ $x = 1$

Check interaction equation for compression.

Initial calculations on this structural shape showed that it will fail if the axial force is considered to be compression. In order to circumnavigate this problem the finite-element model was used to due an axial stress plot. This stress plot shows that the member in question is actually in tension not compression. The interaction equation for tension is used below.

$\frac{f_a}{F_a} + \frac{f_{bx}}{F_{bx}} + \frac{f_{by}}{F_{by}} = 1.138$

The interaction equation exceeds 1, however, this member is not considered a prime structural member. For this reason, allow F_{bx} and F_{by} to be equal to the yield stress of the material.

$F_{bx} := Fy$ $F_{by} := Fy$

$\frac{f_a}{F_a} + \frac{f_{bx}}{F_{bx}} + \frac{f_{by}}{F_{by}} = 0.748$

Since the resultant is less than or equal to 1, the beam is adequate to support the load per AISC 1989.

BAR 6" x 6" Real Constant #10 in the finite-element model.

Properties of bar shape.

$l := 69.25 \cdot in$ maximum column length

$A := (6 \cdot in)^2$ $A = 36 \cdot in^2$ cross sectional area

$I := \frac{(6 \cdot in)^4}{12}$ $I = 108 \cdot in^4$ moment of inertia about either axis

$S := \frac{I}{\left(\frac{6 \cdot in}{2}\right)}$ $S = 36 \cdot in^3$ section modulus about either axis

$r_x := \sqrt{\frac{I}{A}}$ $r_x = 1.732 \cdot in$ radius of gyration about x axis

$r_y := \sqrt{\frac{I}{A}}$ $r_y = 1.732 \cdot in$ radius of gyration about y axis

ICF KAISER
HANFORD COMPANY

DESIGN ANALYSIS

Calc. No.
Revision 0
Page No. 10 of

ent: Westinghouse Hanford Company
ubject: 241AZ Truss Buckling Analysis
Location: 200 E /

WO/Job No. C01909
Date: 06/28/95
Checked: 7/19/95
Revised:

By: B. L. Coverdell
By:
By:

Determine the allowable stresses on the beam.

$\frac{k \cdot l}{r_x} = 39.982$ slenderness ratio

$F_a := 19190 \cdot psi$ Allowable axial compressive stress of the column from AISC, 1989, page 3-16 using 40 for kl/r (no interpolation).

$F_v := 0.4 \cdot Fy$ $F_v = 14400 \cdot psi$ Allowable shear stress per AISC 1989, Page 5-49, F4-1.

$F_{bx} := .60 \cdot Fy$ $F_{bx} = 21600 \cdot psi$ Allowable bending stress per AISC 1989, Page 5-48, F2-2.

$F_{by} := F_{bx}$ This is a square bar.

Determine the actual shear, axial and bending stresses in the shape and compare them with the allowables.

Axial forces and bending moments on the beam. Determined from the finite-element model AZTR_BLC11B, SRAC, 1993.

$F_r := 120987 \cdot lbf$ $V_s := 1183 \cdot lbf$ $V_t := 1222.8 \cdot lbf$

$M_s := 64246.7 \cdot lbf \cdot in$ $M_t := 62143.9 \cdot lbf \cdot in$

$f_a := \frac{F_r}{A}$ $f_a = 3360.75 \cdot psi$ Maximum compressive stress in the beam.

$f_v := \frac{\sqrt{V_s^2 + V_t^2}}{A}$ $f_v = 47.261 \cdot psi$ Maximum shear stress in the beam.

$f_{bx} := \frac{M_t}{S}$ $f_{bx} = 1726.219 \cdot psi$ Maximum bending stress about major axis of beam.

$f_{by} := \frac{M_s}{S}$ $f_{by} = 1784.631 \cdot psi$ Maximum bending stress about major axis of beam.

$x := f_a \le F_a$ $x = 1$ $x := f_v \le F_v$ $x = 1$

$x := f_{bx} \le F_{bx}$ $x = 1$ $x := f_{by} \le F_{by}$ $x = 1$

Check interaction equation for compression.

$\frac{f_a}{F_a} = 0.175$ Since the resultant is greater than 0.15, use the equation H1-1 per AISC 1989, page 5-54.

ICF KAISER
HANFORD COMPANY

Calc. No.
Revision 0
Page No. 11 of

DESIGN ANALYSIS

ent: Westinghouse Hanford Company
ubject: 241AZ Truss Buckling Analysis
Location: 200 E /

WO/Job No. C01909
Date: 06/28/95
Checked: 7/19/95
Revised:

By: B. L. Coverdell
By:
By:

$$F'_{ex} := \frac{12\cdot\pi^2\cdot E}{23\cdot\left(\frac{k\cdot l}{r_x}\right)^2} \qquad F'_{ex} = 96639.819\cdot psi$$

Euler stress for x axis bending divided by a factor of safety per AISC, page 5-54.

$$F'_{ey} := \frac{12\cdot\pi^2\cdot E}{23\cdot\left(\frac{k\cdot l}{r_y}\right)^2} \qquad F'_{ey} = 96639.819\cdot psi$$

Euler stress for y axis bending divided by a factor of safety per AISC, page 5-54.

$C_{mx} := 0.85$ Compression coefficient. Determined from AISC, page 5-55.

$C_{my} := C_{mx}$ Compression coefficient. Determined from AISC, page 5-55.

$$\frac{f_a}{F_a} + \frac{C_{mx}\cdot f_{bx}}{\left(1 - \frac{f_a}{F'_{ex}}\right)\cdot F_{bx}} + \frac{C_{my}\cdot f_{by}}{\left(1 - \frac{f_a}{F'_{ey}}\right)\cdot F_{by}} = 0.318$$

Since the resultant is less than or equal to 1, the beam is adequate to support the load per AISC 1989.

BAR 4" x 4" Real Constant #11 in finite-element model.

Properties of bar shape.

$l := 67\cdot in$ maximum column length

$A := (4\cdot in)^2 \qquad A = 16\cdot in^2$ cross sectional area

$$I := \frac{(4\cdot in)^4}{12} \qquad I = 21.333\cdot in^4$$

moment of inertia about either axis

$$S := \frac{I}{\left(\frac{4\cdot in}{2}\right)} \qquad S = 10.667\cdot in^3$$

section modulus about either axis

$$r_x := \sqrt{\frac{I}{A}} \qquad r_x = 1.155\cdot in$$

radius of gyration about x axis

$$r_y := \sqrt{\frac{I}{A}} \qquad r_y = 1.155\cdot in$$

radius of gyration about y axis

Determine the allowable stresses on the beam.

$\frac{k\cdot l}{r_y} = 58.024$ slenderness ratio

$F_a := 17620\cdot psi$ The allowable axial compressive stress from AISC, 1989, page 3-16 using 58 for kl/r (no interpolation.

ICF KAISER
HANFORD COMPANY

Calc. No.
Revision 0
Page No. 12 of

DESIGN ANALYSIS

Client: Westinghouse Hanford Company
Subject: 241AZ Truss Buckling Analysis
Location: 200 E /

WO/Job No. C01909
Date: 06/28/95
Checked: 7/17/95
Revised:

By: B. L. Coverdell
By:
By:

$F_v := 0.4 \cdot Fy$ $F_v = 14400 \cdot psi$ Allowable shear stress per AISC 1989, Page 5-49, F4-1.

$F_{bx} := 0.60 \cdot Fy$ $F_{bx} = 21600 \cdot psi$ Allowable bending stress per AISC 1989, Page 5-48, F2-2.

$F_{by} = F_{bx}$ True for a solid bar per AISC 1989.

Determine the actual shear, axial and bending stresses in the shape and compare them with the allowables.

Axial forces and bending moments on the beam. Determined from the finite-element model AZTR_BLC11B, SRAC, 1993.

$F_r := 52855.4 \cdot lbf$ $V_s := 1003.0 \cdot lbf$ $V_t := 465.9 \cdot lbf$

$M_s := 21676.1 \cdot lbf \cdot in$ $M_t := 18182.1 \cdot lbf \cdot in$

$f_a := \frac{F_r}{A}$ $f_a = 3303.463 \cdot psi$ Maximum compressive stress in the beam.

$f_v := \frac{\sqrt{V_s^2 + V_t^2}}{A}$ $f_v = 69.12 \cdot psi$ Maximum shear stress in the beam.

$f_{bx} := \frac{M_t}{S}$ $f_{bx} = 1704.572 \cdot psi$ Maximum bending stress about major axis of beam.

$f_{by} := \frac{M_s}{S}$ $f_{by} = 2032.134 \cdot psi$ Maximum bending stress about major axis of beam.

$x := f_a \le F_a$ $x = 1$ $x := f_v \le F_v$ $x = 1$

$x := f_{bx} \le F_{bx}$ $x = 1$ $x := f_{by} \le F_{by}$ $x = 1$

Check interaction equation for compression.

$\frac{f_a}{F_a} = 0.187$ Since the resultant is greater than 0.15, use the equation H1-1 per AISC 1989, page 5-54.

$F'_{ex} := \frac{12 \cdot \pi^2 \cdot E}{23 \cdot \left(\frac{k \cdot l}{r_x}\right)^2}$ $F'_{ex} = 45884.24 \cdot psi$ Euler stress for x axis bending divided by a factor of safety per AISC, page 5-54.

$F'_{ey} := \frac{12 \cdot \pi^2 \cdot E}{23 \cdot \left(\frac{k \cdot l}{r_y}\right)^2}$ $F'_{ey} = 45884.24 \cdot psi$ Euler stress for y axis bending divided by a factor of safety per AISC, page 5-54.

ICF KAISER
HANFORD COMPANY

DESIGN ANALYSIS

Calc. No.
Revision 0
Page No. 13 of

ent: Westinghouse Hanford Company
ubject: 241AZ Truss Buckling Analysis
Location: 200 E /

WO/Job No. C01909
Date: 06/28/95
Checked: 7/19/95
Revised:

By: B. L. Coverdell
By:
By:

$C_{mx} := 0.85$ Compression coefficient. Determined from AISC, page 5-55.

$C_{my} := C_{mx}$ Compression coefficient. Determined from AISC, page 5-55.

$$\frac{f_a}{F_a} + \frac{C_{mx} \cdot f_{bx}}{\left(1 - \frac{f_a}{F'_{ex}}\right) \cdot F_{bx}} + \frac{C_{my} \cdot f_{by}}{\left(1 - \frac{f_a}{F'_{ey}}\right) \cdot F_{by}} = 0.346$$

Since the resultant is less than or equal to 1, the beam is adequate to support the load per AISC 1989.

TS 1 1/2" x 1 1/2" x 1/8" Real Constant #12 in the finite-element model.

Properties of structural shape.

$l := 69.25 \cdot in$ maximum column length

$A := (1.5 \cdot in)^2 - (1.5 \cdot in - 0.25 \cdot in)^2$ $A = 0.688 \cdot in^2$ cross sectional area

$$I := \frac{(1.5 \cdot in)^4 - (1.5 \cdot in - 0.25 \cdot in)^4}{12} \quad I = 0.218 \cdot in^4$$

$$S := \frac{I}{\left(\frac{1.5 \cdot in}{2}\right)} \quad S = 0.291 \cdot in^3$$ section modulus about either axis

$$r_x := \sqrt{\frac{I}{A}} \quad r_x = 0.564 \cdot in$$ radius of gyration

$$r_y := \sqrt{\frac{I}{A}} \quad r_y = 0.564 \cdot in$$ radius of gyration

Determine the allowable stresses on the beam.

$\frac{k \cdot l}{r_y} = 122.859$ slenderness ratio

$F_a := 9870 \cdot psi$ Allowable axial compressive stress of the column from AISC, 1989, page 3-17 using 123 for kl/r (no interpolation).

$F_v := 0.4 \cdot Fy_{ts}$ $F_v = 18400 \cdot psi$ Allowable shear stress per AISC 1989, Page 5-49, F4-1.

$F_{bx} := 0.60 \cdot Fy_{ts}$ $F_{bx} = 27600 \cdot psi$ Allowable bending stress per AISC 1989, Page 5-49, F3-3, conservative.

$F_{by} := F_{bx}$ Square box.

ICF KAISER
HANFORD COMPANY

DESIGN ANALYSIS

Calc. No.
Revision 0
Page No. 14 of

ent: Westinghouse Hanford Company
ubject: 241AZ Truss Buckling Analysis
Location: 200 E /

WO/Job No. C01909
Date: 06/28/95
Checked: 7/19/95
Revised:

By: B. L. Coverdell
By:
By:

Determine the actual shear, axial and bending stresses in the shape and compare them with the allowables.

Axial forces and bending moments on the beam. Determined from the finite-element model AZTR_BLC11B, SRAC, 1993.

$F_r := 664.8 \cdot lbf$ $V_s := 276.5 \cdot lbf$ $V_t := 126.8 \cdot lbf$

$M_s := 785.7 \cdot lbf \cdot in$ $M_t := 1693.8 \cdot lbf \cdot in$

$f_a := \frac{F_r}{A}$ $f_a = 966.982 \cdot psi$ Maximum compressive stress in the beam.

$f_v := \frac{\sqrt{V_s^2 + V_t^2}}{A}$ $f_v = 442.456 \cdot psi$ Maximum shear stress in the beam.

$f_{bx} := \frac{M_t}{S}$ $f_{bx} = 5815.969 \cdot psi$ Maximum bending stress about major axis of beam.

$f_{by} := \frac{M_s}{S}$ $f_{by} = 2697.843 \cdot psi$ Maximum bending stress about major axis of beam.

$x := f_a \le F_a$ $x = 1$ $x := f_v \le F_v$ $x = 1$

$x := f_{bx} \le F_{bx}$ $x = 1$ $x := f_{by} \le F_{by}$ $x = 1$

Check interaction equation for compression.

$\frac{f_a}{F_a} = 0.098$ Since the resultant is less than 0.15, use the following equations per AISC, page 5-54.

$\frac{f_a}{F_a} + \frac{f_{bx}}{F_{bx}} + \frac{f_{by}}{F_{by}} = 0.406$ Since the resultant is less than or equal to 1, the beam is adequate to support the load per AISC 1989.

BAR 4" x 2" Real Constant #13 in the finite-element model.

Properties of bar.

$A := 4 \cdot in \cdot 2 \cdot in$ $A = 8 \cdot in^2$ cross sectional area

$l := 67 \cdot in$ maximum column length

Determine moment of inertia and section modulus.

$I_x := \frac{2 \cdot in \cdot (4 \cdot in)^3}{12}$ $I_x = 10.667 \cdot in^4$ moment of inertia about major axis

$I_y := \frac{4 \cdot in \cdot (2 \cdot in)^3}{12}$ $I_y = 2.667 \cdot in^4$ moment of inertia about minor axis

ICF KAISER
HANFORD COMPANY

Calc. No.
Revision 0
Page No. 15 of

DESIGN ANALYSIS

Client: Westinghouse Hanford Company
Subject: 241AZ Truss Buckling Analysis
Location: 200 E /

WO/Job No. C01909
Date: 06/28/95
Checked: 7/19/95
Revised:

By: B. L. Coverdell
By:
By:

$$S_x := \frac{I_x}{\left(\frac{4 \cdot in}{2}\right)} \qquad S_x = 5.333 \cdot in^3$$ section modulus about major axis

$$S_y := \frac{I_y}{\left(\frac{2 \cdot in}{2}\right)} \qquad S_y = 2.667 \cdot in^3$$ section modulus about minor axis

$$r_x := \sqrt{\frac{I_x}{A}} \qquad r_x = 1.155 \cdot in$$ radius of gyration

$$r_y := \sqrt{\frac{I_y}{A}} \qquad r_y = 0.577 \cdot in$$ radius of gyration

Determine the allowable stresses on the beam.

$\frac{k \cdot l}{r_y} = 116.047$ slenderness ratio

$F_a := 10850 \cdot psi$ Allowable axial compressive stress of the column from AISC, 1989, page 3-16 using 116 for kl/r (no interpolation).

$F_v := 0.4 \cdot Fy \qquad F_v = 14400 \cdot psi$ Allowable shear stress per AISC 1989, Page 5-49, F4-1.

$F_{bx} := 0.6 \cdot Fy \qquad F_{bx} = 21600 \cdot psi$ Allowable bending stress per AISC 1989, Page 5-48, F2-2.

$F_{by} := F_{bx}$ Rectangular solid member.

Determine the actual shear, axial and bending stresses in the shape and compare them with the allowables.

Axial forces and bending moments on the beam. Determined from the finite-element model AZTR_BLC11B, SRAC, 1993.

$F_r := 14744.8 \cdot lbf \qquad V_s := 5258.4 \cdot lbf \qquad V_t := 2325.0 \cdot lbf$

$M_s := 7624.3 \cdot lbf \cdot in \qquad M_t := 42070.2 \cdot lbf \cdot in$

$$f_a := \frac{F_r}{A} \qquad f_a = 1843.1 \cdot psi$$ Maximum compressive stress in the beam.

$$f_v := \frac{\sqrt{V_s^2 + V_t^2}}{A} \qquad f_v = 718.684 \cdot psi$$ Maximum shear stress in the beam.

$$f_{bx} := \frac{M_t}{S_x} \qquad f_{bx} = 7888.163 \cdot psi$$ Maximum bending stress about major axis of beam.

ICF KAISER
HANFORD COMPANY

DESIGN ANALYSIS

Calc. No.
Revision 0
Page No. 16 of

Client: Westinghouse Hanford Company
Subject: 241AZ Truss Buckling Analysis
Location: 200 E /

WO/Job No. C01909
Date: 06/28/95
Checked: 7/19/95
Revised:

By: B. L. Coverdell
By:
By:

$$f_{by} = \frac{M_s}{S_y} \qquad f_{by} = 2859.113 \cdot psi$$

Maximum bending stress about major axis of beam.

$x = f_a \le F_a$ $x = 1$ $x = f_v \le F_v$ $x = 1$

$x = f_{bx} \le F_{bx}$ $x = 1$ $x = f_{by} \le F_{by}$ $x = 1$

Check interaction equation for compression.

$$\frac{f_a}{F_a} = 0.17$$

Since the resultant is greater than 0.15, use the equation H1-1 per AISC 1989, page 5-54.

$$F'_{ex} = \frac{12 \cdot \pi^2 \cdot E}{23 \cdot \left(\frac{k \cdot l}{r_x}\right)^2} \qquad F'_{ex} = 45884.24 \cdot psi$$

Euler stress for x axis bending divided by a factor of safety per AISC, page 5-54.

$$F'_{ey} = \frac{12 \cdot \pi^2 \cdot E}{23 \cdot \left(\frac{k \cdot l}{r_y}\right)^2} \qquad F'_{ey} = 11471.06 \cdot psi$$

Euler stress for y axis bending divided by a factor of safety per AISC, page 5-54.

$C_{mx} = 0.85$ Compression coefficient. Determined from AISC, page 5-55.

$C_{my} = C_{mx}$ Compression coefficient. Determined from AISC, page 5-55.

$$\frac{f_a}{F_a} + \frac{C_{mx} \cdot f_{bx}}{\left(1 - \frac{f_a}{F'_{ex}}\right) \cdot F_{bx}} + \frac{C_{my} \cdot f_{by}}{\left(1 - \frac{f_a}{F'_{ey}}\right) \cdot F_{by}} = 0.627$$

Since the resultant is less than or equal to 1, the beam is adequate to support the load per AISC 1989.

RESULTS AND CONCLUSIONS:

The calculations combined with the finite-element model AZTR_BLC11B determined that all structural shapes and bars are adequate per AISC 1989.

REFERENCES:

AISC, 1989, *Manual of Steel Construction*, 9th Edition, American Institute of Steel Construction, Chicago, Illinois.

SRAC, 1993, *COSMOS/M*, Version 1.71, Structural Research and Analysis Corporations, Santa Monica, California.

MAXIMUM FORCES AND MOMENTS
per COSMOS/M model AZTR_BLC11B

REAL CONSTANT #1

* Selection List 1 Load case 53 Top Face
Elem FR
306 76444.9

* Selection List 1 Load case 53 Top Face
Elem VS
2 1597.94

* Selection List 1 Load case 53 Top Face
Elem VT
2 1665.21

* Selection List 1 Load case 53 Top Face
Elem MS
142 26969

* Selection List 1 Load case 53 Top Face
Elem MT
142 26093.7

REAL CONSTANT #2

* Selection List 1 Load case 53 Top Face
Elem FR
155 41495.4

* Selection List 1 Load case 53 Top Face
Elem VS
1670 1332.7

* Selection List 1 Load case 53 Top Face
Elem VT
1655 914.75

* Selection List 1 Load case 53 Top Face
Elem MS
178 15971.6

* Selection List 1 Load case 53 Top Face
Elem MT
393 9379.66

REAL CONSTANT #3 & 4

* Selection List 1 Load case 53 Top Face
Elem FR
230 17961.2

* Selection List 1 Load case 53 Top Face
Elem VS
1452 1131.86

* Selection List 1 Load case 53 Top Face
Elem VT
1439 922.078

* Selection List 1 Load case 53 Top Face
Elem MS
1201 5435.27

* Selection List 1 Load case 53 Top Face
Elem MT
1277 5333.93

REAL CONSTANT #7

* Selection List 1 Load case 53 Top Face
Elem FR
2513 2252.35

* Selection List 1 Load case 53 Top Face
Elem VS
2441 178.318

* Selection List 1 Load case 53 Top Face
Elem VT
2440 7.08987

* Selection List 1 Load case 53 Top Face
Elem MS
2440 45.7269

* Selection List 1 Load case 53 Top Face
Elem MT
2492 3464.73

REAL CONSTANT #9

* Selection List 1 Load case 53 Top Face
Elem FR
2751 3304.13

* Selection List 1 Load case 53 Top Face
Elem VS
2713 431.393

* Selection List 1 Load case 53 Top Face
Elem VT
2577 419.167

* Selection List 1 Load case 53 Top Face
Elem MS
2577 2563.69

* Selection List 1 Load case 53 Top Face
Elem MT
2713 2638.75

REAL CONSTANT #10

* Selection List 1 Load case 53 Top Face
Elem FR
143 120987

* Selection List 1 Load case 53 Top Face
Elem VS
261 1183

* Selection List 1 Load case 53 Top Face
Elem VT
261 1222.75

* Selection List 1 Load case 53 Top Face
Elem MS
260 64246.7

* Selection List 1 Load case 53 Top Face
Elem MT
260 62143.9

REAL CONSTANT #11

* Selection List 1 Load case 53 Top Face
Elem FR
1678 52855.4

* Selection List 1 Load case 53 Top Face
Elem VS
1683 1003.04

* Selection List 1 Load case 53 Top Face
Elem VT
273 465.895

* Selection List 1 Load case 53 Top Face
Elem MS
273 21676.1

* Selection List 1 Load case 53 Top Face
Elem MT
1683 18182.1

REAL CONSTANT #12

* Selection List 1 Load case 53 Top Face
Elem FR
2895 664.788

* Selection List 1 Load case 53 Top Face
Elem VS
2849 276.458

* Selection List 1 Load case 53 Top Face
Elem VT
2848 126.785

* Selection List 1 Load case 53 Top Face
Elem MS
2849 785.662

* Selection List 1 Load case 53 Top Face
Elem MT
2848 1693.79

SDS 7/19/95

REAL CONSTANT #13

* Selection List 1		Load case 53	Top Face
Elem	FR		
7875	14744.8		
* Selection List 1		Load case 53	Top Face
Elem	VS		
7899	5258.44		
* Selection List 1		Load case 53	Top Face
Elem	VT		
7889	2324.95		
* Selection List 1		Load case 53	Top Face
Elem	MS		
751	7624.26		
* Selection List 1		Load case 53	Top Face
Elem	MT		
7980	42070.2		

Appendix E: Weld Evaluation

THIS PAGE INTENTIONALLY
LEFT BLANK

It should be noted that all welds have been analyzed per Troitsky 1982, however all welds are either full penetration or a prequalified weld. These welds will develop the full strength of the base metals being connected. For this reason, all welds are adequate if the base metals are adequate.

Section 10.5.1: Local or "punching" shear failure (Bottom Tube -> Truss Tube).

Model Results					branch		Tube Info			main				allowable punching shear						actual punching shear			
Elem	P/A	MS/SS	MT/ST	sigma b	a	b	tb	theta	ax	D	tc	P/A (all)	sigma y	beta	Qbeta	U	Qf	gamma	tau all	Ka	Kb	tau act	MS
88	4722.132	1334.287	118.454	1341.507	2	4	0.3125	30.3	3.964104	8	0.375	12000	36000	0.666667	1.125	0.363511	1	8	8437.5	1.327351	2.26012	1990.37	3.239182
89	5807.573	352.378	356.8231	502.7731	2	4	0.3125	30.3	3.964104	8	0.375	12000	36000	0.666667	1.125	0.483964	0.978018	8	8232.025	1.327351	2.26012	2024.833	3.073208
116	4302.414	1756.055	50.4411	1756.779	2	4	0.3125	30.3	3.964104	8	0.375	12000	36000	0.666667	1.125	0.358534	1	8	8437.5	1.327351	2.26012	2010.539	3.196635
117	5370.866	256.0948	377.9085	458.5079	2	4	0.3125	30.3	3.964104	8	0.375	12000	36000	0.666667	1.125	0.447558	0.996221	8	8405.814	1.327351	2.26012	1859.494	3.498197
Bar->Truss																							
582	4423.868	528.1065	327.6617	621.5894	2	4	0.3125	30.3	3.964104	6	0.375	12000	36000	0.666667	1.125	0.368656	1	8	8437.5	1.327351	2.26012	1630.452	4.174845
598	2548.249	218.5927	240.3173	324.6517	2	4	0.3125	30.3	3.964104	6	0.375	12000	36000	0.666667	1.125	0.212354	1	8	8437.5	1.327351	2.26012	928.9409	8.102522
610	587.8607	404.1253	222.5878	461.3008	2	4	0.3125	30.3	3.964104	6	0.375	12000	36000	0.666667	1.125	0.047322	1	8	8437.5	1.327351	2.26012	349.8798	23.10455
611	3625.593	431.9082	116.1441	447.2527	2	4	0.3125	30.3	3.964104	6	0.375	12000	36000	0.666667	1.125	0.302132	1	8	8437.5	1.327351	2.26012	1313.315	5.424584
625	1567.158	248.6445	66.20567	266.2063	2	4	0.3125	30.3	3.964104	6	0.375	12000	36000	0.666667	1.125	0.130567	1	8	8437.5	1.327351	2.26012	595.312	13.17324
652	4424.332	531.5021	327.2741	624.1617	2	4	0.3125	30.3	3.964104	6	0.375	12000	36000	0.666667	1.125	0.368694	1	8	8437.5	1.327351	2.26012	1631.559	4.171447
668	2548.447	221.2841	239.6284	326.1724	2	4	0.3125	30.3	3.964104	6	0.375	12000	36000	0.666667	1.125	0.212371	1	8	8437.5	1.327351	2.26012	927.4868	8.097185
680	589.8434	411.131	221.1598	466.8406	2	4	0.3125	30.3	3.964104	6	0.375	12000	36000	0.666667	1.125	0.047495	1	8	8437.5	1.327351	2.26012	352.6599	22.92532
681	3629.103	431.0242	115.8962	446.3337	2	4	0.3125	30.3	3.964104	6	0.375	12000	36000	0.666667	1.125	0.302175	1	8	8437.5	1.327351	2.26012	1313.14	5.425437
695	1567.483	250.5963	66.11453	268.1093	2	4	0.3125	30.3	3.964104	6	0.375	12000	36000	0.666667	1.125	0.130624	1	8	8437.5	1.327351	2.26012	595.7257	13.1634

Section 10.5.1: Local or "punching" shear failure (Top Tube -> Truss Tube).

Model Results					Tube Info									allowable punching shear						actual punching shear			
Elem	P/A	MS/SS	MT/ST	sigma b	a	b	tb	theta	ax	D	tc	P/A (all)	sigma y	beta	Qbeta	U	Qf	gamma	tau all	Ka	Kb	tau act	MS
75	4774.835	888.1219	428.8514	788.3774	2	4	0.3125	30.3	3.964104	4	0.375	12000	36000	1	2.488783	0.6	0.92	5.333333	25758.9	1.327351	2.26012	1763.312	13.44441
102	5815.071	524.3252	281.1348	594.94	2	4	0.3125	30.3	3.964104	4	0.375	12000	36000	1	2.488783	0.6	0.92	5.333333	25758.9	1.327351	2.26012	2061.261	11.49649
103	4294.816	989.5493	290.7325	1012.201	2	4	0.3125	30.3	3.964104	4	0.375	12000	36000	1	2.488783	0.6	0.92	5.333333	25758.9	1.327351	2.26012	1733.83	13.85836
130	5376.195	385.5734	290.5334	482.78	2	4	0.3125	30.3	3.964104	4	0.375	12000	36000	1	2.488783	0.6	0.92	5.333333	25758.9	1.327351	2.26012	1861.558	12.69021
203	7004.477	536.8946	687.0909	871.8345	2	4	0.3125	30.3	3.964104	4	0.375	12000	36000	1	2.488783	0.6	0.92	5.333333	25758.9	1.327351	2.26012	2540.131	9.140778
231	6497.179	658.7981	642.9602	920.5274	2	4	0.3125	30.3	3.964104	4	0.375	12000	36000	1	2.488783	0.6	0.92	5.333333	25758.9	1.327351	2.26012	2367.597	9.744523
583	2555.747	240.7702	183.8314	302.9282	2	4	0.3125	30.3	3.964104	4	0.375	12000	36000	1	2.488783	0.6	0.92	5.333333	25758.9	1.327351	2.26012	921.2278	26.96149
597	575.8486	107.8897	69.03304	139.8523	2	4	0.3125	30.3	3.964104	4	0.375	12000	36000	1	2.488783	0.6	0.92	5.333333	25758.9	1.327351	2.26012	233.9129	109.1217
624	3618.085	248.0343	384.4913	457.5528	2	4	0.3125	30.3	3.964104	4	0.375	12000	36000	1	2.488783	0.6	0.92	5.333333	25758.9	1.327351	2.26012	1314.737	18.58243
636	1559.861	70.7468	152.3508	167.9753	2	4	0.3125	30.3	3.964104	4	0.375	12000	36000	1	2.488783	0.6	0.92	5.333333	25758.9	1.327351	2.26012	555.9568	45.33239
653	2555.944	241.9359	182.476	303.0384	2	4	0.3125	30.3	3.964104	4	0.375	12000	36000	1	2.488783	0.6	0.92	5.333333	25758.9	1.327351	2.26012	921.3311	26.95435
667	577.4409	106.8228	68.77483	138.8958	2	4	0.3125	30.3	3.964104	4	0.375	12000	36000	1	2.488783	0.6	0.92	5.333333	25758.9	1.327351	2.26012	234.1175	109.0255
694	3618.605	247.7582	385.1673	457.9716	2	4	0.3125	30.3	3.964104	4	0.375	12000	36000	1	2.488783	0.6	0.92	5.333333	25758.9	1.327351	2.26012	1315.056	18.58768
708	1559.989	67.54837	152.7052	166.9781	2	4	0.3125	30.3	3.964104	4	0.375	12000	36000	1	2.488783	0.6	0.92	5.333333	25758.9	1.327351	2.26012	555.6937	45.35449

Weld Analysis

Section 10.5.1: Local or "punching" shear failure (Bottom Tube -> 2x4 Studs).

Model Results					branch		Tube Info		main				allowable punching shear						actual punching shear			
Elem	P/A	MS/SS	MT/ST	sigma b	a	b	tb	theta	ax	D	tc	P/A (all)	sigma y	beta	Qbeta	U	Qf	gamma	tau all	Ka	Kb	tau act	MS
709	743.8140	2859.857	1035.602	3041.390	2	4	0.25	90	2	8	0.375	12000	36000	0.666667	1.125	0.081993	1	8	8437.5	1	1	2923.543	2.343514
723	384.9540	2546.192	1608.248	3009.868	2	4	0.25	90	2	8	0.375	12000	36000	0.666667	1.125	0.030413	1	8	8437.5	1	1	2249.849	2.750085
737	522.8574	1733.60	1826.414	2377.141	2	4	0.25	90	2	8	0.375	12000	36000	0.666667	1.125	0.043571	1	8	8437.5	1	1	1933.332	3.304227
751	550.2704	1554.230	961.7849	1838.355	2	4	0.25	90	2	8	0.375	12000	36000	0.666667	1.125	0.045856	1	8	8437.5	1	1	1562.417	4.296549
Bar->Stud																							
1421	61.61020	3208.654	1169.708	3415.81	2	4	0.25	90	2	8	0.375	12000	36000	0.666667	1.125	0.005134	1	8	8437.5	1	1	2318.28	2.639552
1435	50.23632	2956.79	1108.511	3185.916	2	4	0.25	90	2	8	0.375	12000	36000	0.666667	1.125	0.004187	1	8	8437.5	1	1	2157.436	2.910892
1449	193.5747	2622.80	1321.323	3207.758	2	4	0.25	90	2	8	0.375	12000	36000	0.666667	1.125	0.016131	1	8	8437.5	1	1	2267.555	2.720968
1463	200.3061	2935.74	1240.071	3187.130	2	4	0.25	90	2	8	0.375	12000	36000	0.666667	1.125	0.0167	1	8	8437.5	1	1	2258.356	2.736125
1477	238.75	1541.864	142.9854	1548.48	2	4	0.25	90	2	8	0.375	12000	36000	0.666667	1.125	0.019898	1	8	8437.5	1	1	1191.487	6.08149
1504	239.4411	1570.808	119.0447	1575.312	2	4	0.25	90	2	8	0.375	12000	36000	0.666667	1.125	0.019953	1	8	8437.5	1	1	1209.835	5.974088
1505	256.2883	1234.720	626.4489	1384.555	2	4	0.25	90	2	8	0.375	12000	36000	0.666667	1.125	0.021357	1	8	8437.5	1	1	1003.695	8.713261
1519	257.8651	1259.564	622.4521	1404.999	2	4	0.25	90	2	8	0.375	12000	36000	0.666667	1.125	0.021489	1	8	8437.5	1	1	1108.576	6.811114
1533	126.3481	1129.554	287.0711	1160.697	2	4	0.25	90	2	8	0.375	12000	36000	0.666667	1.125	0.010520	1	8	8437.5	1	1	858.0303	8.833568
1560	125.4807	1149.248	261.4547	1175.687	2	4	0.25	90	2	8	0.375	12000	36000	0.666667	1.125	0.010457	1	8	8437.5	1	1	867.4449	8.728843
1561	308.1959	670.1024	582.0405	887.3857	2	4	0.25	90	2	8	0.375	12000	36000	0.666667	1.125	0.025683	1	8	8437.5	1	1	707.1877	9.584062
1575	310.2023	696.2177	578.3321	897.4201	2	4	0.25	90	2	8	0.375	12000	36000	0.666667	1.125	0.02585	1	8	8437.5	1	1	805.0616	9.480305
1589	53.11584	423.3564	272.9718	503.4055	2	4	0.25	90	2	8	0.375	12000	36000	0.666667	1.125	0.004428	1	8	8437.5	1	1	371.0142	21.74172
1618	51.65371	436.7089	270.7889	513.8965	2	4	0.25	90	2	8	0.375	12000	36000	0.666667	1.125	0.004304	1	8	8437.5	1	1	377.0354	21.37853
1617	118.9518	2737.229	251.842	2748.79	2	4	0.25	90	2	8	0.375	12000	36000	0.666667	1.125	0.009740	1	8	8437.5	1	1	1910.494	3.416398
1644	115.8413	2856.228	230.6853	2867.018	2	4	0.25	90	2	8	0.375	12000	36000	0.666667	1.125	0.009537	1	8	8437.5	1	1	1855.109	3.548257

Section 10.5.1: Local or "punching" shear failure (Top Tube -> 2x4 Studs).

Model Results					branch		Tube Info		main				allowable punching shear						actual punching shear			
Elem	P/A	MS/SS	MT/ST	sigma b	a	b	tb	theta	ax	D	tc	P/A (all)	sigma y	beta	Qbeta	U	Qf	gamma	tau all	Ka	Kb	tau act	MS
722	34.60035	1780.057	427.2830	1840.343	2	3.99	0.125	90	2	4	0.375	12000	36000	0.9975	1.875	0.007717	1	5.333333	14400	1	1	832.3141	21.77549
736	789.2133	1484.078	1414.383	2050.112	2	3.99	0.125	90	2	4	0.375	12000	36000	0.9975	1.875	0.084101	1	5.333333	14400	1	1	639.7752	14.32281
750	76.81247	682.3820	215.3004	715.5419	2	3.99	0.125	90	2	4	0.375	12000	36000	0.9975	1.875	0.008401	1	5.333333	14400	1	1	264.1181	53.52109
764	638.3284	123.8112	1256.113	1262.2	2	3.99	0.125	90	2	4	0.375	12000	36000	0.9975	1.875	0.053194	1	5.333333	14400	1	1	633.5093	21.73053
Bar->Stud																							
1434	43.00648	1497.003	834.8281	1765.877	2	3.99	0.125	90	2	4	0.375	12000	36000	0.9975	1.875	0.003584	1	5.333333	14400	1	1	602.8955	22.88473
1448	34.65511	1385.659	677.3774	1640.07	2	3.99	0.125	90	2	4	0.375	12000	36000	0.9975	1.875	0.002888	1	5.333333	14400	1	1	558.2417	24.76528
1462	79.48419	1305.072	1058.432	1680.955	2	3.99	0.125	90	2	4	0.375	12000	36000	0.9975	1.875	0.006622	1	5.333333	14400	1	1	586.8083	23.53962
1476	73.95045	1259.132	1052.182	1640.887	2	3.99	0.125	90	2	4	0.375	12000	36000	0.9975	1.875	0.006163	1	5.333333	14400	1	1	571.6124	24.1919
1490	896.1103	843.8414	2222.107	2414.249	2	3.99	0.125	90	2	4	0.375	12000	36000	0.9975	1.875	0.074676	1	5.333333	14400	1	1	1103.453	12.04994
1491	892.9588	917.6002	2233.100	2414.284	2	3.99	0.125	90	2	4	0.375	12000	36000	0.9975	1.875	0.074413	1	5.333333	14400	1	1	1102.413	12.06225
1518	20.81397	1499.518	190.0718	1501.564	2	3.99	0.125	90	2	4	0.375	12000	36000	0.9975	1.875	0.001734	1	5.333333	14400	1	1	507.4683	27.3761
1532	20.72987	1462.198	192.0783	1474.76	2	3.99	0.125	90	2	4	0.375	12000	36000	0.9975	1.875	0.001727	1	5.333333	14400	1	1	498.4969	27.88688
1546	568.0173	639.869	250.2774	687.0743	2	3.99	0.125	90	2	4	0.375	12000	36000	0.9975	1.875	0.047335	1	5.333333	14400	1	1	418.3639	33.4198
1547	567.5472	626.8633	250.8629	675.1982	2	3.99	0.125	90	2	4	0.375	12000	36000	0.9975	1.875	0.047296	1	5.333333	14400	1	1	414.2478	33.7616
1574	18.39772	558.2058	41.88335	559.8498	2	3.99	0.125	90	2	4	0.375	12000	36000	0.9975	1.875	0.001533	1	5.333333	14400	1	1	192.7482	73.70849
1588	18.2627	548.5784	43.18311	548.28	2	3.99	0.125	90	2	4	0.375	12000	36000	0.9975	1.875	0.001522	1	5.333333	14400	1	1	188.8478	75.25197
1602	552.9803	215.6208	232.6255	317.186	2	3.99	0.125	90	2	4	0.375	12000	36000	0.9975	1.875	0.046062	1	5.333333	14400	1	1	290.0555	48.84568
1603	551.8035	233.2753	234.9227	331.0086	2	3.99	0.125	90	2	4	0.375	12000	36000	0.9975	1.875	0.045984	1	5.333333	14400	1	1	294.29	47.83132
1630	32.81394	1424.521	166.4705	1434.448	2	3.99	0.125	90	2	4	0.375	12000	36000	0.9975	1.875	0.002734	1	5.333333	14400	1	1	489.0674	28.44259
1631	33.19148	1445.076	174.5002	1455.574	2	3.99	0.125	90	2	4	0.375	12000	36000	0.9975	1.875	0.002760	1	5.333333	14400	1	1	498.255	28.01734

Weld Analysis (continued)

THIS PAGE INTENTIONALLY
LEFT BLANK

Appendix F: Overturning Analysis

THIS PAGE INTENTIONALLY
LEFT BLANK

KAISER ENGINEERS HANFORD

Calc. No. N/A
Revision 0
Page No. of

DESIGN ANALYSIS

ient Westinghouse
subject 241 AZ Trough Analysis
Location 200 E

WO/Job No. C01909
Date 9/27/95
Checked 9/28/95
Revised

By Mark Axup
By Theresa Peterson
By

OVERTURNING WIND CALCULATION FOR 50 TON HYDRAULIC TRAILER

OBJECTIVE:

Check adequacy of trussed structure (trough) against overturning due to wind for the following two load cases:

1. Strongback and 36" truss in vertical position without carriage.
2. Strongback and 36" truss in vertical position without carriage but with a 5000 lb. load concentrated at top and offset 1 foot.

Overturning wind calculations have originally been done by Jordan Engineering for the 50 ton hydraulic trailer carrying a solid 4.5 ft. dia. cylinder in the vertical position. The design wind pressure, without the force coefficient C_f, was 10 psf. which conservatively corresponds with a 45 mph wind for safety class 3 structure in exposure category C as shown below. A 45 mph wind is the maximum allowable wind speed for operation of the trailer as stated in section 2.2 of the Westinghouse Hydraulic Trailer Operation Manual, vendor information manual no. 22642.

$q_z = 0.00256K_z(IV)^2$ See (Eq.3), ASCE 7-93
where $I = 1.07$
$V = 45$
$K_z = 1.29$ @ 80 ft.

$q_z = 7.66$ psf use 10.0 psf

The Jordan Engineering overturning calculations are contained in Westinghouse 50 Ton Hydraulic Trailer, Final Submittal Specification WHC-S-0256, Rev. 2, vendor information manual no. 22642. These pages are also duplicated and included in this calculation as pages F-5 through F-7.

This calculation will qualify the above two load cases using the same trailer dimensions as per the original calculation by Jordan Engineering. The design wind load of 10 psf. will be modified in accordance with the wind analysis method contained in ASCE 7-93 to reflect the unique structural geometry of the trussed trough as shown on drawings H-2-83768 shts. 1-9.

Design loading:

Weight of trailer + strongback — See page F-6

35,000 + 15,000 = 50,000 lbs.

Weight of 36" truss = 10,640 lbs. — See CC:Mail message from Tom Mackey, page F-8

ASCE 7-93 design wind pressures.

$F = q_z G_h C_f A_f$ — See "Other Structures", table 4

$q_z G_h = 10$ psf. — As stated above.

C_f is determined from table 15 for trussed triangular towers and is a function of the ratio of the solid area to gross area of tower face.

KAISER ENGINEERS HANFORD

Calc. No. N/A
Revision 0
Page No. of

DESIGN ANALYSIS

ient Westinghouse
Subject 241 AZ Trough Analysis
Location 200 E

WO/Job No. C01909
Date 9/27/95
Checked 9/28/95
Revised

By Mark Axup
By Theresa Peterson
By

Wind Overturning Analysis: (Cont'd.)

Conservatively, check ratio of solids to gross for truss as depicted on view C, sht. 3 of H-2-83768. For members shown with an asterisk, (*), see section B, sht. 5.

Typical section between col. lines spaced at approx. 5'-9" consists of the following members. Approximate depth of truss is 3'-9".

Member Description	Area ($ft.^2$)
TS $4x4x^3/_8x5'-9"$ (horizontal)	1.917
TS $6x6x^3/_8x5'-9"$ (horizontal)	2.875
TS $4x2x^1/_4x3'-4"$ (vertical)	0.556
TS $4x2x^5/_{16}x7'-0"$ (diagonal)	1.167
*TS $1^1/_2x1^1/_2x^1/_8x5'-6"$ (rotated 45 deg.)	0.972
*TS $2^1/_2x1^1/_2x^3/_{16}x5'-6"$ (doubled, rotated 45 deg.)	1.789
*L $2x2x^1/_4x5'-6"$ (rotated 45 deg.)	1.296
Total	10.573

Gross Area = 5.75 x 3.75 = 21.562 $ft.^2$

$\frac{\text{Solid Area}}{\text{Gross Area}} = \frac{10.573}{21.562} = 0.49$ Therefore, from table 15, $C_f = 1.7$

A review of original wind overturning calculations by Jordan Engineering shows that the basic wind pressure of 10 psf was modified (multiplied) by force coefficients of 1.0 for the upper circular part of the cannister and 1.4 for the lower portion including the strongback. This calculation will use the same methodology and conservatively use $C_f = 1.7$ for the entire length of the raised vertical trough. For the strongback, use $C_f = 1.05$ (interpolating from table 12)

Length of strongback = 24.5 ft.

Length of trough extending past strongback = 39.0 ft.

Extension of outriggers from center of trailer = 8.0 ft.

Top wind load area = 3.75 x 39.0 x 0.49 = 71.66 ft^2

Bottom wind load area = 7.43 x 24.5 x 1.0 = 182.1 ft^2

Top wind load = 71.66 x 10.0 x 1.7 = 1218.26 lbs.

Bottom wind load = 182.1 x 10.0 x 1.05 = 1912.05 lbs.

KAISER ENGINEERS HANFORD

Calc. No. N/A
Revision 0
Page No. of

DESIGN ANALYSIS

ient Westinghouse
Subject 241 AZ Trough Analysis
Location 200 E

WO/Job No. C01909
Date 9/27/95
Checked 9/28/95
Revised

By Mark Axup
By Theresa Peterson
By

Wind Overturning Analysis: (Cont'd.)

Check Load Cases:

Load Case 1

Wind OT moment = (1218.26 x 51.5) + (1912.05 x 19.75) = 100,503.4 ft-lbs.

Dead weight resisting moment = (50,000 + 10,640) x 8.0 = 485,120.0 ft-lbs.

F.S. against overturning = $\frac{485,120.0}{100,503.4}$ = 4.83

Load Case 2

OT moment (wind + offset load) = 100,503.4 + 5000.0 x 1.0 = 105,503.4 ft-lbs.

Dead weight resisting moment = 485,120.0 + 5000.0 x 7.0 = 520,120.0 ft-lbs.

F.S. against overturning = $\frac{520,120.0}{105,503.4}$ = 4.93

OVERTURNING DUE TO WIND LOADING WITH THE STRONG BACK IN THE VERTICAL POSITION

SUM Fy = ORL-25200 LBS (62' TRANSPORT ASSY.)-15000 LBS (STRONG BACK ASSY)-35,000 LBS TRAILER ASSY=0

ORL=OUTRIGGER LOADING VERTICAL= 75,200 LBS.

ASSUME THAT EACH SIDE IS EQUAL SO THAT EACH SET OF OUTRIGGERS SEES 1/2 ORL OR 37,600 LBS.

THE TOP LOAD OF 6500 LBS. WAS REMOVED FOR THIS CALCULATION



TRAILER OVERTURNING FORCE DIAGRAM

USE PAGE 50&51 FOR OUTRIGGER LOADING

WIND LOADS USED ARE AS FOLLOWS

TOP WIND LOAD AREA = 4.5 FT. X 39' = 175.5 sq.ft.

BOTTOM WIND LOAD AREA = 5.58' X 24.5 ' = 136.7 sq.ft.

TOP WIND LOAD = 175.5 sq.ft. x 10 lb/sq.ft. = *1755 lbs.*

BOTTOM WIND LOAD = 136.7 sq.ft. x 14 lbs./sq. ft.= *1913 lbs*

SUM OF THE MOMENTS ABOUT THE OFF SIDE OUTRIGGER

TRL=TRAILER LOAD (lbs.)
SB = STRONG BACK LOAD (lbs.)
TP = TRANSPORT ASSY 62' (lbs.)
WLT= WIND LOAD AT THE TOP OF THE TRANSPORT ASSY. (lbs.)
WLB = WIND LOAD AT THE BOTTOM OF THE ASSY. (lbs.)
DIST1= DISTANCE FROM THE FOOT OF THE OUTRIGGER TO THE PERPENDICULAR OF THE CG OF TRL,SB,AND TP.(in.)
DIST2 = DISTANCE FROM THE OUTRIGGER FOOT TO THE PERPENDICULAR OF THE REACTION FORCE FROM THE TOP WIND LOAD REACTION (lbs.)
DIST3 = DISTANCE FROM THE OUTRIGGER FOOT TO THE PERPENDICULAR OF THE BOTTOM LOAD REACTION(in.)
OVM = OVER TURN MOMENT
WM = WIND MOMENT

OVM = DIST1 * (TRL+SB+TP) = 96 *(35000 + 15000 +25200) = *7,219,200 in-lbs.*
WM = DIST2*WLT +DIST3*WLB = 618*-1755 +237*-1950 = *1,546,740 in-lbs.*

SHOWS THAT "FACTOR OF SAFTEY FOR OVERTURNING"

F.S.O.T. =7,219,200/1,546,740 = *4.67 TO 1*

Author: Thomas C Mackey at ~WHC396
Date: 8/18/95 7:14 AM
Priority: Normal
TO: Bradford L Coverdell at ~WHC240
TO: John L Julyk at ~KEH16
TO: Mark D Axup at ~KEH16
CC: Richard N Kyle at ~WHC239
CC: Kenneth D Junt at ~WHC339
CC: Thomas C Mackey
CC: Theresa K Peterson at ~KEH7
Subject: 101-AZ Truss Weight

---------- Message Contents ----------

FYI

The weight of the subject 20" truss (trough) is 11,960#.
The weight of the 36" is 10,640#.

These are the weights painted on the equipment.

TCM

THIS PAGE INTENTIONALLY
LEFT BLANK

Appendix G: Frequency Analysis

THIS PAGE INTENTIONALLY
LEFT BLANK

INTRODUCTION

This set of calculations is used to determine the adequacy of the trough to resist the effects resonance due to vortex shedding.

SUMMARY OF RESULTS

From the FEA model it was determined that the natural frequency of the loaded trough is 4.2 hz. Hand calculations show that the driving frequency due to vortex shedding will range between 1.8 and 2.8 hz. The driving frequency range is due to the transition between laminar and turbulent flow.

DESCRIPTION

The trough is a 64 ft long device used in the process of removing equipment from highly radioactive waste tanks. It was deemed possible for resonance due to vortex shedding to occur. For this reason, a FEA model of the loaded trough was created to determine its' natural frequency. Hand calculation were used to determined the driving frequency due to vortex shedding. The two frequencies are then compared to determine if resonance could occur.

RESULTS/CONCLUSIONS

From comparison of the trough natural frequency (4.2 hz) to the driving frequency due to vortex shedding (1.8 to 2.8 hz), it is apparent that they are far enough apart to preclude resonance.

```
**********************************************************************
**********************************************************************
**                                                                  **
**                                                                  **
**  CCCC   0000   SSSS   M     M   0000   SSSS     / M     M  **
**  C      0  0   S      MM   MM   0  0   S       /  MM   MM  **
**  C      0  0   SSSS   M M M M   0  0   SSSS   /   M M M M  **
**  C      0  0      S   M  M  M   0  0      S  /    M  M  M  **
**  CCCC   0000   SSSS   M     M   0000   SSSS /     M     M  **
**                                                                  **
**                                                                  **
**                       VERSION:  1.71                             **
**                     DISTRIBUTED BY:                              **
**      STRUCTURAL  RESEARCH  AND  ANALYSIS  CORPORATION            **
**                 2951 28TH STREET SUITE 1000                      **
**             SANTA MONICA,   CALIFORNIA    90405                  **
**                TEL. NO.   (310)  452-2158                        **
**               COPYRIGHT  1988   S. R. A. C.                      **
**                                                                  **
**********************************************************************
**********************************************************************

Licensed to :
Problem name: AZTR_BLC11B_FREQ
Date        : 08/24/1995     Time:   07:13:26
Title       :
      |
Subtitle    :


  C O N T R O L   I N F O R M A T I O N
   NUMBER OF LOAD CASES  . . . . . (NLCASE)  =        1
   SOLUTION MODE . . . . . (MODEX)   =        2
      EQ. 0, STATIC ANALYSIS
      EQ. 1, BUCKLING ANALYSIS
      EQ. 2, DYNAMIC ANALYSIS
   THERMAL LOADING FLAG . . . . . .(ITHERM)  =        0
      EQ. 0, NO THERMAL EFFECTS CONSIDERED
      EQ. 1, ADD TEMPERATURE EFFECT
   GRAVITY LOADING FLAG . . . . . .(IGRAV)   =        0
      EQ. 0, NO GRAVITY LOADING CONSIDERED
      EQ. 1, ADD GRAVITY LOADING EFFECT
   CENTRIFUGAL LOADING FLAG . . . . . .(ICNTRF)  =        0
      EQ. 0, NO CENTRIFUGAL LOADING CONSIDERED
      EQ. 1, ADD CENTRIFUGAL LOADING EFFECT
   IN-PLANE STIFFENING FLAG . . . . . .(INPLN)   =        0
      EQ. 0, NO IN-PLANE EFFECTS CONSIDERED
      EQ. 1, IN-PLANE EFFECTS CONSIDERED
```

```
 SOFT SPRING ADDITION FLAG . . . . . (ISOFT)   =        0
    EQ. 0, NO SOFT SPRING OPTION
    EQ. 1, SOFT SPRING ADDED

 SAVE DECOMPOSED STIFFNESS MATRIX FLAG . . . (ISAVK)   =        0
    EQ. 0, DO NOT SAVE DECOMPOSED K
    EQ. 1, SAVE DECOMPOSED K
 FORM STIFFNESS MATRIX FLAG . . . . . .(IFORMK)  =        0
    EQ. 0, FORM STIFFNESS MATRIX
    EQ. 1, USE EXIST DECOMPOSED STIFFNESS MATRIX

T O T A L  S Y S T E M  D A T A
 NUMBER OF EQUATIONS . . . . . .(NEQ)  =    43640
 NUMBER OF MATRIX ELEMENTS . . . . . .(NWK)  = 25917887
 MAXIMUM HALF BANDWIDTH . . . . . (MK )  =     1794
 MEAN HALF BANDWIDTH . . . . . .(MM )  =      593
 NUMBER OF ELEMENTS. . . . . .(NUME) =     7999
 NUMBER OF NODAL POINTS. . . . . .(NUMNP)=     7281
 ADJUSTED BLOCK SIZE . . . . . .(MTBLK)=   372049
 NUMBER OF STIFFNESS BLOCKS. . . . . (NBLK) =       70



 MAXIMUM DIAGONAL STIFFNESS MATRIX VALUE =  0.926177E+10 ( 40693)
 MINIMUM DIAGONAL STIFFNESS MATRIX VALUE =  0.110997E+06 (  8575)
1

 ---------------------------------------------------------------------
 |           M A S S   M O M E N T   I N F O R M A T I O N           |
 |-------------------------------------------------------------------|
 |MASS    0.299103E+02   |VOLUME  0.409744E+05   |WEIGHT  0.000000E+00  |
 |-------------------------------------------------------------------|
 | MASS MOMENT OF INERTIA W.R.T. C.G.                                |
 |-------------------------------------------------------------------|
 |IX      0.154052E+05   |IY      0.136532E+07   |IZ      0.135834E+07  |
 |-------------------------------------------------------------------|
 | MASS PRODUCT OF INERTIA W.R.T. C.G.                               |
 |-------------------------------------------------------------------|
 |PXY     0.286927E+04   |PXZ    -0.243830E-02   |PYZ    -0.265892E-01  |
 |-------------------------------------------------------------------|
 | RADII OF GYRATION W.R.T. C.G.                                     |
 |-------------------------------------------------------------------|
 |RX      0.226946E+02   |RY      0.213652E+03   |RZ      0.213105E+03  |
 |-------------------------------------------------------------------|
 | CENTER OF GRAVITY                                                 |
 |-------------------------------------------------------------------|
 |CGx     0.349781E+03   |CGy     0.153938E+02   |CGz     0.521111E-06  |
 |-------------------------------------------------------------------|
 | PRINCIPAL MASS MOMENT OF INERTIA                                  |
```

P1	0.136533E+07	P2	0.135834E+07	P3	0.153991E+05

PRINCIPAL RADII OF GYRATION

R1	0.213652E+03	R2	0.213105E+03	R3	0.226901E+02

PRINCIPAL AXES (DIRECTION COSINES IN ROWS W.R.T C.G)

N_11	0.212550E-02	N_12	-0.999998E+00	N_13	-0.380677E-05
N_21	-0.855476E-05	N_22	0.400484E-02	N_23	0.999992E+00
N_31	-0.999990E+00	N_32	-0.212548E-02	N_33	-0.424487E-07

S O L U T I O N P A R A M E T E R S

NUMBER OF EIGENVALUES.	(NFR)=	5
MASS TYPE: 1-LUMPED,2-CONSISTENT. . . .	(MASS)=	1
MODE SHAPE PRINT FLAG.	(MPRNT)=	0
INTERMEDIATE SOLUTION PRINT FLAG	(IFPR)=	0
STURM SEQUENCE CHECK FLAG.	(IFSS)=	0
MAXIMUM NUMBER OF ITERATIONS	(ITMAX)=	16
FREQUENCY SHIFT FLAG	(IFRSH)=	0
FREQUENCY SHIFT.	(FRSH)=	0.0000000E+00
CONVERGENCE TOLERANCE.	(RTOL)=	0.1000000E-04
COMPOSITE MODAL DAMPING CALC. FLAG . . .	(IMDC)=	0
MODAL ACCELERATION FLAG.	(IMAM)=	0

S U B S P A C E I T E R A T I O N

ITERATION NUMBER 1

ITERATION NUMBER 2

ITERATION NUMBER 3

ITERATION NUMBER 4

ITERATION NUMBER 5

ITERATION NUMBER 6

ITERATION NUMBER 7

CONVERGENCE REACHED FOR RTOL 0.1000E-04

F R E Q U E N C Y A N A L Y S I S
by
S U B S P A C E A L G O R I T H M

FREQUENCY NUMBER	FREQUENCY (RAD/SEC)	FREQUENCY (CYCLES/SEC)	PERIOD (SECONDS)
1	0.2610489E+02	0.4154722E+01	0.2406900E+00
2	0.2762723E+02	0.4397010E+01	0.2274273E+00
3	0.5331185E+02	0.8484845E+01	0.1178572E+00
4	0.8672043E+02	0.1380198E+02	0.7245335E-01
5	0.1205615E+03	0.1918796E+02	0.5211601E-01

S O L U T I O N T I M E L O G (sec)

INPUT PHASE	19
ASSEMBLAGE OF THE STIFFNESS MATRIX	54
ASSEMBLAGE OF THE MASS MATRIX	0
DECOMPOSITION OF THE STIFFNESS MATRIX	2312
EIGENVALUE SOLUTION	1858
OUTPUT PHASE	13
TOTAL SOLUTION TIME	4256

ICF KAISER
HANFORD COMPANY

DESIGN ANALYSIS

Calc. No.
Revision 0
Page No. 1 of

ənt: Westinghouse Hanford Company
ubject: 241AZ Truss Analysis
Location: 200 E /

WO/Job No. C01909
Date: 06/28/95
Checked: 9/29/95
Revised:

By: B. L. Coverdell
By:
By:

PURPOSE:

This section of calculations is used to determine the excitation frequency of the container due to wind.

CONSIDERATIONS:

1) Vortex shedding off the cylindrical carriage is worse off the sparse frame of the trough.

DESCRIPTION:

The excitation frequency due to wind on the trough and cylindrical carriage assembly is caused by vortex shedding. Vortex shedding causes a periodic change in side pressure on the cylindrical carriage. The equations determining the frequency of the change in side pressure were determined from Blevins 1977.

CALCULATIONS

$V_0 := 15 \cdot mph$ Maximum wind velocity that the trough and carriage will be rotated into the vertical position.

$d := 28 \cdot in$ Diameter of the carriage.

$\rho := 0.00234 \cdot 32.2 \cdot \frac{lb}{ft^3}$ Density of air at standard temperature and pressure (converted from slugs to pounds-mass).

$\mu := 3.78 \cdot 10^{-7} \cdot \frac{lbf \cdot sec}{ft^2}$ Viscosity of air at standard temperature and pressure.

$Re := \frac{V_0 \cdot d \cdot \rho}{\mu}$ $Re = 3.18 \cdot 10^5$ Reynolds number.

$S := \begin{pmatrix} .19 \\ .3 \end{pmatrix}$ Strouhal numbers determined from the graph of Reynolds number versus Strouhal number on page 15 of Blevins 1977. Due to the spread of data, the strouhal number has an upper and lower bound

$n := \frac{S \cdot V_0}{d}$

$n = \begin{pmatrix} 1.791 \\ 2.829 \end{pmatrix} \cdot hz$ The range of excitation frequency.

RESULTS AND CONCLUSIONS:

The range of excitatation frequencies combined with the natural frequency output from the finite element analysis model AZTR_BLC11B_FREQ shows that resonance should not occur.

REFERENCES:

Blevins R. D., 1977, *Flow-Induced Vibration*, Van Norstrand Reinhold and Company, New York, New York.

Appendix H: Carriage Maximum Wheel Load Calculations

THIS PAGE INTENTIONALLY
LEFT BLANK

ICF KAISER
HANFORD COMPANY

DESIGN ANALYSIS

Calc. No.
Revision 0
Page No. 1 of

ent: Westinghouse Hanford Company
Subject: 241AZ Trough Analysis
Location: 200 E /

WO/Job No. C01909
Date: 06/28/95
Checked: 9/29/95
Revised:

By: B. L. Coverdell
By:
By:

PURPOSE:

This set of calculations determines the maximum allowable carriage wheel load on the two 2 1/2 x 1 1/2 x 3/16 TS.

CALCULATIONS:

$L := 69.25 \cdot in$ Maximum length of tube steel to be analyzed (WHC 1995a and WHC 1995b).

$c := \frac{2.5 \cdot in}{2}$ Distance to outer fiber (WHC 1995a and WHC 1995b).

$I_{xx} := 2.107 \cdot in^4$ Moment of inertia about loaded axis (Appendix D, Page D-1).

$\sigma := 0.6 \cdot 36000 \cdot psi$ $\sigma = 2.16 \cdot 10^4 \cdot psi$ The maximum allowable stress in the tubular section per AISC 1989.

$M_{max} := \frac{\sigma \cdot I_{xx}}{c}$ $M_{max} = 3.641 \cdot 10^4 \cdot in \cdot lbf$ The maximum allowable bending moment in the beam.

$P_{max} := \frac{8 \cdot M_{max}}{L}$ $P_{max} = 4.206 \cdot 10^3 \cdot lbf$ The maximum allowable point load (carriage wheel load) in a beam fixed at either end per AISC 1989, page 3-125.

$\frac{P_{max}}{2} = 2.103 \cdot 10^3 \cdot lbf$ If an added factor-of-safety of 2 is preferred, then the maximum wheel load is 2100 lbf.

RESULTS AND CONCLUSIONS:

The 2 1/2 x 1 1/2 x 3/16 TS is adequate to support a maximum carriage wheel load of 2100 lbf.

REFERENCES:

AISC, 1989, *Manual of Steel Construction,* Ninth Edition, American Institute of Steel Construction, Chicago, Illinois.

WHC, 1995a, *Trough Assembly 36 in. Dia. x 64 ft Long,* drawing H-2-83768 Rev 0, Westinghouse Hanford Company, Richland, Washington.

WHC, 1995b, *Trough Assembly 20 in. Dia. x 64 ft Long,* drawing H-2-83769 Rev 0, Westinghouse Hanford Company, Richland, Washington.

THIS PAGE INTENTIONALLY
LEFT BLANK

Appendix I: Connection Calculations

THIS PAGE INTENTIONALLY
LEFT BLANK

INTRODUCTION

The data in this appendix is used to determine the maximum reaction force by the loaded trough on the strongback. The reaction force data is then used to determine the adequacy of the four 1 in A325 bolts.

SUMMARY OF RESULTS

From the FEA model output contained in this appendix, the maximum tensile load is 7,500 lbf and the maximum shear load is 20,600 lbf.

DESCRIPTION

The plot on the following page shows the nodes and the displacement boundary conditions applied to the FEA model AZTR_BLC11B. The displacement boundary conditions located closest to the origin represent the lower attachment points of the trough and those farthest away from the origin represent the upper attachments points. The plot is used to inform the reader as to the location of the reaction forces listed on the following pages. The reaction force listing output was used to determine the maximum force on the bolts. From this output it was quickly determined that any applied loading by the trough is less than that applied by the 241C106 shipping container.

RESULTS/CONCLUSIONS

The comparison of the reaction forces contained in this document to the ERS-W320 design connection load shows that the four A325 bolts are adequate to connect the trough to the strongback.



Plot of Reaction Forces and Respective Nodes

Reaction Forces from Load Case 10

Node	Csid	RFX	RFY	RFZ	RMX	RMY	RMZ
2786	0	-	1.03e+04	0.00e+00	-	-	-
2787	0	-	1.03e+04	0.00e+00	-	-	-
2788	0	5.12e-06	-1.63e+03	2.35e+03	-	-	-
3030	0	-5.03e-06	-1.63e+03	-2.35e+03	-	-	-

Reaction Forces from Load Case 51

Node	Csid	RFX	RFY	RFZ	RMX	RMY	RMZ
2786	0	-	1.17e+04	0.00e+00	-	-	-
2787	0	-	1.29e+04	0.00e+00	-	-	-
2788	0	1.23e+04	-3.79e+03	5.20e+03	-	-	-
3030	0	-1.23e+04	-2.97e+03	-3.27e+03	-	-	-

Reaction Forces from Load Case 52

Node	Csid	RFX	RFY	RFZ	RMX	RMY	RMZ
2786	0	-	1.17e+04	0.00e+00	-	-	-
2787	0	-	1.29e+04	0.00e+00	-	-	-
2788	0	1.23e+04	-3.84e+03	5.26e+03	-	-	-
3030	0	-1.23e+04	-3.02e+03	-3.34e+03	-	-	-

Reaction Forces from Load Case 53

Node	Csid	RFX	RFY	RFZ	RMX	RMY	RMZ
2786	0	-	1.33e+04	0.00e+00	-	-	-
2787	0	-	1.36e+04	0.00e+00	-	-	-
2788	0	1.23e+04	-5.70e+03	7.17e+03	-	-	-
3030	0	-1.23e+04	-4.68e+03	-5.25e+03	-	-	-

Reaction Forces from Load Case 54

Node	Csid	RFX	RFY	RFZ	RMX	RMY	RMZ
2786	0	-	1.29e+04	0.00e+00	-	-	-
2787	0	-	1.41e+04	0.00e+00	-	-	-
2788	0	1.23e+04	-5.60e+03	7.26e+03	-	-	-
3030	0	-1.23e+04	-4.78e+03	-5.34e+03	-	-	-

Reaction Forces from Load Case 55

Node	Csid	RFX	RFY	RFZ	RMX	RMY	RMZ
2786	0	-	-5.03e+02	0.00e+00	-	-	-
2787	0	-	7.15e+02	0.00e+00	-	-	-
2788	0	2.06e+04	-5.16e+02	1.40e+03	-	-	-
3030	0	-4.06e+03	3.04e+02	5.24e+02	-	-	-